



TATA POWER-DDL

TPDDL/REGULATORY/2025-26/03/ 189
Aug 05, 2025

Office of the Head (Regulatory)

The Secretary

Delhi Electricity Regulatory Commission
Viniyamak Bhawan, C-Block, Shivalik
Malviya Nagar, New Delhi-110017

Subject: Submission of details of electrical accidents and action taken in line with DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 for the month of July 2025.

Dear Sir,

The Hon'ble Commission had notified the DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 which was published in the official gazette on 26.07.2024. With their publication in the official gazette, these Regulations have come into force from 26.07.2024 as provided in these Regulations.

Further, these Regulations provide for submission to the Hon'ble Commission by 15th of every succeeding month, the details of electrical accidents occurring within the respective jurisdiction of the distribution licensee and action taken thereon in accordance with these Regulations. Same is reproduced below for ready reference:

"18. Information to the Commission: -

The generating company or transmission licensee or distribution licensee shall submit to the Commission by 15th of every succeeding month, the details of electrical accidents occurring within their respective jurisdiction and action taken thereon in accordance with these Regulations."

Accordingly, Tata Power-DDL is submitting the report, enclosed herewith as **Annexure-1**, for the month of July 2025 i.e. 01.07.2025 to 31.07.2025.

We hope the Hon'ble Commission would find the above in order.

Yours Sincerely,

For Tata Power Delhi Distribution Ltd.

Ritu Gupta
Head (Regulatory)

TATA POWER DELHI DISTRIBUTION LIMITED

(A Tata Power and Delhi Government Joint Venture)

Regd. & Corp. Office : NDPL House Hudson Lines Kingsway Camp Delhi - 110 009

Website : www.tatapower-ddl.com CIN No. : U40109DL2001PLC111526

Email : tpddl@tatapower-ddl.com Tel. : 011-6611 2272

Annexure-1

S No.	Date of Incident	Zone/ District	Address/ Location	Brief Detail	TPDDL network involved?	Fatal/ non-fatal	Remarks
1	30.07.2025	Zone – 519 (D- Mangolpuri)	House No 209 B BLK-B RAJEEV NAGAR VILLAGE BEGAMPUR CITY DELHI 110086 (as per TPDDL record CA no- 60011461120)	On 30.07.2025, at approximately 10:48 PM, a complaint (Complaint No.:2041970654) was received at the TPDDL Call Centre regarding current leakage at House No.209, Block-B, Rajeev Nagar Village Begampur, Delhi -110086. The Telephone Operator (TO) immediately informed the Breakdown Team, Zonal Shift Officer (ZSO) on duty and the No Current Complaint (NCC) team. Due to heavy rain and water logging at that time, manual disconnection of the power supply would have been delayed. Therefore, in the interest of public safety, On-duty ZSO promptly switched off power supply remotely via the Power System Control (PSC) and immediately proceeded to the complainant location. Upon arrival at the site, local residents informed the team that three persons had received electric shock and were already taken to the hospital. The ZSO conducted an inspection of the premises in the presence of Delhi Police personnel and found that current leakage from damaged and defective internal wiring belonging to consumer at the premises. Also, during inspection, it was found that only MCB is installed after meter. No ELCB was found installed in the premises. An Unsafe Wiring Notice (Notice No.701726) was issued and pasted at the site. To prevent any further risk, the power supply of consumer was disconnected from Pole No.519 41/36/1/5. Intimation of the incident was also given to PS Begampur through letter. Name of the deceased – Ms. Anju (Age approx. 20 years), Mr. Sonu/Vivek (Age approx. 16 years).	No	Fatal	The Electrical Inspector has been informed and the enquiry report is awaited. 