Name Of Distribution Licensee: TATA POWER DDL
Period Of Outage: JUN-2020

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
					BADLI							
1	1-Jun-2020	PART OF BIA PHASE I PRAHLADPUR BADLI	3	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	09:00	1-Jun-2020	09:20	20	0.00001	INTERRUPTION DUE TO FAULTS
2	1-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	1090	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	09:12	1-Jun-2020	09:30	18	0.00005	INTERRUPTION DUE TO FAULTS
3	1-Jun-2020	PARTS OF INTER CONNECTOR 3&4 RG-30 TO RG-6	1791	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	14:44	1-Jun-2020	14:55	10	0.00007	INTERRUPTION DUE TO FAULTS
4	1-Jun-2020	PARTS OF C & B BLOCK SEC-16 ROHINI	1886	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	17:21	1-Jun-2020	17:28	7	0.00011	INTERRUPTION DUE TO FAULTS
5	1-Jun-2020	PARTS OF C & B BLOCK SEC-16 ROHINI	823	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	17:21	1-Jun-2020	17:48	27	0.00019	INTERRUPTION DUE TO FAULTS
6	1-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	2250	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	17:33	1-Jun-2020	18:00	27	0.00038	INTERRUPTION DUE TO FAULTS
7	1-Jun-2020	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY	369	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	18:24	1-Jun-2020	18:45	21	0.00007	INTERRUPTION DUE TO FAULTS
8	2-Jun-2020	PARTS OF SURAJ PARK, PART OF BIA PHASE I	999	400 kVA	PLANNED OUTAGE	2-Jun-2020	10:41	2-Jun-2020	14:56	255	0.00064	PLANNED OUTAGE
9	2-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	2250	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	00:03	2-Jun-2020	00:30	27	0.00023	INTERRUPTION DUE TO FAULTS
10	2-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	1090	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:56	2-Jun-2020	07:15	19	0.00012	INTERRUPTION DUE TO FAULTS
11	2-Jun-2020	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY	1218	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	07:43	2-Jun-2020	09:00	77	0.00034	INTERRUPTION DUE TO FAULTS
12	2-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	439	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	09:00	2-Jun-2020	09:20	20	0.00005	INTERRUPTION DUE TO FAULTS
13	2-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	286	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	10:05	2-Jun-2020	10:15	10	0.00001	INTERRUPTION DUE TO FAULTS
14	2-Jun-2020	PART OF TYRE MARKET SAMAYPUR BADLI	3	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	09:29	2-Jun-2020	10:30	61	0.00003	INTERRUPTION DUE TO FAULTS
15	2-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	381	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	11:45	2-Jun-2020	12:40	55	0.00023	INTERRUPTION DUE TO FAULTS
16	2-Jun-2020	PART OF GUPTA COLONY BADLI	18	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	13:36	2-Jun-2020	13:53	17	0.00002	SYSTEM SCHEDULE OUTAGE
17	2-Jun-2020	PART OF AW BLOCK SGT NAGAR BADLI	5	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	13:50	2-Jun-2020	14:45	55	0.00003	INTERRUPTION DUE TO FAULTS
18	3-Jun-2020	PART OF PARK WALA SAMAYPUR BADLI	20	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	13:25	3-Jun-2020	13:55	30	0.00002	SYSTEM SCHEDULE OUTAGE
19	3-Jun-2020	PART OF TYRE MARKET SAMAYPUR BADLI	20	400 kVA	PLANNED OUTAGE	3-Jun-2020	07:11	3-Jun-2020	11:05	234	0.00007	PLANNED OUTAGE
20	3-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	167	OTHER OUTAGE	PLANNED OUTAGE	3-Jun-2020	11:24	3-Jun-2020	15:45	261	0.00015	PLANNED OUTAGE
21	3-Jun-2020	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	1146	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	18:23	3-Jun-2020	18:45	22	0.00028	INTERRUPTION DUE TO FAULTS
22	3-Jun-2020	PARTS OF LIG SEC-28, PART OF ROHINI	330	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	07:20	3-Jun-2020	07:38	18	0.00005	INTERRUPTION DUE TO FAULTS
23	3-Jun-2020	PARTS OF LIG SEC-28, PART OF ROHINI	999	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	07:20	3-Jun-2020	07:50	30	0.00012	INTERRUPTION DUE TO FAULTS
24	3-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	1090	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	08:38	3-Jun-2020	10:10	92	0.00107	INTERRUPTION DUE TO FAULTS
25	3-Jun-2020	PARTS OF SEC-35 ROHINI	673	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	13:11	3-Jun-2020	13:34	22	0.00009	INTERRUPTION DUE TO FAULTS
26	3-Jun-2020	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE	834	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	19:14	3-Jun-2020	19:48	33	0.00068	INTERRUPTION DUE TO FAULTS
27	3-Jun-2020	PART OF TYRE MARKET SAMAYPUR BADLI	3	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	19:14	3-Jun-2020	20:40	85	0.00002	INTERRUPTION DUE TO FAULTS
28	4-Jun-2020	PART OF RAJEEV NAGAR AMBEY GARDEN	8	400 kVA	PLANNED OUTAGE	4-Jun-2020	07:25	4-Jun-2020	11:00	215	0.00006	PLANNED OUTAGE
29	4-Jun-2020	PARTS OF AG, AW BLOCK SGT NAGAR BADLI	137	630 kVA	PLANNED OUTAGE	4-Jun-2020	08:23	4-Jun-2020	15:55	452	0.00013	PLANNED OUTAGE
30	4-Jun-2020	PARTS OF GALI NO-3 SAMAYPUR BADLI	1108	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	15:07	4-Jun-2020	18:50	223	0.00155	FORCE MAJEURE DUE TO SABOTAGE
31	4-Jun-2020	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY, PRAHLADPUR.	1629	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:13	4-Jun-2020	18:50	97	0.00067	INTERRUPTION DUE TO FAULTS
32	4-Jun-2020	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE.	275	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	08:51	4-Jun-2020	09:45	54	0.00023	INTERRUPTION DUE TO FAULTS
33	4-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	1090	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:20	4-Jun-2020	17:40	20	0.00014	INTERRUPTION DUE TO FAULTS
34	4-Jun-2020	PARTS OF SHAHBAD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS	628	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:41	4-Jun-2020	19:53	133	0.00092	FORCE MAJEURE DUE TO SABOTAGE
35	4-Jun-2020	PARTS OF GALI NO 9 SAMAYA PUR BADLI	81	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	05:25	4-Jun-2020	06:03	38	0.00004	INTERRUPTION DUE TO FAULTS
36	4-Jun-2020	PART OF SEC 28 ROHINI	3	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	18:55	4-Jun-2020	20:00	65	0.00002	INTERRUPTION DUE TO FAULTS
37	5-Jun-2020	PART OF SANJAY GANDHI PHASE-II BADLI	1	OTHER OUTAGE	PLANNED OUTAGE	5-Jun-2020	14:36	5-Jun-2020	16:46	130	0.00004	PLANNED OUTAGE
38	5-Jun-2020	PARTS OF SAMAY PUR GALI NO.3 & SAMAY PUR GALI NO.15, GALI NO - 6 SHAKTI BHOG WALI,POST OFFICE WALI GALI, MTNL WALI GALI, MANDIR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR	668	OTHER OUTAGE	PLANNED OUTAGE	5-Jun-2020	07:59	5-Jun-2020	14:50	411	0.0008	PLANNED OUTAGE
39	5-Jun-2020	PARTS OF DDA MARKET SEC-17, 464 LIG FLATS SEC-17,	127	OTHER OUTAGE	PLANNED OUTAGE	5-Jun-2020	11:16	5-Jun-2020	14:18	182	0.00025	PLANNED OUTAGE
40	5-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	435	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	05:33	5-Jun-2020	06:33	59	0.00015	INTERRUPTION DUE TO FAULTS
41	5-Jun-2020	PART OF TYRE MARKET SAMAYPUR BADLI	19	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	14:48	5-Jun-2020	16:18	90	0.00013	SYSTEM SCHEDULE OUTAGE
42	5-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	286	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	17:12	5-Jun-2020	17:48	36	0.00015	INTERRUPTION DUE TO FAULTS
43	5-Jun-2020	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY	369	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	05:45	5-Jun-2020	06:10	25	0.00005	INTERRUPTION DUE TO FAULTS
44	5-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	428	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	04:23	5-Jun-2020	05:10	47	0.00013	INTERRUPTION DUE TO FAULTS
45	5-Jun-2020	PARTS OF SHAHBAD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS	2762	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	05:50	5-Jun-2020	07:08	77	0.00202	INTERRUPTION DUE TO FAULTS
46	5-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	1090	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	06:17	5-Jun-2020	08:16	119	0.00066	INTERRUPTION DUE TO FAULTS
47	5-Jun-2020	PARTS OF LIG SEC-28, PART OF ROHINI	1329	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	07:39	5-Jun-2020	08:20	41	0.00029	INTERRUPTION DUE TO FAULTS
48	5-Jun-2020	PARTS OF PUMP HOUSE NO-2 SEC - 28, IGL SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK	797	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	08:41	5-Jun-2020	09:30	49	0.00034	INTERRUPTION DUE TO FAULTS
49	6-Jun-2020	PARTS OF C & B BLOCK SEC-16 ROHINI	1886	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	19:02	6-Jun-2020	19:21	19	0.00024	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
50	6-Jun-2020	PART OF TYRE MARKET SAMAYPUR BADLI	9	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	07:23	6-Jun-2020	12:30	307	0.00009	PLANNED OUTAGE
51	22-Jun-2020	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK	23	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	07:00	22-Jun-2020	07:50	50	0.00007	INTERRUPTION DUE TO FAULTS
52	6-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	105	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	13:33	6-Jun-2020	15:00	87	0.00017	INTERRUPTION DUE TO FAULTS
53	6-Jun-2020	PART OF RAJEEV NAGAR AMBEY GARDEN	8	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	12:07	6-Jun-2020	15:26	199	0.00011	FORCE MAJEURE DUE TO SABOTAGE
54	6-Jun-2020	PARTS OF C & B BLOCK SEC-16 ROHINI	823	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	19:02	6-Jun-2020	19:34	32	0.00016	INTERRUPTION DUE TO FAULTS
55	6-Jun-2020	PART OF B BLK SEC-16 ROHINI	10	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	19:45	6-Jun-2020	20:50	65	0.00002	INTERRUPTION DUE TO FAULTS
56	6-Jun-2020	PARTS OF BADLI TRIKONA PARK,KHADDE-WALA & BADLI EXTENTION.	1401	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	07:51	6-Jun-2020	08:25	34	0.00026	INTERRUPTION DUE TO FAULTS
57	6-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	2250	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	08:48	6-Jun-2020	09:20	33	0.00025	INTERRUPTION DUE TO FAULTS
58	6-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	205	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	12:26	6-Jun-2020	14:06	99	0.00022	INTERRUPTION DUE TO FAULTS
59	6-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	46	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	13:06	6-Jun-2020	14:06	60	0.00003	INTERRUPTION DUE TO FAULTS
60	6-Jun-2020	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE.	713	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	18:11	6-Jun-2020	19:05	54	0.00013	INTERRUPTION DUE TO FAULTS
61	11-Jun-2020	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY	26	OTHER OUTAGE	PLANNED OUTAGE	11-Jun-2020	11:21	11-Jun-2020	15:45	264	0.00007	PLANNED OUTAGE
62	7-Jun-2020	PART OF SAMAY PUR GALI NO.9 BADLI	8	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	14:49	7-Jun-2020	15:07	18	0.00001	INTERRUPTION DUE TO FAULTS
63	12-Jun-2020	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY	26	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:00	12-Jun-2020	16:00	179	0.00015	FORCE MAJEURE DUE TO SABOTAGE
64	7-Jun-2020	PARTS OF GALI NO 9 SAMAYA PUR BADLI	81	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	23:28	8-Jun-2020	01:17	110	0.00037	INTERRUPTION DUE TO FAULTS
65	8-Jun-2020	PARTS OF GALI NO-6,MASTER MOHALLA, CONTINENTAL ENGG, AMBEY GARDEN RAIL POLE, SANTOSH DHARAM KANTA	171	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	18:23	8-Jun-2020	18:40	17	0.00006	INTERRUPTION DUE TO FAULTS
66	8-Jun-2020	PARTS OF SEC-35 ROHINI	673	OTHER OUTAGE	PLANNED OUTAGE	8-Jun-2020	11:21	8-Jun-2020	15:05	224	0.00044	PLANNED OUTAGE
67	8-Jun-2020	PARTS OF DDA MARKET SEC-17, 464 LIG FLATS SEC-17,	650	OTHER OUTAGE	PLANNED OUTAGE	8-Jun-2020	11:02	8-Jun-2020	13:40	158	0.00031	PLANNED OUTAGE
68	8-Jun-2020	PART OF SEC-26 NALA ROHINI	19	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	23:23	8-Jun-2020	23:45	22	0.00002	INTERRUPTION DUE TO FAULTS
69	8-Jun-2020	PART OF SIRAS PUR VILLAGE. BADLI	15	250 kVA	PLANNED OUTAGE	8-Jun-2020	07:12	8-Jun-2020	13:50	398	0.00011	PLANNED OUTAGE
70	9-Jun-2020	PART OF AMBEY GARDEN BADLI	6	315 kVA	PLANNED OUTAGE	9-Jun-2020	07:17	9-Jun-2020	11:40	263	0.00007	PLANNED OUTAGE
71	16-Jun-2020	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY	28	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	14:55	16-Jun-2020	15:45	50	0.00014	INTERRUPTION DUE TO FAULTS
72	29-Jun-20	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY	26	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:37	29-Jun-20	18:37	60	0.00042	INTERRUPTION DUE TO FAULTS
73	9-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	286	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	21:12	9-Jun-2020	21:28	16	0.00004	INTERRUPTION DUE TO FAULTS
74	9-Jun-2020	PARTS OF GALI NO-3 SAMAYPUR BADLI	1117	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	07:12	9-Jun-2020	08:12	60	0.00030	INTERRUPTION DUE TO FAULTS
75	9-Jun-2020	PART OF BIA PHASE I PRAHLADPUR	3	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	13:38	9-Jun-2020	14:40	62	0.00004	INTERRUPTION DUE TO FAULTS
76	9-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	830	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	16:23	9-Jun-2020	16:40	17	0.00002	INTERRUPTION DUE TO FAULTS
77	10-Jun-2020	PART OF GALI NO-05 SAMAYPUR BADLI	7	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	09:36	10-Jun-2020	12:05	149	0.00021	FORCE MAJEURE DUE TO SABOTAGE
78	10-Jun-2020	PARTS OF SHAHBAD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS	628	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	11:09	10-Jun-2020	11:45	36	0.00032	INTERRUPTION DUE TO FAULTS
79	10-Jun-2020	PARTS OF GALI NO-05 AND SHIV DHARAM KANTA BADLI	139	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	13:32	10-Jun-2020	16:16	164	0.00018	FORCE MAJEURE DUE TO SABOTAGE
80	10-Jun-2020	PARTS OF KALI MATA MANDIR, MASTER PROPERTY.	221	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	11:48	10-Jun-2020	12:55	67	0.00009	INTERRUPTION DUE TO FAULTS
81	10-Jun-2020	PARTS OF RAJA VIHAR AND KHADDA BASTI BADLI	51	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	19:18	10-Jun-2020	20:55	97	0.00005	INTERRUPTION DUE TO FAULTS
82	10-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	286	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	00:53	10-Jun-2020	01:24	31	0.00010	INTERRUPTION DUE TO FAULTS
83	10-Jun-2020	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY	369	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	04:58	10-Jun-2020	05:25	28	0.00008	INTERRUPTION DUE TO FAULTS
84	10-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	1244	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	13:45	10-Jun-2020	14:26	41	0.00029	INTERRUPTION DUE TO FAULTS
85	10-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	2460	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:30	10-Jun-2020	17:16	45	0.00034	INTERRUPTION DUE TO FAULTS
86	10-Jun-2020	PARTS OF POCKET B-4 ESS-1 SECT-35	653	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:04	10-Jun-2020	17:28	24	0.00003	INTERRUPTION DUE TO FAULTS
87	10-Jun-2020	PARTS OF SEC-28 L.I.G NO-2, M.I.G NO-2 SEC-28, A-4 POCKET SECTOR 28 ROHINI, DDA BOOSTER PUMP, BLOCK A, SECTOR-28 ROHINI	1016	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:05	10-Jun-2020	17:30	25	0.00007	INTERRUPTION DUE TO FAULTS
88	10-Jun-2020	PARTS OF RAJA VIHAR AND KHADDA BASTI BADLI	161	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:16	10-Jun-2020	18:05	49	0.00041	INTERRUPTION DUE TO FAULTS
89	10-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	286	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:09	10-Jun-2020	17:25	16	0.00002	INTERRUPTION DUE TO FAULTS
90	10-Jun-2020	PARTS OF SEC-35 ROHINI	1509	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:13	10-Jun-2020	17:32	19	0.00016	INTERRUPTION DUE TO FAULTS
91	10-Jun-2020	PARTS OF BAGGAWALA, GALI NO - 13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA	2017	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:19	10-Jun-2020	18:00	40	0.00028	INTERRUPTION DUE TO FAULTS
92	10-Jun-2020	PARTS OF BAGGAWALA, GALI NO - 13, JAIN WALA (RAILWAY ROAD), DELHI DHARAM KANTA	563	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:19	10-Jun-2020	18:00	41	0.00013	INTERRUPTION DUE TO FAULTS
93	10-Jun-2020	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE	267	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:17	10-Jun-2020	18:00	43	0.00007	INTERRUPTION DUE TO FAULTS
94	10-Jun-2020	PARTS OF ESS NO -1 SAMAYA PUR BADLI	490	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:50	10-Jun-2020	18:15	25	0.00004	INTERRUPTION DUE TO FAULTS
95	10-Jun-2020	PARTS OF GALI NO-05 AND SHIV DHARAM KANTA BADLI	182	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:22	10-Jun-2020	18:35	72	0.00010	INTERRUPTION DUE TO FAULTS
96	10-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	7177	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:07	10-Jun-2020	18:30	23	0.00059	INTERRUPTION DUE TO FAULTS
97	10-Jun-2020	PARTS OF GIVAN PARK SIRASPUR, PART OF BAGHAT SINGH PARK, PART OF SIRASPUR VILLAGE.	1867	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:36	10-Jun-2020	18:35	59	0.00025	INTERRUPTION DUE TO FAULTS
98	10-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	435	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:45	10-Jun-2020	19:02	17	0.00004	INTERRUPTION DUE TO FAULTS
99	10-Jun-2020	PARTS OF ESS NO -1 SAMAYA PUR BADLI	295	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	19:24	10-Jun-2020	21:34	131	0.00029	FORCE MAJEURE DUE TO RAIN/STORM
100	10-Jun-2020	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	1146	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	11:12	10-Jun-2020	13:45	153	0.00051	PLANNED OUTAGE
101	10-Jun-2020	PARTS OF RAM BABU SPD SAMAYA PUR BADLI	182	315 kVA	PLANNED OUTAGE	10-Jun-2020	07:16	10-Jun-2020	12:58	342	0.00019	PLANNED OUTAGE
102	11-Jun-2020	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE	267	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	12:01	11-Jun-2020	12:50	49	0.00010	INTERRUPTION DUE TO FAULTS
103	11-Jun-2020	PARTS OF KALI MATA MANDIR, MASTER PROPERTY.	221	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	12:42	11-Jun-2020	13:20	38	0.00005	INTERRUPTION DUE TO FAULTS
104	11-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	459	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	16:40	11-Jun-2020	17:40	59	0.00017	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
105	11-Jun-2020	PART OF KHADDA BASTI SAMAYPUR BADLI	16	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	20:52	11-Jun-2020	21:50	58	0.00008	INTERRUPTION DUE TO FAULTS
106	11-Jun-2020	PARTS OF GALI-4 SAMAYPUR BADLI	101	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	05:34	11-Jun-2020	08:12	158	0.00022	FORCE MAJEURE DUE TO SABOTAGE
107	11-Jun-2020	PARTS OF GALI-4 SAMAYPUR BADLI	47	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	07:36	11-Jun-2020	08:12	36	0.00002	INTERRUPTION DUE TO FAULTS
108	11-Jun-2020	PARTS OF SEC-28 L.I.G NO-2, M.I.G NO-2 SEC-28, A-4 POCKET SECTOR 28 ROHINI, DDA BOOSTER PUMP, BLOCK A, SECTOR-28 ROHINI	1016	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	05:19	11-Jun-2020	05:35	16	0.00005	INTERRUPTION DUE TO FAULTS
109	11-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	2250	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	07:48	11-Jun-2020	08:35	47	0.00033	INTERRUPTION DUE TO FAULTS
110	11-Jun-2020	PARTS OF SEC-35 ROHINI	822	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	17:18	11-Jun-2020	18:30	72	0.00032	INTERRUPTION DUE TO FAULTS
111	11-Jun-2020	PARTS OF SEC-35 ROHINI	673	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	17:18	11-Jun-2020	18:35	77	0.00030	INTERRUPTION DUE TO FAULTS
112	11-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	1045	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	22:57	11-Jun-2020	23:30	33	0.00023	INTERRUPTION DUE TO FAULTS
113	11-Jun-2020	PARTS OF INTER CONNECTOR 3&4 RG-30 TO RG-6	133	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	22:53	11-Jun-2020	23:25	32	0.00014	INTERRUPTION DUE TO FAULTS
114	11-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	1045	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	23:40	11-Jun-2020	23:50	11	0.00007	INTERRUPTION DUE TO FAULTS
115	11-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	1045	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	23:50	12-Jun-2020	00:28	38	0.00026	INTERRUPTION DUE TO FAULTS
116	11-Jun-2020	PARTS OF SIRAS PUR GALI NO-7 BADLI	202	400 kVA	PLANNED OUTAGE	11-Jun-2020	07:09	11-Jun-2020	11:15	246	0.00027	PLANNED OUTAGE
117	11-Jun-2020	PART OF SEC-35 ROHINI	14	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	17:18	11-Jun-2020	18:35	77	0.00002	INTERRUPTION DUE TO FAULTS
118	12-Jun-2020	PARTS OF C & B BLOCK SEC-16 ROHINI	823	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	11:08	12-Jun-2020	14:05	177	0.00039	PLANNED OUTAGE
119	2-Jun-2020	PARTS OF GIVAN PARK SIRASPUR, PART OF BAGHAT SINGH PARK	26	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	11:12	2-Jun-2020	14:32	200	0.00028	FORCE MAJEURE DUE TO SABOTAGE
120	12-Jun-2020	PARTS OF DDA MARKET SEC-17, 464 LIG FLATS SEC-17,	127	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	20:07	12-Jun-2020	20:29	22	0.00002	INTERRUPTION DUE TO FAULTS
121	12-Jun-2020	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	417	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	19:14	12-Jun-2020	21:15	120	0.00050	FORCE MAJEURE DUE TO SABOTAGE
122	12-Jun-2020	PARTS OF LIG SEC-28, PART OF ROHINI	44	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	16:35	12-Jun-2020	17:10	34	0.00014	INTERRUPTION DUE TO FAULTS
123	12-Jun-2020	PARTS OF SEC-28 L.I.G NO-2, M.I.G NO-2 SEC-28, A-4 POCKET SECTOR 28 ROHINI, DDA BOOSTER PUMP, BLOCK A, SECTOR-28 ROHINI	138	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	19:14	12-Jun-2020	20:00	46	0.00005	INTERRUPTION DUE TO FAULTS
124	12-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	1244	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	01:40	12-Jun-2020	02:05	25	0.00018	INTERRUPTION DUE TO FAULTS
125	12-Jun-2020	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY	3519	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	01:53	12-Jun-2020	02:15	22	0.00040	INTERRUPTION DUE TO FAULTS
126	12-Jun-2020	PARTS OF SEC-18 ROHINI	515	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	06:21	12-Jun-2020	07:05	44	0.00030	INTERRUPTION DUE TO FAULTS
127	12-Jun-2020	PARTS OF RAM BABU BHAGAT SINGH PARK, INDRAJ SPD, LATT WALA, AMBEY GERDEN, SANTOSH DHARAM KANTA,	177	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	08:01	12-Jun-2020	08:26	24	0.00010	INTERRUPTION DUE TO FAULTS
128	12-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	801	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:19	12-Jun-2020	14:46	88	0.00039	INTERRUPTION DUE TO FAULTS
129	12-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	46	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	15:25	12-Jun-2020	18:40	195	0.00011	FORCE MAJEURE DUE TO SABOTAGE
130	12-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	205	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	17:38	12-Jun-2020	18:40	62	0.00007	INTERRUPTION DUE TO FAULTS
131	12-Jun-2020	PARTS OF SIRAS PUR GALI NO-7 BADLI	379	400 kVA	PLANNED OUTAGE	12-Jun-2020	07:36	12-Jun-2020	10:00	144	0.00016	PLANNED OUTAGE
132	12-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	106	630 kVA	PLANNED OUTAGE	12-Jun-2020	09:45	12-Jun-2020	15:15	330	0.00009	PLANNED OUTAGE
133	12-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	298	630 kVA	PLANNED OUTAGE	12-Jun-2020	08:31	12-Jun-2020	13:28	297	0.00025	PLANNED OUTAGE
134	13-Jun-2020	PART OF SAMAY PUR GALI NO.9 BADLI	5	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	18:19	14-Jun-2020	08:40	861	0.00048	FORCE MAJEURE DUE TO SABOTAGE
135	13-Jun-2020	PART OF AMAR JYOTI COLONY BADLI	7	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	02:20	13-Jun-2020	03:22	62	0.00002	INTERRUPTION DUE TO FAULTS
136	13-Jun-2020	PARTS OF SHAHBAD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS	32	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	03:20	13-Jun-2020	06:00	160	0.00022	FORCE MAJEURE DUE TO SABOTAGE
137	13-Jun-2020	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	1313	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	04:33	13-Jun-2020	05:44	71	0.00024	INTERRUPTION DUE TO FAULTS
138	13-Jun-2020	PARTS OF SHAHBAD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS	628	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	01:22	13-Jun-2020	02:08	46	0.00019	INTERRUPTION DUE TO FAULTS
139	13-Jun-2020	PARTS OF SHAHBAD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS	621	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	03:06	13-Jun-2020	03:22	16	0.00011	INTERRUPTION DUE TO FAULTS
140	13-Jun-2020	PARTS OF B BLOCK WAZIR PUR INDUSTRIAL AREA	135	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	12:21	13-Jun-2020	12:35	14	0.00009	INTERRUPTION DUE TO FAULTS
141	13-Jun-2020	PARTS OF GALI NO-05 AND SHIV DHARAM KANTA BADLI	182	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:50	13-Jun-2020	15:20	30	0.00017	INTERRUPTION DUE TO FAULTS
142	13-Jun-2020	PARTS OF RAM BABU BHAGAT SINGH PARK, INDRAJ SPD, LATT WALA, AMBEY GERDEN, SANTOSH DHARAM KANTA,	168	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:55	13-Jun-2020	15:30	36	0.00005	INTERRUPTION DUE TO FAULTS
143	13-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	1090	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:22	13-Jun-2020	15:55	33	0.00019	INTERRUPTION DUE TO FAULTS
144	13-Jun-2020	PARTS OF BIA PHASE III, RAJA VIHAR, PART OF BIA PHASE II	144	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:16	13-Jun-2020	15:55	39	0.00005	INTERRUPTION DUE TO FAULTS
145	13-Jun-2020	PARTS OF LIG SEC-28, PART OF ROHINI	31	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:37	13-Jun-2020	17:30	53	0.00004	INTERRUPTION DUE TO FAULTS
146	13-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	1090	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:28	13-Jun-2020	17:50	22	0.00014	INTERRUPTION DUE TO FAULTS
147	13-Jun-2020	PART OF RAJEEV NAGAR AMBEY GARDEN	8	250 kVA	PLANNED OUTAGE	13-Jun-2020	07:10	13-Jun-2020	11:05	235	0.00007	PLANNED OUTAGE
148	13-Jun-2020	PARTS OF BIA PHASE I AND PHASE 2 BADLI	25	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	10:38	13-Jun-2020	14:30	232	0.00006	PLANNED OUTAGE
149	13-Jun-2020	PART OF SEC 28 ROHINI	2	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	11:30	13-Jun-2020	12:40	70	0.00004	INTERRUPTION DUE TO FAULTS
150	14-Jun-2020	PART OF AMAR JYOTI COLONY BADLI	11	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	16:56	14-Jun-2020	17:30	34	0.00002	INTERRUPTION DUE TO FAULTS
151	14-Jun-2020	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY, PRAHLADPUR.	112	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	10:40	14-Jun-2020	11:40	60	0.00020	INTERRUPTION DUE TO FAULTS
152	14-Jun-2020	PARTS OF BIA PHASE I AND PHASE 2 BADLI	27	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	15:07	14-Jun-2020	20:10	303	0.00084	FORCE MAJEURE DUE TO SABOTAGE
153	14-Jun-2020	PARTS OF BIA PHASE I AND PHASE 2 BADLI	86	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	16:13	14-Jun-2020	16:24	10	0.00011	INTERRUPTION DUE TO FAULTS
154	15-Jun-2020	PARTS OF RAJA VIHAR AND KHADDA BASTI BADLI	55	160 kVA	PLANNED OUTAGE	15-Jun-2020	10:25	15-Jun-2020	13:15	170	0.00005	PLANNED OUTAGE
155	15-Jun-2020	PARTS OF BADLI JAI, JAIL COLONY, BADLI POLICE QTRS. SEWAGE PUMP SECTOR - 19,	946	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	11:43	15-Jun-2020	13:55	132	0.00033	PLANNED OUTAGE
156	15-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	1091	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	10:45	15-Jun-2020	15:52	307	0.00154	PLANNED OUTAGE
157	15-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	517	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	00:32	15-Jun-2020	01:00	28	0.00004	INTERRUPTION DUE TO FAULTS
158	15-Jun-2020	PARTS OF BIA PHASE I AND PHASE 2 BADLI	27	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	08:09	15-Jun-2020	08:43	34	0.00003	INTERRUPTION DUE TO FAULTS
159	15-Jun-2020	PARTS OF RAJA VIHAR AND KHADDA BASTI BADLI	426	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	14:38	15-Jun-2020	15:13	35	0.00044	INTERRUPTION DUE TO FAULTS
160	15-Jun-2020	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	685	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	17:50	15-Jun-2020	19:00	70	0.00049	INTERRUPTION DUE TO FAULTS
161	15-Jun-2020	PART OF KHADDA BASTI BADLI	16	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	00:14	15-Jun-2020	01:00	46	0.00003	INTERRUPTION DUE TO FAULTS
162	15-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	5819	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	11:26	15-Jun-2020	12:10	44	0.00061	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
163	15-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	1359	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	11:26	15-Jun-2020	14:15	169	0.00117	FORCE MAJEURE DUE TO SABOTAGE
164	15-Jun-2020	PARTS OF BADLI INDUSTRIAL AREA	108	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	13:39	15-Jun-2020	15:03	84	0.00232	INTERRUPTION DUE TO FAULTS
165	15-Jun-2020	PARTS OF BADLI INDUSTRIAL AREA	48	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	13:39	15-Jun-2020	16:20	161	0.00054	FORCE MAJEURE DUE TO SABOTAGE
166	15-Jun-2020	PARTS OF BADLI INDS. AREA PAHSE-2 & 5	104	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	14:23	15-Jun-2020	15:17	53	0.00059	INTERRUPTION DUE TO FAULTS
167	15-Jun-2020	PARTS OF SHAHBAD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS	2762	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	14:23	15-Jun-2020	15:33	69	0.00087	INTERRUPTION DUE TO FAULTS
168	15-Jun-2020	PARTS OF GALI NO-3 SAMAYPUR BADLI	1117	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	22:45	16-Jun-2020	00:05	80	0.00115	INTERRUPTION DUE TO FAULTS
169	15-Jun-2020	PART OF GUPTA COLONY BADLI	16	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	11:34	15-Jun-2020	11:50	16	0.00002	INTERRUPTION DUE TO FAULTS
170	15-Jun-2020	PARTS OF GALI NO 9 SAMAYA PUR BADLI	142	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	08:26	15-Jun-2020	09:05	39	0.00013	INTERRUPTION DUE TO FAULTS
171	16-Jun-2020	PART OF SAMAY PUR GALI NO.9 BADLI	5	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	07:07	16-Jun-2020	10:45	218	0.00012	FORCE MAJEURE DUE TO SABOTAGE
172	16-Jun-2020	PARTS OF C & B BLOCK SEC-16 ROHINI	441	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	21:14	16-Jun-2020	21:35	21	0.00005	INTERRUPTION DUE TO FAULTS
173	16-Jun-2020	PARTS OF RAM BABU BHAGAT SINGH PARK, INDRAJ SPD, LATT WALA, AMBEY GERDEN, SANTOSH DHARAM KANTA,	521	OTHER OUTAGE	PLANNED OUTAGE	16-Jun-2020	11:28	16-Jun-2020	12:47	78	0.00011	PLANNED OUTAGE
174	16-Jun-2020	PART OF PARK WALA SAMAYPUR BADLI	18	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	21:44	16-Jun-2020	22:12	28	0.00002	INTERRUPTION DUE TO FAULTS
175	16-Jun-2020	PARTS OF BADLI AND PARK WALA SAMAYA PUR BADLI	597	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	21:54	16-Jun-2020	22:12	18	0.00005	INTERRUPTION DUE TO FAULTS
176	16-Jun-2020	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE.	275	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	01:03	16-Jun-2020	01:16	13	0.00002	SYSTEM SCHEDULE OUTAGE
177	16-Jun-2020	PART OF PARK WALA SAMAYPUR BADLI	18	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	13:52	16-Jun-2020	15:07	75	0.00010	INTERRUPTION DUE TO FAULTS
178	29-Jun-20	PART OF GALI NO 9 SAMAYPUR BADLI	7	250 kVA	PLANNED OUTAGE	29-Jun-20	07:36	29-Jun-20	11:22	226	0.00006	PLANNED OUTAGE
179	29-Jun-20	PART OF GALI NO 9 SAMAYPUR BADLI	4	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:34	29-Jun-20	20:27	113	0.00003	SYSTEM SCHEDULE OUTAGE
180	16-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	439	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	02:07	16-Jun-2020	02:35	28	0.00016	INTERRUPTION DUE TO FAULTS
181	16-Jun-2020	PARTS OF SHAHBAD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS	628	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	14:09	16-Jun-2020	16:20	131	0.00091	FORCE MAJEURE DUE TO SABOTAGE
182	16-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	1048	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	03:27	16-Jun-2020	04:05	38	0.00013	INTERRUPTION DUE TO FAULTS
183	16-Jun-2020	PARTS OF BADLI INDS. AREA PAHSE-2 & 5	82	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	06:46	16-Jun-2020	07:10	24	0.00009	INTERRUPTION DUE TO FAULTS
184	16-Jun-2020	PARTS OF BADLI INDS. AREA PAHSE-2 & 5	22	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	06:46	16-Jun-2020	07:20	34	0.00005	INTERRUPTION DUE TO FAULTS
185	4-Jun-2020	PART OF GALI NO 9 SAMAYPUR BADLI	2	100 kVA	UNPLANNED OUTAGE	4-Jun-2020	12:32	4-Jun-2020	12:57	25	0.00001	SYSTEM SCHEDULE OUTAGE
186	16-Jun-2020	PARTS OF BADLI AND PARK WALA SAMAYA PUR BADLI	597	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	14:49	16-Jun-2020	15:01	12	0.00008	INTERRUPTION DUE TO FAULTS
187	13-Jun-2020	PART OF GALI NO 9 SAMAYPUR BADLI	3	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:46	13-Jun-2020	18:20	34	0.00003	INTERRUPTION DUE TO FAULTS
188	16-Jun-2020	PART OF TEACHERS COLONY BADLI	16	OTHER OUTAGE	PLANNED OUTAGE	16-Jun-2020	12:56	16-Jun-2020	13:12	16	0.000005	PLANNED OUTAGE
189	20-Jun-2020	PART OF GALI NO 9 SAMAYPUR BADLI	7	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	09:51	20-Jun-2020	11:44	112	0.00006	INTERRUPTION DUE TO FAULTS
190	17-Jun-2020	PART OF SANJAY GANDHI PHASE-II BADLI	2	OTHER OUTAGE	PLANNED OUTAGE	17-Jun-2020	14:30	17-Jun-2020	15:28	58	0.00002	PLANNED OUTAGE
191	17-Jun-2020	PART OF ARYA APARTMENT BADLI	13	250 kVA	PLANNED OUTAGE	17-Jun-2020	11:53	17-Jun-2020	15:20	207	0.00006	PLANNED OUTAGE
192	17-Jun-2020	PARTS OF GALI NO 9 SAMAYA PUR BADLI	81	OTHER OUTAGE	PLANNED OUTAGE	17-Jun-2020	10:15	17-Jun-2020	15:33	318	0.00009	PLANNED OUTAGE
193	9-Jun-2020	PART OF GALI NO-23 LIBAS PUR BADLI	3	63 kVA	PLANNED OUTAGE	9-Jun-2020	10:35	9-Jun-2020	13:05	150	0.00004	PLANNED OUTAGE
194	17-Jun-2020	PARTS OF LIG SEC-28, PART OF ROHINI	331	OTHER OUTAGE	PLANNED OUTAGE	17-Jun-2020	08:31	17-Jun-2020	13:40	309	0.00026	PLANNED OUTAGE
195	17-Jun-2020	PARTS OF GALI NO-05 AND SHIV DHARAM KANTA BADLI	182	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	06:49	17-Jun-2020	08:25	96	0.00016	INTERRUPTION DUE TO FAULTS
196	17-Jun-2020	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY	361	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	11:55	17-Jun-2020	12:30	35	0.00015	INTERRUPTION DUE TO FAULTS
197	17-Jun-2020	PARTS OF 448 SFS NO-1 BADLI RESIDENTIAL	163	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	18:56	17-Jun-2020	19:02	6	0.00003	INTERRUPTION DUE TO FAULTS
198	17-Jun-2020	PART OF 448 SFS NO-1 BADLI RES.	4	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	18:56	17-Jun-2020	20:20	84	0.00002	INTERRUPTION DUE TO FAULTS
199	17-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	1244	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	00:45	17-Jun-2020	01:28	43	0.00031	INTERRUPTION DUE TO FAULTS
200	17-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	849	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	02:19	17-Jun-2020	02:35	16	0.00008	INTERRUPTION DUE TO FAULTS
201	2-Jun-2020	PART OF GALI NO-3 SAMAYPUR BADLI	7	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	07:26	2-Jun-2020	07:48	22	0.00001	INTERRUPTION DUE TO FAULTS
202	5-Jun-2020	PART OF GALI-4 SAMAYPUR SAMAYPUR BADLI	12	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	18:41	5-Jun-2020	19:09	28	0.00001	INTERRUPTION DUE TO FAULTS
203	17-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	849	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	20:58	17-Jun-2020	21:25	27	0.00014	INTERRUPTION DUE TO FAULTS
204	17-Jun-2020	PARTS OF SURAJ PARK, PART OF BIA PHASE I	185	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	22:02	17-Jun-2020	22:14	11	0.00004	INTERRUPTION DUE TO FAULTS
205	17-Jun-2020	PARTS OF SURAJ PARK, PART OF BIA PHASE I	3002	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	22:02	17-Jun-2020	22:57	55	0.00154	INTERRUPTION DUE TO FAULTS
206	17-Jun-2020	PARTS OF INTER CONNECTOR 1&2 RG-30 TO RG-6	576	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	22:36	17-Jun-2020	22:56	20	0.00007	INTERRUPTION DUE TO FAULTS
207	17-Jun-2020	PARTS OF INTER CONNECTOR 1&2 RG-30 TO RG-6	576	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	22:50	18-Jun-2020	00:06	76	0.00025	INTERRUPTION DUE TO FAULTS
208	1-Jun-2020	PART OF GALI-4 SAMAYPUR SAMAYPUR BADLI	4	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	15:30	1-Jun-2020	16:00	30	0.00002	INTERRUPTION DUE TO FAULTS
209	18-Jun-2020	PART OF AW BLOCK SGT NAGAR BADLI	5	OTHER OUTAGE	PLANNED OUTAGE	18-Jun-2020	10:38	18-Jun-2020	13:10	152	0.00004	PLANNED OUTAGE
210	23-Jun-2020	PART OF GALI-4 SAMAYPUR SAMAYPUR BADLI	4	250 kVA	PLANNED OUTAGE	23-Jun-2020	10:46	23-Jun-2020	15:13	267	0.00007	PLANNED OUTAGE
211	23-Jun-2020	PART OF GALI-4 SAMAYPUR SAMAYPUR BADLI	8	400 kVA	PLANNED OUTAGE	23-Jun-2020	10:15	23-Jun-2020	12:50	155	0.00004	PLANNED OUTAGE
212	18-Jun-2020	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	106	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	23:17	18-Jun-2020	23:40	23	0.00003	INTERRUPTION DUE TO FAULTS
213	18-Jun-2020	PART OF KHADDA BASTI BADLI	7	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	18:36	18-Jun-2020	19:04	28	0.00001	INTERRUPTION DUE TO FAULTS
214	18-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	508	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	02:52	18-Jun-2020	03:47	55	0.00018	INTERRUPTION DUE TO FAULTS
215	22-Jun-2020	PART OF GALI-4 SAMAYPUR SAMAYPUR BADLI	11	315 kVA	PLANNED OUTAGE	22-Jun-2020	13:59	22-Jun-2020	15:38	99	0.00003	PLANNED OUTAGE
216	18-Jun-2020	PARTS OF KALI MATA MANDIR, MASTER PROPERTY.	21	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	14:02	18-Jun-2020	14:45	44	0.00002	INTERRUPTION DUE TO FAULTS
217	18-Jun-2020	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	331	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	16:43	18-Jun-2020	17:38	55	0.00017	INTERRUPTION DUE TO FAULTS
218	18-Jun-2020	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	3853	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	16:43	18-Jun-2020	17:44	60	0.00121	INTERRUPTION DUE TO FAULTS
219	18-Jun-2020	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	685	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	16:43	18-Jun-2020	18:40	116	0.00074	INTERRUPTION DUE TO FAULTS
220	18-Jun-2020	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY, PRAHLADPUR.	54	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	19:41	18-Jun-2020	20:00	19	0.00003	INTERRUPTION DUE TO FAULTS
221	18-Jun-2020	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY, PRAHLADPUR.	1631	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	19:41	18-Jun-2020	20:20	39	0.00019	INTERRUPTION DUE TO FAULTS
222	18-Jun-2020	PARTS OF SEC-35 ROHINI	673	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	22:13	18-Jun-2020	22:40	27	0.00011	INTERRUPTION DUE TO FAULTS
223	18-Jun-2020	PART OF D-2 POCKET SEC-29 ROHINI	10	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	13:48	18-Jun-2020	14:32	44	0.00001	SYSTEM SCHEDULE OUTAGE
224	19-Jun-2020	PART OF KAILASH VIHAR BADLI	11	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	12:01	19-Jun-2020	12:42	41	0.00001	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
225	19-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	801	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	07:52	19-Jun-2020	08:18	26	0.00012	INTERRUPTION DUE TO FAULTS
226	19-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	155	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	11:22	19-Jun-2020	15:30	248	0.00034	FORCE MAJEURE DUE TO SABOTAGE
227	19-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	336	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	17:50	19-Jun-2020	18:20	30	0.00007	INTERRUPTION DUE TO FAULTS
228	19-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	2250	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	18:13	19-Jun-2020	18:33	20	0.00017	INTERRUPTION DUE TO FAULTS
229	19-Jun-2020	PARTS OF SEC-35 ROHINI	824	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	05:59	19-Jun-2020	06:35	36	0.00017	INTERRUPTION DUE TO FAULTS
230	19-Jun-2020	PARTS OF SEC-35 ROHINI	687	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	05:59	19-Jun-2020	06:37	38	0.00014	INTERRUPTION DUE TO FAULTS
231	19-Jun-2020	PARTS OF BADLI INDUSTRIAL AREA	25	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	07:44	19-Jun-2020	08:40	56	0.00005	INTERRUPTION DUE TO FAULTS
232	20-Jun-2020	PARTS OF 448 SFS NO-1 BADLI RESIDENTIAL	168	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	10:17	20-Jun-2020	12:30	133	0.00019	FORCE MAJEURE DUE TO SABOTAGE
233	20-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	227	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	15:57	20-Jun-2020	16:40	43	0.00007	SYSTEM SCHEDULE OUTAGE
234	20-Jun-2020	PARTS OF GALI NO - 1,2,3,4 LIBAS PUR, SIRASPUR PARTLYGALI NO - 1,2,3,4,5,6 JEEVAN PUR, AMBE GARDEN, CHANDAN PUR, SHIV MANDIR LIBAS PUR, 66 FOOTA ROAD 66 FOOTA ROAD	38	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	20:32	20-Jun-2020	20:52	20	0.00002	INTERRUPTION DUE TO FAULTS
235	20-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	529	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	11:02	20-Jun-2020	13:30	148	0.00021	FORCE MAJEURE DUE TO SABOTAGE
236	20-Jun-2020	PART OF BIA PHASE I PRAHLADPUR	14	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	15:39	20-Jun-2020	16:35	56	0.00003	INTERRUPTION DUE TO FAULTS
237	20-Jun-2020	PARTS OF GALI NO-3 SAMAYPUR BADLI	884	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	01:01	20-Jun-2020	01:30	29	0.00029	INTERRUPTION DUE TO FAULTS
238	20-Jun-2020	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	378	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	02:36	20-Jun-2020	04:10	93	0.00065	INTERRUPTION DUE TO FAULTS
239	20-Jun-2020	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE.	713	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	01:56	20-Jun-2020	02:32	36	0.00025	INTERRUPTION DUE TO FAULTS
240	20-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	1091	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:19	20-Jun-2020	05:20	61	0.00087	INTERRUPTION DUE TO FAULTS
241	20-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	801	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:38	20-Jun-2020	05:40	62	0.00090	INTERRUPTION DUE TO FAULTS
242	20-Jun-2020	PARTS OF GALI NO-6,MASTER MOHALLA, CONTINENTAL ENGG, AMBEY GARDEN RAIL POLE, SANTOSH DHARAM KANTA	166	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	07:21	20-Jun-2020	08:53	91	0.00013	INTERRUPTION DUE TO FAULTS
243	20-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	801	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	07:31	20-Jun-2020	08:35	65	0.00020	INTERRUPTION DUE TO FAULTS
244	20-Jun-2020	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE.	275	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:11	20-Jun-2020	11:09	178	0.00025	FORCE MAJEURE DUE TO RAIN/STORM
245	20-Jun-2020	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY, PRAHLADPUR.	988	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:16	20-Jun-2020	08:46	30	0.00014	INTERRUPTION DUE TO FAULTS
246	20-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	2250	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:28	20-Jun-2020	09:15	47	0.00028	INTERRUPTION DUE TO FAULTS
247	20-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	3201	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	14:35	20-Jun-2020	15:15	40	0.00122	INTERRUPTION DUE TO FAULTS
248	20-Jun-2020	PARTS OF KALI MATA MANDIR, MASTER PROPERTY.	221	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	18:08	20-Jun-2020	18:35	28	0.00039	INTERRUPTION DUE TO FAULTS
249	20-Jun-2020	PARTS OF BADLI AND PARK WALA SAMAYA PUR BADLI	615	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	23:20	20-Jun-2020	23:42	22	0.00009	INTERRUPTION DUE TO FAULTS
250	20-Jun-2020	PARTS OF BADLI INDUSTRIAL AREA	25	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	22:39	20-Jun-2020	23:00	21	0.00003	INTERRUPTION DUE TO FAULTS
251	21-Jun-2020	PART OF SEC 28 ROHINI	11	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	20:55	21-Jun-2020	21:30	35	0.00005	INTERRUPTION DUE TO FAULTS
252	21-Jun-2020	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE.	713	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	00:01	21-Jun-2020	00:27	26	0.00007	INTERRUPTION DUE TO FAULTS
253	21-Jun-2020	PARTS OF PUMP HOUSE NO-2 SEC - 28, IGL SEC-28, D-2 POCKET SEC-29 ROHINI, KANKAD KHERA, DDA COMMAND TANK	797	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	12:33	21-Jun-2020	13:00	28	0.00008	INTERRUPTION DUE TO FAULTS
254	22-Jun-2020	PART OF BADLI INDUSTRIAL AREA	3	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	10:56	22-Jun-2020	11:35	39	0.00003	INTERRUPTION DUE TO FAULTS
255	22-Jun-2020	PARTS OF BADLI TRIKONA PARK,KHADDE-WALA & BADLI EXTENTION.	448	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	12:25	22-Jun-2020	14:30	125	0.00042	FORCE MAJEURE DUE TO SABOTAGE
256	22-Jun-2020	PARTS OF GALI NO 14 HVDS, GALI NO - 3,12,15 LIBASPUR, GALI NO - 5, 6 MASTER MOHALLA, SIRAS PUR ROAD, PART OF JJ CLUSTER SAMAY PUR GALI NO-9	455	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	13:08	22-Jun-2020	13:50	42	0.00011	INTERRUPTION DUE TO FAULTS
257	22-Jun-2020	PARTS OF F-BLOCK, PART OF G-BLOCK, SEC-16, PART OF E BLOCK, A BLOCK	137	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	14:32	22-Jun-2020	17:15	163	0.00027	FORCE MAJEURE DUE TO SABOTAGE
258	22-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	439	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:51	22-Jun-2020	06:30	39	0.00027	INTERRUPTION DUE TO FAULTS
259	22-Jun-2020	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	1604	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	06:51	22-Jun-2020	08:15	84	0.00081	INTERRUPTION DUE TO FAULTS
260	22-Jun-2020	PARTS OF POCKET B-4 ESS-1 SECT-35	54	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	07:00	22-Jun-2020	07:20	20	0.00006	INTERRUPTION DUE TO FAULTS
261	22-Jun-2020	PARTS OF GALI NO-05 AND SHIV DHARAM KANTA BADLI	182	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	06:47	22-Jun-2020	08:00	73	0.00051	INTERRUPTION DUE TO FAULTS
262	28-Jun-2020	PARTS OF SEC-28 L.I.G NO-2, M.I.G NO-2 SEC-28, A-4 POCKET SECTOR 28 ROHINI	22	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	23:19	29-Jun-2020	00:39	80	0.00009	SYSTEM SCHEDULE OUTAGE
263	22-Jun-2020	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	685	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	08:03	22-Jun-2020	08:25	22	0.00015	INTERRUPTION DUE TO FAULTS
264	22-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	286	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	14:18	22-Jun-2020	16:11	113	0.00019	INTERRUPTION DUE TO FAULTS
265	22-Jun-2020	PARTS OF RAJA VIHAR AND KHADDA BASTI BADLI	548	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	17:11	22-Jun-2020	18:30	79	0.00026	INTERRUPTION DUE TO FAULTS
266	22-Jun-2020	PARTS OF 8-A,8-B, SEC-15,ARYA APARTMENT ,C-BLOCK SEC-15 & SOCIATY SEC-15	136	OTHER OUTAGE	PLANNED OUTAGE	22-Jun-2020	07:13	22-Jun-2020	10:07	174	0.0001	PLANNED OUTAGE
267	22-Jun-2020	PART OF GALI NO-05 SAMAYPUR BADLI	7	315 kVA	PLANNED OUTAGE	22-Jun-2020	10:53	22-Jun-2020	12:56	123	0.00003	PLANNED OUTAGE
268	23-Jun-2020	PART OF BIA PHASE III PRAHLADPUR	5	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	09:44	23-Jun-2020	10:09	25	0.00003	INTERRUPTION DUE TO FAULTS
269	23-Jun-2020	PARTS OF KRISHAN COLONY BADLI	1146	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	11:02	23-Jun-2020	12:10	68	0.00047	INTERRUPTION DUE TO FAULTS
270	7-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY	24	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	23:13	7-Jun-2020	23:31	18	0.00001	INTERRUPTION DUE TO FAULTS
271	23-Jun-2020	PARTS OF INTER CONNECTOR 3&4 RG-30 TO RG-6	3098	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	05:47	23-Jun-2020	06:38	51	0.00070	INTERRUPTION DUE TO FAULTS
272	23-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	439	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	06:46	23-Jun-2020	07:15	29	0.00020	INTERRUPTION DUE TO FAULTS
273	23-Jun-2020	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE	419	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	08:14	23-Jun-2020	08:52	38	0.00009	INTERRUPTION DUE TO FAULTS
274	23-Jun-2020	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY	369	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	10:55	23-Jun-2020	11:50	55	0.00011	INTERRUPTION DUE TO FAULTS
275	23-Jun-2020	PARTS OF KRISHAN COLONY BADLI	1146	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	12:40	23-Jun-2020	13:00	20	0.00013	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
276	23-Jun-2020	PARTS OF GALI NO-6,MASTER MOHALLA, CONTINENTAL ENGG, AMBEY GARDEN RAIL POLE, SANTOSH DHARAM KANTA	171	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	13:15	23-Jun-2020	14:10	55	0.00009	INTERRUPTION DUE TO FAULTS
277	23-Jun-2020	PARTS OF SEC-18 ROHINI	352	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	13:45	23-Jun-2020	13:50	5	0.00001	INTERRUPTION DUE TO FAULTS
278	23-Jun-2020	PARTS OF SEC-18 ROHINI	163	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	13:45	23-Jun-2020	14:10	25	0.00003	INTERRUPTION DUE TO FAULTS
279	23-Jun-2020	PARTS OF SURAJ PARK, PART OF BIA PHASE I	1214	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	16:31	23-Jun-2020	18:00	89	0.00054	INTERRUPTION DUE TO FAULTS
280	23-Jun-2020	PARTS OF SURAJ PARK, PART OF BIA PHASE I	3002	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	17:47	23-Jun-2020	18:35	48	0.00056	INTERRUPTION DUE TO FAULTS
281	23-Jun-2020	PARTS OF GALI NO-6,MASTER MOHALLA, CONTINENTAL ENGG, AMBEY GARDEN RAIL POLE, SANTOSH DHARAM KANTA	171	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	18:05	23-Jun-2020	19:05	59	0.00040	INTERRUPTION DUE TO FAULTS
282	23-Jun-2020	PARTS OF BARWALA VILLAGE, PAPPU COLONY, SRI ENCLAVE, DEEP VIHAR, DRISHNA COLONY, PRAHLAD VIHAR.	278	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	20:15	23-Jun-2020	21:00	46	0.00025	INTERRUPTION DUE TO FAULTS
283	23-Jun-2020	PARTS OF LIG SEC-28, PART OF ROHINI	44	OTHER OUTAGE	PLANNED OUTAGE	23-Jun-2020	09:48	23-Jun-2020	14:22	274	0.00008	PLANNED OUTAGE
284	23-Jun-2020	PARTS OF 448 SFS NO-1 BADLI RESIDENTIAL	168	OTHER OUTAGE	PLANNED OUTAGE	23-Jun-2020	11:10	23-Jun-2020	13:30	140	0.00008	PLANNED OUTAGE
285	2-Jun-2020	PART OF JAIN WALA (RAILWAY ROAD) BADLI	11	160 kVA	UNPLANNED OUTAGE	2-Jun-2020	11:13	2-Jun-2020	11:59	46	0.00001	SYSTEM SCHEDULE OUTAGE
286	24-Jun-2020	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE	267	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	08:15	24-Jun-2020	08:50	35	0.00006	INTERRUPTION DUE TO FAULTS
287	24-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	923	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	11:22	24-Jun-2020	14:15	173	0.00096	FORCE MAJEURE DUE TO SABOTAGE
288	24-Jun-2020	PARTS OF BADLI JAI, JAIL COLONY, BADLI POLICE QTRS. SEWAGE PUMP SECTOR - 19,	159	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	05:21	24-Jun-2020	06:14	53	0.00003	INTERRUPTION DUE TO FAULTS
289	24-Jun-2020	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	286	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	08:07	24-Jun-2020	08:40	33	0.00006	INTERRUPTION DUE TO FAULTS
290	24-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	802	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	12:19	24-Jun-2020	12:42	23	0.00010	INTERRUPTION DUE TO FAULTS
291	24-Jun-2020	PARTS OF KRISHAN COLONY BADLI	1146	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	19:01	24-Jun-2020	19:25	25	0.00017	INTERRUPTION DUE TO FAULTS
292	24-Jun-2020	PART OF BIA PHASE 6 PRAHLADPUR	5	400 kVA	UNPLANNED OUTAGE	24-Jun-2020	11:18	24-Jun-2020	12:51	93	0.00003	SYSTEM SCHEDULE OUTAGE
293	24-Jun-2020	PART OF BADLI INDUSTRIAL AREA	3	250 kVA	UNPLANNED OUTAGE	24-Jun-2020	15:12	24-Jun-2020	16:32	80	0.00002	SYSTEM SCHEDULE OUTAGE
294	24-Jun-2020	PARTS OF GALI NO-05 AND SHIV DHARAM KANTA BADLI	182	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	10:09	24-Jun-2020	16:35	386	0.00021	PLANNED OUTAGE
295	24-Jun-2020	PARTS OF SEC 17/16 ROHINI	915	990 kVA	PLANNED OUTAGE	24-Jun-2020	10:46	24-Jun-2020	12:41	115	0.00003	PLANNED OUTAGE
296	24-Jun-2020	PARTS OF 8-A,8-B, SEC-15,ARYA APARTMENT ,C-BLOCK SEC-15 & SOCIATY SEC-15	177	630 kVA	PLANNED OUTAGE	24-Jun-2020	14:26	24-Jun-2020	16:05	99	0.00005	PLANNED OUTAGE
297	25-Jun-2020	PART OF SANJAY GANDHI PHASE-II BADLI	17	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	13:01	25-Jun-2020	20:41	459	0.00013	FORCE MAJEURE DUE TO SABOTAGE
298	30-Jun-20	PART OF SHAHBAD DAIRY B - BLK BADLI	4	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	05:07	30-Jun-20	07:05	118	0.00007	INTERRUPTION DUE TO FAULTS
299	2-Jun-2020	PART OF SHAHBAD DAIRY B - BLK BADLI	5	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	10:53	2-Jun-2020	11:29	36	0.00002	INTERRUPTION DUE TO FAULTS
300	25-Jun-2020	PART OF TYRE MARKET SAMAYPUR BADLI	2	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	18:18	25-Jun-2020	19:09	51	0.00001	SYSTEM SCHEDULE OUTAGE
301	25-Jun-2020	PARTS OF GALI NO - 1,2,3,4 LIBAS PUR, SIRASPUR PARTLYGALI NO - 1,2,3,4,5,6 JEEVAN PUR, AMBE GARDEN, CHANDAN PUR, SHIV MANDIR LIBAS PUR, 66 FOOTA ROAD 66 FOOTA ROAD	412	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	19:55	25-Jun-2020	20:32	37	0.00005	INTERRUPTION DUE TO FAULTS
302	4-Jun-2020	PART OF SHAHBAD DAIRY B - BLK BADLI	7	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	11:34	4-Jun-2020	14:42	188	0.00005	PLANNED OUTAGE
303	25-Jun-2020	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY	1060	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	02:30	25-Jun-2020	02:50	20	0.00008	INTERRUPTION DUE TO FAULTS
304	25-Jun-2020	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	1091	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	04:10	25-Jun-2020	04:25	16	0.00009	INTERRUPTION DUE TO FAULTS
305	25-Jun-2020	PARTS OF GALI NO - 1,2,3,4 LIBAS PUR, SIRASPUR PARTLYGALI NO - 1,2,3,4,5,6 JEEVAN PUR, AMBE GARDEN, CHANDAN PUR, SHIV MANDIR LIBAS PUR, 66 FOOTA ROAD 66 FOOTA ROAD	429	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	13:01	25-Jun-2020	13:50	48	0.00020	INTERRUPTION DUE TO FAULTS
306	25-Jun-2020	PARTS OF MAIN SIRASPUR LIBASPUR, PART OF SIRAS PUR VILLAGE.	713	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:20	25-Jun-2020	15:03	44	0.00012	INTERRUPTION DUE TO FAULTS
307	25-Jun-2020	PARTS OF SHAHBAD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS	2762	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	18:10	25-Jun-2020	18:49	38	0.00074	INTERRUPTION DUE TO FAULTS
308	9-Jun-2020	PART OF SHAHBAD DAIRY B - BLK BADLI	4	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	14:25	9-Jun-2020	16:40	135	0.00004	FORCE MAJEURE DUE TO SABOTAGE
309	25-Jun-2020	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE	64	630 kVA	PLANNED OUTAGE	25-Jun-2020	07:39	25-Jun-2020	11:39	240	0.00007	PLANNED OUTAGE
310	25-Jun-2020	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY, PRAHLADPUR.	484	OTHER OUTAGE	PLANNED OUTAGE	25-Jun-2020	09:28	25-Jun-2020	13:40	252	0.00035	PLANNED OUTAGE
311	16-Jun-2020	PART OF SHAHBAD DAIRY B - BLK BADLI	7	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	19:05	16-Jun-2020	19:54	49	0.00007	INTERRUPTION DUE TO FAULTS
312	26-Jun-2020	PART OF SEC-26 NALA ROHINI	8	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	11:41	26-Jun-2020	12:20	39	0.00001	SYSTEM SCHEDULE OUTAGE
313	26-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	768	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	04:51	26-Jun-2020	05:10	19	0.00008	INTERRUPTION DUE TO FAULTS
314	26-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	81	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	04:51	26-Jun-2020	06:10	79	0.00013	INTERRUPTION DUE TO FAULTS
315	26-Jun-2020	PARTS OF SEC 28 PRAHLADPUR ROHINI	93	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	05:17	26-Jun-2020	06:10	53	0.00012	INTERRUPTION DUE TO FAULTS
316	26-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	428	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	07:10	26-Jun-2020	08:08	58	0.00019	INTERRUPTION DUE TO FAULTS
317	26-Jun-2020	PARTS OF SHAHBAD VILLAGE, AMAR JYOTI COLONY, B S CHEMICALS	1063	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	11:29	26-Jun-2020	13:20	111	0.00037	INTERRUPTION DUE TO FAULTS
318	26-Jun-2020	PART OF TYRE MARKET SAMAYPUR BADLI	2	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	11:53	26-Jun-2020	18:42	409	0.00011	FORCE MAJEURE DUE TO SABOTAGE
319	26-Jun-2020	PARTS OF BIA PHASE III, RAJA VIHAR, PART OF BIA PHASE II	144	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	14:18	26-Jun-2020	14:56	38	0.00005	INTERRUPTION DUE TO FAULTS
320	26-Jun-2020	PART OF GUPTA COLONY BADLI	17	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	11:14	26-Jun-2020	12:45	91	0.00005	INTERRUPTION DUE TO FAULTS
321	26-Jun-2020	PART OF RAJEEV NAGAR AMBEY GARDEN	6	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	17:01	26-Jun-2020	18:00	59	0.00003	INTERRUPTION DUE TO FAULTS
322	26-Jun-2020	PARTS OF PRAHLADPUR CHOWK BADLI	2249	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	06:28	26-Jun-2020	06:55	27	0.00027	INTERRUPTION DUE TO FAULTS
323	17-Jun-2020	PART OF SHAHBAD DAIRY B - BLK BADLI	8	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	11:44	17-Jun-2020	12:30	46	0.00003	INTERRUPTION DUE TO FAULTS
324	18-Jun-2020	PART OF SHAHBAD DAIRY B - BLK BADLI	5	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	18:26	18-Jun-2020	19:30	64	0.00002	INTERRUPTION DUE TO FAULTS
325	23-Jun-2020	PART OF SHAHBAD DAIRY B - BLK BADLI	7	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	14:25	23-Jun-2020	15:00	35	0.00002	INTERRUPTION DUE TO FAULTS
326	26-Jun-2020	PART OF GALI NO-05 SAMAYPUR BADLI	1	160 kVA	PLANNED OUTAGE	26-Jun-2020	07:35	26-Jun-2020	11:00	205	0.00006	PLANNED OUTAGE
327	27-Jun-2020	PARTS OF BARWALA VILLAGE, PAPPU COLONY, SRI ENCLAVE, DEEP VIHAR, DRISHNA COLONY, PRAHLAD VIHAR.	132	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	15:46	27-Jun-2020	16:05	19	0.00002	INTERRUPTION DUE TO FAULTS
328	27-Jun-2020	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE	267	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	18:44	27-Jun-2020	19:35	50	0.00007	INTERRUPTION DUE TO FAULTS
329	25-Jun-2020	PART OF SHAHBAD DAIRY B - BLK BADLI	10	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	19:22	25-Jun-2020	21:05	102	0.00006	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
330	27-Jun-2020	PARTS OF SAMAY PUR GALI NO.3 & SAMAY PUR GALI NO.15, GALI NO - 6 SHAKTI BHOG WALI,POST OFFICE WALI GALI, MTNL WALI GALI, MANDIR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR	652	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	23:43	28-Jun-2020	00:08	25	0.00012	INTERRUPTION DUE TO FAULTS
331	27-Jun-2020	PARTS OF SAMAY PUR GALI NO.3 & SAMAY PUR GALI NO.15, GALI NO - 6 SHAKTI BHOG WALI,POST OFFICE WALI GALI, MTNL WALI GALI, MANDIR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR	103	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	23:43	28-Jun-2020	01:22	98	0.00016	INTERRUPTION DUE TO FAULTS
332	27-Jun-2020	PARTS OF BADLI INDS. AREA PAHSE-2 & 5	29	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	09:41	27-Jun-2020	14:20	279	0.00008	PLANNED OUTAGE
333	27-Jun-2020	PART OF BIA PHASE I PRAHLADPUR	14	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	09:43	27-Jun-2020	14:17	274	0.00008	PLANNED OUTAGE
334	27-Jun-2020	PARTS OF MTNL, BIA PHASE I & PRAHLADPUR	41	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	09:39	27-Jun-2020	14:17	278	0.00008	PLANNED OUTAGE
335	27-Jun-2020	PARTS OF 1/17 BADLI RESIDENTIAL	619	630 kVA	PLANNED OUTAGE	27-Jun-2020	11:02	27-Jun-2020	13:00	118	0.00023	PLANNED OUTAGE
336	28-Jun-2020	PARTS OF OLD VILLAGE BADLI,BADLI BUS STAND & PRIMARY SCHOOL.	2309	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	17:43	28-Jun-2020	18:10	27	0.00045	INTERRUPTION DUE TO FAULTS
337	28-Jun-2020	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY	1060	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	04:22	28-Jun-2020	04:55	33	0.00015	INTERRUPTION DUE TO FAULTS
338	28-Jun-2020	PART OF BIA PHASE I PRAHLADPUR	14	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	11:53	28-Jun-2020	12:19	26	0.00010	INTERRUPTION DUE TO FAULTS
339	28-Jun-2020	PARTS OF BIA PHASE I AND PHASE 2 BADLI	99	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	11:53	28-Jun-2020	12:25	32	0.00035	INTERRUPTION DUE TO FAULTS
340	28-Jun-2020	PARTS OF INTER CONNECTOR 3&4 RG-30 TO RG-6	1791	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	12:37	28-Jun-2020	13:02	25	0.00028	INTERRUPTION DUE TO FAULTS
341	28-Jun-2020	PARTS OF SEC-35 ROHINI	673	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	23:11	28-Jun-2020	23:45	34	0.00014	INTERRUPTION DUE TO FAULTS
342	29-Jun-20	PARTS OF SEC-18 ROHINI	163	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	11:03	29-Jun-20	13:25	142	0.00008	PLANNED OUTAGE
343	29-Jun-20	PARTS OF LIG SEC-28, PART OF ROHINI	279	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	10:26	29-Jun-20	11:30	64	0.00005	PLANNED OUTAGE
344	29-Jun-20	PARTS OF LIG SEC-28, PART OF ROHINI	279	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	16:52	29-Jun-20	17:20	28	0.00002	PLANNED OUTAGE
345	29-Jun-20	PARTS OF BADLI AND PARK WALA SAMAYA PUR BADLI	615	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	00:57	29-Jun-20	01:08	11	0.00004	INTERRUPTION DUE TO FAULTS
346	29-Jun-20	PART OF BADLI INDUSTRIAL AREA	6	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	10:57	29-Jun-20	16:20	323	0.00009	FORCE MAJEURE DUE TO SABOTAGE
347	29-Jun-20	PARTS OF SAMAY PUR GALI NO.3 & SAMAY PUR GALI NO.15, GALI NO - 6 SHAKTI BHOG WALI,POST OFFICE WALI GALI, MTNL WALI GALI, MANDIR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR MOHALLA, MAIN MARKET SAMAYPUR, BAWANA ROAD SAMAYPUR	1437	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	12:48	29-Jun-20	16:55	247	0.00103	FORCE MAJEURE DUE TO SABOTAGE
348	29-Jun-20	PARTS OF DDA COMMAND TANK, B-1 SEC-29, JAIN COLONY, PRAHLADPUR.	53	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:37	29-Jun-20	18:25	48	0.00033	INTERRUPTION DUE TO FAULTS
349	29-Jun-20	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	286	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	20:09	29-Jun-20	23:10	181	0.00030	FORCE MAJEURE DUE TO SABOTAGE
350	29-Jun-20	PART OF BADLI INDUSTRIAL AREA	17	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	23:25	29-Jun-20	23:58	33	0.00003	INTERRUPTION DUE TO FAULTS
351	29-Jun-20	PARTS OF D-342,SEC-8 RHN, JUDICIAL QUARTER, SHAHBAD DAIRY B - BLOCK, BIKASH VIHAR,DAULATPUR, SHIV VIHAR,SHAHBAD DIARY	369	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	01:20	29-Jun-20	01:37	17	0.00014	INTERRUPTION DUE TO FAULTS
352	29-Jun-20	PARTS OF H. NO-29,REGAL KIOSK, GALI NO-22, TYRE MARKET, MCD OFFICE	419	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:32	29-Jun-20	17:50	18	0.00013	INTERRUPTION DUE TO FAULTS
353	29-Jun-20	PARTS OF POCKET B-4 ESS-1 SECT-35	673	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:36	29-Jun-20	18:45	69	0.00029	INTERRUPTION DUE TO FAULTS
354	29-Jun-20	PARTS OF LIG SEC-28, PART OF ROHINI	815	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:38	29-Jun-20	18:10	33	0.00014	INTERRUPTION DUE TO FAULTS
355	29-Jun-20	PARTS OF SEC-28 L.I.G NO-2, M.I.G NO-2 SEC-28, A-4 POCKET SECTOR 28 ROHINI, DDA BOOSTER PUMP, BLOCK A, SECTOR-28 ROHINI	1019	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:38	29-Jun-20	20:25	168	0.00093	FORCE MAJEURE DUE TO RAIN/STORM
356	29-Jun-20	PARTS OF SEC-28 L.I.G NO-2, M.I.G NO-2 SEC-28, A-4 POCKET SECTOR 28 ROHINI, DDA BOOSTER PUMP, BLOCK A, SECTOR-28 ROHINI	1019	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	21:30	29-Jun-20	21:40	10	0.00006	INTERRUPTION DUE TO FAULTS
357	29-Jun-20	PARTS OF GALI NO-23 LIBAS PUR, PART OF E BLK YADAV NGR, PART OF MAIN ROAD SIRASPUR LIBAS PUR	192	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:44	29-Jun-20	17:55	11	0.00005	INTERRUPTION DUE TO FAULTS
358	29-Jun-20	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	286	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:35	29-Jun-20	19:38	124	0.00021	FORCE MAJEURE DUE TO RAIN/STORM
359	29-Jun-20	PARTS OF KALI MATA MANDIR, MASTER PROPERTY.	165	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:51	29-Jun-20	18:55	64	0.00063	INTERRUPTION DUE TO FAULTS
360	29-Jun-20	PARTS OF SEC 28 PRAHLADPUR ROHINI	435	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:58	29-Jun-20	19:49	51	0.00021	INTERRUPTION DUE TO FAULTS
361	29-Jun-20	PARTS OF KALI MATA MANDIR, MASTER PROPERTY.	165	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	21:14	29-Jun-20	21:55	42	0.00007	INTERRUPTION DUE TO FAULTS
362	29-Jun-20	PARTS OF SHAHBAD DAIRY B - BLK,MCD SCHOOL, PUMP HOUSE, GUPTA COLONY SHAHBAD DAIRY	154	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	21:42	29-Jun-20	22:15	33	0.00003	INTERRUPTION DUE TO FAULTS
363	30-Jun-20	PARTS OF B BLOCK, PART OF D BLOCK,PART OF A BLOCK,PART OF C BLOCK,PART OF E BLOCK SEC-18	194	OTHER OUTAGE	PLANNED OUTAGE	30-Jun-20	11:07	30-Jun-20	13:40	153	0.00008	PLANNED OUTAGE
364	30-Jun-20	PARTS OF SEC-28 L.I.G NO-2, M.I.G NO-2 SEC-28, A-4 POCKET SECTOR 28 ROHINI, DDA BOOSTER PUMP, BLOCK A, SECTOR-28 ROHINI	234	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	00:17	30-Jun-20	00:54	37	0.00005	INTERRUPTION DUE TO FAULTS
365	30-Jun-20	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	286	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	06:49	30-Jun-20	07:16	27	0.00005	INTERRUPTION DUE TO FAULTS
366	30-Jun-20	PARTS OF SEC-28 L.I.G NO-2, M.I.G NO-2 SEC-28, A-4 POCKET SECTOR 28 ROHINI, DDA BOOSTER PUMP, BLOCK A, SECTOR-28 ROHINI	138	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	08:18	30-Jun-20	08:35	17	0.00002	INTERRUPTION DUE TO FAULTS
367	30-Jun-20	PARTS OF B BLOCK, PART OF D BLOCK,PART OF A BLOCK,PART OF C BLOCK,PART OF E BLOCK SEC-18	31	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	09:56	30-Jun-20	10:10	14	0.00001	INTERRUPTION DUE TO FAULTS
368	30-Jun-20	PARTS OF KAILASH VIHAR, PRAHALADPUR BANGAR , COMPLAINT CENTER PRAHLADPUR	165	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	12:17	30-Jun-20	12:57	40	0.00028	INTERRUPTION DUE TO FAULTS
369	30-Jun-20	PARTS OF RAM BABU BHAGAT SINGH PARK, INDRAJ SPD, LATT WALA, AMBEY GERDEN, SANTOSH DHARAM KANTA,	521	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	08:08	30-Jun-20	08:40	32	0.00009	INTERRUPTION DUE TO FAULTS
370	30-Jun-20	PARTS OF SECTOR - 26, SULMS QUARTER SHAHABAD DAIRY, GUPTA COLONY , PART SECTOR 27, 28 ROHINI, KANKAR KHERA VILLAGE	1091	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	19:41	30-Jun-20	20:06	25	0.00010	INTERRUPTION DUE TO FAULTS
371	30-Jun-20	PARTS OF AMAR JYOTI COLONY, GALI NO-4 SAMAY PUR, RAMA ENCLAVE, A-3 POCKET SECTOR -28 ROHINI	439	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	14:22	30-Jun-20	15:00	37	0.00026	INTERRUPTION DUE TO FAULTS
					BAWANA							
1	1-Jun-2020	PART OF B BLK SEC-2 POOTHKHURD BAWANA	5	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	10:47	1-Jun-2020	11:49	62	0.00003	INTERRUPTION DUE TO FAULTS
2	1-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	1910	OTHER OUTAGE	PLANNED OUTAGE	1-Jun-2020	10:22	1-Jun-2020	12:30	128	0.00028	PLANNED OUTAGE
3	1-Jun-2020	PART OF D-BLOCK SEC-1 DSIDC BAWANA	11	315 kVA	PLANNED OUTAGE	1-Jun-2020	11:52	1-Jun-2020	12:57	65	0.00002	PLANNED OUTAGE
4	1-Jun-2020	PART OF D-BLOCK SEC-1 DSIDC BAWANA	3	315 kVA	PLANNED OUTAGE	1-Jun-2020	14:24	1-Jun-2020	15:49	85	0.00002	PLANNED OUTAGE
5	1-Jun-2020	PARTS OF JJ CLUSTER NO.3 KANJHAWALA BAWANA	344	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	14:46	1-Jun-2020	16:44	118	0.00033	INTERRUPTION DUE TO FAULTS
6	1-Jun-2020	PARTS OF B BLK SEC-2 POOTH KHURD BAWANA	180	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	14:52	1-Jun-2020	15:55	63	0.00026	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
7	1-Jun-2020	PART OF J BLOCKS OF SEC - 4 DSIDC BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	16:22	1-Jun-2020	16:43	21	0.00001	INTERRUPTION DUE TO FAULTS
8	1-Jun-2020	PART OF B BLOCK SEC-1 POOTHKHURD BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	15:25	1-Jun-2020	16:18	53	0.00003	INTERRUPTION DUE TO FAULTS
9	1-Jun-2020	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	258	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	15:39	1-Jun-2020	16:18	39	0.00011	INTERRUPTION DUE TO FAULTS
10	1-Jun-2020	PARTS OF ZONAL OFFICE KARALA BAWANA	1463	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	18:20	1-Jun-2020	18:55	35	0.00058	INTERRUPTION DUE TO FAULTS
11	1-Jun-2020	PARTS OF D BLK SEC-5 POOTH KHURD BAWANA	323	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	02:03	1-Jun-2020	02:35	32	0.00044	INTERRUPTION DUE TO FAULTS
12	1-Jun-2020	PARTS OF G BLK SEC-02 POOTH KHURD BAWANA	24	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	08:35	1-Jun-2020	09:07	32	0.00036	INTERRUPTION DUE TO FAULTS
13	1-Jun-2020	PARTS OF G BLK SEC-02 POOTH KHURD BAWANA	156	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	08:35	1-Jun-2020	09:37	62	0.00017	INTERRUPTION DUE TO FAULTS
14	1-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1091	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	10:30	1-Jun-2020	11:12	42	0.00018	INTERRUPTION DUE TO FAULTS
15	1-Jun-2020	PARTS OF RANI KHERA KARALA BAWANA	2908	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	13:21	1-Jun-2020	13:45	24	0.00020	INTERRUPTION DUE TO FAULTS
16	1-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1723	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	17:16	1-Jun-2020	18:30	74	0.00041	INTERRUPTION DUE TO FAULTS
17	1-Jun-2020	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	262	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	11:29	1-Jun-2020	12:20	51	0.00014	INTERRUPTION DUE TO FAULTS
18	1-Jun-2020	PART OF G BLK SEC-02 POOTHKHURD BAWANA	1	160 kVA	UNPLANNED OUTAGE	1-Jun-2020	14:47	1-Jun-2020	15:14	27	0.00001	SYSTEM SCHEDULE OUTAGE
19	1-Jun-2020	PART OF INTERCONNECTOR - 1 POOTHKHURD BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	17:50	1-Jun-2020	19:30	100	0.00006	INTERRUPTION DUE TO FAULTS
20	1-Jun-2020	PART OF INTERCONNECTOR-1 POOTHKHURD BAWANA	2	315 kVA	UNPLANNED OUTAGE	1-Jun-2020	15:50	1-Jun-2020	16:12	22	0.00001	SYSTEM SCHEDULE OUTAGE
21	1-Jun-2020	PART OF L BLOCK SEC-3 POOTHKHURD BAWANA	7	315 kVA	UNPLANNED OUTAGE	1-Jun-2020	12:25	1-Jun-2020	13:22	57	0.00002	SYSTEM SCHEDULE OUTAGE
22	2-Jun-2020	PART OF C BLK SEC-02 POOTHKHURD BAWANA	4	160 kVA	UNPLANNED OUTAGE	2-Jun-2020	11:38	2-Jun-2020	11:57	19	0.00001	SYSTEM SCHEDULE OUTAGE
23	2-Jun-2020	PART OF C BLK SEC-1 POOTHKHURD BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	15:00	2-Jun-2020	16:05	65	0.00004	INTERRUPTION DUE TO FAULTS
24	2-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	13:50	2-Jun-2020	16:30	160	0.00004	FORCE MAJEURE DUE TO SABOTAGE
25	2-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	1365	OTHER OUTAGE	PLANNED OUTAGE	2-Jun-2020	15:30	2-Jun-2020	16:30	60	0.00022	PLANNED OUTAGE
26	2-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	1365	OTHER OUTAGE	PLANNED OUTAGE	2-Jun-2020	10:15	2-Jun-2020	12:00	105	0.00035	PLANNED OUTAGE
27	2-Jun-2020	PART OF DE BLOCK SEC-3 DSIDC	8	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	12:17	2-Jun-2020	13:09	52	0.00003	SYSTEM SCHEDULE OUTAGE
28	2-Jun-2020	PART OF I BLOCK SEC-3 POOTH KHURD	19	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	14:19	2-Jun-2020	15:40	81	0.00005	INTERRUPTION DUE TO FAULTS
29	2-Jun-2020	PARTS OF CHANDPUR MAJRA BAWANA	2108	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	22:51	2-Jun-2020	23:13	22	0.00075	INTERRUPTION DUE TO FAULTS
30	2-Jun-2020	PARTS OF DIVYA JYOTI APPARTMENT BAWANA	247	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:36	2-Jun-2020	07:35	58	0.00013	INTERRUPTION DUE TO FAULTS
31	2-Jun-2020	PARTS OF DHEERAJ VIHAR, RAJEEV NAGAR EXTN	794	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	02:34	2-Jun-2020	03:31	57	0.00024	INTERRUPTION DUE TO FAULTS
32	2-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	1730	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	05:55	2-Jun-2020	07:39	104	0.00116	INTERRUPTION DUE TO FAULTS
33	2-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	3601	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	05:59	2-Jun-2020	06:50	51	0.00050	INTERRUPTION DUE TO FAULTS
34	2-Jun-2020	PARTS OF CHANDPUR MAJRA BAWANA	2108	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	05:59	2-Jun-2020	07:15	76	0.00076	INTERRUPTION DUE TO FAULTS
35	2-Jun-2020	PARTS OF I BLK SEC-1 POOTH KHURD BAWANA	222	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:45	2-Jun-2020	07:00	15	0.00010	INTERRUPTION DUE TO FAULTS
36	2-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	3749	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	07:31	2-Jun-2020	08:14	43	0.00054	INTERRUPTION DUE TO FAULTS
37	2-Jun-2020	PARTS OF MBS HOSPITAL BAWANA & DISTRICT OFFICE BAWANA	2989	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	12:40	2-Jun-2020	13:38	58	0.00047	SYSTEM SCHEDULE OUTAGE
38	2-Jun-2020	PART OF BWN INTERCONNECTOR-1	6	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:50	2-Jun-2020	07:20	30	0.00002	INTERRUPTION DUE TO FAULTS
39	2-Jun-2020	PARTS OF F & G BLOCK SEC-3 POOTH KHURD BAWANA	243	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	09:46	2-Jun-2020	10:24	38	0.00013	INTERRUPTION DUE TO FAULTS
40	2-Jun-2020	PARTS OF A- BLOCK SEC-1 POOTH KHURD BAWANA	89	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	09:11	2-Jun-2020	09:16	5	0.00002	INTERRUPTION DUE TO FAULTS
41	2-Jun-2020	PART OF A- BLOCK SEC-1 BAWANA	14	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	09:11	2-Jun-2020	13:26	255	0.00035	FORCE MAJEURE DUE TO SABOTAGE
42	2-Jun-2020	PARTS OF A- BLOCK SEC-1 POOTH KHURD BAWANA	89	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	11:23	2-Jun-2020	13:26	122	0.00051	FORCE MAJEURE DUE TO SABOTAGE
43	2-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	1581	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	09:08	2-Jun-2020	09:35	27	0.00011	INTERRUPTION DUE TO FAULTS
44	2-Jun-2020	PARTS OF MBS HOSPITAL BAWANA & DISTRICT OFFICE BAWANA	4006	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	10:31	2-Jun-2020	10:50	19	0.00021	INTERRUPTION DUE TO FAULTS
45	2-Jun-2020	PARTS OF KARALA & PASHU AUSHADHALAYA BAWANA	775	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	11:34	2-Jun-2020	12:04	30	0.00010	INTERRUPTION DUE TO FAULTS
46	2-Jun-2020	PARTS OF D BLK SEC-5 POOTH KHURD BAWANA	164	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	14:27	2-Jun-2020	15:07	40	0.00013	INTERRUPTION DUE TO FAULTS
47	2-Jun-2020	PARTS OF L BLOCK SEC-2 DSIDC BAWANA	322	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	17:53	2-Jun-2020	18:44	51	0.00021	INTERRUPTION DUE TO FAULTS
48	2-Jun-2020	PART OF N BLK SEC-1 POOTHKHURD BAWANA	2	315 kVA	PLANNED OUTAGE	2-Jun-2020	15:09	2-Jun-2020	16:30	81	0.00002	PLANNED OUTAGE
49	2-Jun-2020	PART OF N BLK SEC-1 POOTHKHURD BAWANA	4	315 kVA	PLANNED OUTAGE	2-Jun-2020	11:07	2-Jun-2020	13:55	168	0.00005	PLANNED OUTAGE
50	2-Jun-2020	PART OF N BLK SEC-1 POOTHKHURD BAWANA	10	315 kVA	PLANNED OUTAGE	2-Jun-2020	12:11	2-Jun-2020	13:16	65	0.00002	PLANNED OUTAGE
51	2-Jun-2020	PART OF N BLK SEC-1 POOTHKHURD BAWANA	3	315 kVA	PLANNED OUTAGE	2-Jun-2020	14:10	2-Jun-2020	17:15	185	0.00005	PLANNED OUTAGE
52	2-Jun-2020	PART OF N BLK SEC-1 POOTHKHURD BAWANA	4	315 kVA	PLANNED OUTAGE	2-Jun-2020	14:25	2-Jun-2020	17:16	171	0.00005	PLANNED OUTAGE
53	2-Jun-2020	PART OF N BLK SEC-1 POOTHKHURD BAWANA	3	315 kVA	PLANNED OUTAGE	2-Jun-2020	11:09	2-Jun-2020	13:56	167	0.00005	PLANNED OUTAGE
54	2-Jun-2020	PART OF N BLK SEC-1 POOTHKHURD BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	11:40	2-Jun-2020	15:20	220	0.00006	FORCE MAJEURE DUE TO SABOTAGE
55	3-Jun-2020	PART OF GANGA TOLI ROAD BAWANA	5	315 kVA	PLANNED OUTAGE	3-Jun-2020	15:29	3-Jun-2020	16:10	41	0.00001	PLANNED OUTAGE
56	3-Jun-2020	PART OF C BLK SEC-02 POOTHKHURD BAWANA	5	250 kVA	UNPLANNED OUTAGE	3-Jun-2020	12:16	3-Jun-2020	13:00	44	0.00001	SYSTEM SCHEDULE OUTAGE
57	3-Jun-2020	PARTS OF JJ CLUSTER NO.3 KANJHAWALA BAWANA	2950	OTHER OUTAGE	PLANNED OUTAGE	3-Jun-2020	09:58	3-Jun-2020	10:42	44	0.00024	PLANNED OUTAGE
58	3-Jun-2020	PART OF GANGA TOLI ROAD BAWANA	7	315 kVA	PLANNED OUTAGE	3-Jun-2020	11:06	3-Jun-2020	15:10	244	0.00007	PLANNED OUTAGE
59	3-Jun-2020	PART OF GANGA TOLI ROAD BAWANA	4	315 kVA	PLANNED OUTAGE	3-Jun-2020	11:37	3-Jun-2020	13:09	92	0.00003	PLANNED OUTAGE
60	3-Jun-2020	PART OF GANGA TOLI ROAD BAWANA	6	315 kVA	PLANNED OUTAGE	3-Jun-2020	14:50	3-Jun-2020	16:20	90	0.00003	PLANNED OUTAGE
61	3-Jun-2020	PARTS OF JJ CLUSTER NO.3 KANJHAWALA BAWANA	344	OTHER OUTAGE	PLANNED OUTAGE	3-Jun-2020	12:57	3-Jun-2020	17:45	288	0.00032	PLANNED OUTAGE
62	3-Jun-2020	PART OF GANGA TOLI ROAD BAWANA	5	315 kVA	PLANNED OUTAGE	3-Jun-2020	11:22	3-Jun-2020	13:43	141	0.00004	PLANNED OUTAGE
63	3-Jun-2020	PART OF GANGA TOLI ROAD BAWANA	7	400 kVA	PLANNED OUTAGE	3-Jun-2020	10:57	3-Jun-2020	13:07	130	0.00004	PLANNED OUTAGE
64	3-Jun-2020	PART OF GANGA TOLI ROAD BAWANA	5	315 kVA	PLANNED OUTAGE	3-Jun-2020	14:52	3-Jun-2020	16:55	123	0.00003	PLANNED OUTAGE
65	3-Jun-2020	PARTS OF CHANDPUR MAJRA BAWANA	2108	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	10:44	3-Jun-2020	11:19	35	0.00049	INTERRUPTION DUE TO FAULTS
66	3-Jun-2020	PARTS OF MAJRI VILLAGE KARALA BAWANA	2102	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	15:29	3-Jun-2020	16:17	48	0.00019	INTERRUPTION DUE TO FAULTS
67	3-Jun-2020	PARTS OF MAJRI VILLAGE KARALA BAWANA	205	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	15:29	3-Jun-2020	21:00	331	0.00028	FORCE MAJEURE DUE TO SABOTAGE
68	3-Jun-2020	PARTS OF MAJRI VILLAGE KARALA BAWANA	2307	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	14:06	3-Jun-2020	15:22	76	0.00106	INTERRUPTION DUE TO FAULTS
69	3-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	1910	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	16:04	3-Jun-2020	16:50	46	0.00026	INTERRUPTION DUE TO FAULTS
70	3-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	1799	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	17:22	3-Jun-2020	17:40	18	0.00010	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
71	3-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2515	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	17:22	3-Jun-2020	18:00	38	0.00032	INTERRUPTION DUE TO FAULTS
72	3-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1072	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	19:05	3-Jun-2020	20:00	56	0.00039	INTERRUPTION DUE TO FAULTS
73	3-Jun-2020	PART OF INTERCONNECTOR - 1 POOTHKHURD BAWANA	2	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	15:07	3-Jun-2020	18:00	173	0.00010	FORCE MAJEURE DUE TO SABOTAGE
74	3-Jun-2020	PART OF M-BLOCK BHORGARH BAWANA	4	400 kVA	UNPLANNED OUTAGE	3-Jun-2020	11:30	3-Jun-2020	11:50	20	0.00001	SYSTEM SCHEDULE OUTAGE
75	3-Jun-2020	PART OF VILLAGE KANJHAWLA BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	15:08	3-Jun-2020	16:50	102	0.00006	INTERRUPTION DUE TO FAULTS
76	4-Jun-2020	PART OF B BLK SEC-2 POOTHKHURD BAWANA	5	250 kVA	UNPLANNED OUTAGE	4-Jun-2020	11:47	4-Jun-2020	12:11	24	0.00001	SYSTEM SCHEDULE OUTAGE
77	4-Jun-2020	PARTS OF KARALA & PASHU AUSHADHALAYA BAWANA	3832	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	08:02	4-Jun-2020	12:59	297	0.0033	PLANNED OUTAGE
78	4-Jun-2020	PART OF LM BLOCK SEC-1 DSIDC	4	315 kVA	PLANNED OUTAGE	4-Jun-2020	10:52	4-Jun-2020	15:30	278	0.00008	PLANNED OUTAGE
79	4-Jun-2020	PART OF LM BLOCK SEC-1 DSIDC	5	315 kVA	PLANNED OUTAGE	4-Jun-2020	10:46	4-Jun-2020	12:44	118	0.00003	PLANNED OUTAGE
80	4-Jun-2020	PART OF LM BLOCK SEC-1 DSIDC	7	315 kVA	PLANNED OUTAGE	4-Jun-2020	11:04	4-Jun-2020	12:45	101	0.00003	PLANNED OUTAGE
81	4-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1362	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	10:27	4-Jun-2020	10:57	30	0.00013	PLANNED OUTAGE
82	4-Jun-2020	PART OF LM BLOCK SEC-1 DSIDC	8	400 kVA	PLANNED OUTAGE	4-Jun-2020	11:07	4-Jun-2020	13:41	154	0.00004	PLANNED OUTAGE
83	4-Jun-2020	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	79	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	12:45	4-Jun-2020	13:20	35	0.00005	INTERRUPTION DUE TO FAULTS
84	4-Jun-2020	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	84	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	13:08	4-Jun-2020	13:20	12	0.00003	INTERRUPTION DUE TO FAULTS
85	4-Jun-2020	PARTS OF DJB RAW WATER PUMP HOUSE, PRAGTI POWER	24	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:31	4-Jun-2020	17:55	24	0.00007	INTERRUPTION DUE TO FAULTS
86	4-Jun-2020	PARTS OF UTSAV VIHAR, RAMA VIHAR BAWANA	2590	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	21:38	4-Jun-2020	22:11	33	0.00023	INTERRUPTION DUE TO FAULTS
87	4-Jun-2020	PARTS OF DTC DEPOT AUCHANDI ROAD BAWANA	1819	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	07:37	4-Jun-2020	07:55	18	0.00031	INTERRUPTION DUE TO FAULTS
88	4-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	804	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	10:41	4-Jun-2020	11:53	72	0.00020	INTERRUPTION DUE TO FAULTS
89	4-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	3021	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	11:49	4-Jun-2020	11:53	4	0.00006	INTERRUPTION DUE TO FAULTS
90	4-Jun-2020	PARTS OF POOTH KHURD VILLAGE BAWANA	386	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	12:49	4-Jun-2020	13:46	57	0.00006	INTERRUPTION DUE TO FAULTS
91	4-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	5198	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	13:52	4-Jun-2020	14:30	38	0.00107	INTERRUPTION DUE TO FAULTS
92	4-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	8841	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:17	4-Jun-2020	18:03	45	0.00141	INTERRUPTION DUE TO FAULTS
93	4-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	1730	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:19	4-Jun-2020	17:45	26	0.00033	INTERRUPTION DUE TO FAULTS
94	4-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	4130	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:14	4-Jun-2020	19:05	111	0.00099	INTERRUPTION DUE TO FAULTS
95	4-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	1581	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	23:20	4-Jun-2020	23:47	27	0.00011	INTERRUPTION DUE TO FAULTS
96	4-Jun-2020	PART OF I BLK SEC-1 POOTHKHURD BAWANA	6	400 kVA	UNPLANNED OUTAGE	4-Jun-2020	12:19	4-Jun-2020	12:56	37	0.00001	SYSTEM SCHEDULE OUTAGE
97	29-Jun-20	PART OF C-BLK SEC-4 POOTHKHURD BAWANA	8	315 kVA	UNPLANNED OUTAGE	29-Jun-20	15:08	29-Jun-20	16:14	66	0.00002	SYSTEM SCHEDULE OUTAGE
98	4-Jun-2020	PART OF RAMA VIHAR KARALA BAWANA	10	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	23:21	5-Jun-2020	00:26	65	0.00004	INTERRUPTION DUE TO FAULTS
99	4-Jun-2020	PART OF PUNJAB KHOR BAWANA	5	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	08:26	4-Jun-2020	13:00	274	0.00008	PLANNED OUTAGE
100	10-Jun-2020	PART OF C-BLK SEC-4 POOTHKHURD BAWANA	2	160 kVA	UNPLANNED OUTAGE	10-Jun-2020	12:50	10-Jun-2020	13:11	21	0.00001	SYSTEM SCHEDULE OUTAGE
101	5-Jun-2020	PART OF GARTHI RINDHALA BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	12:00	5-Jun-2020	13:07	67	0.00002	INTERRUPTION DUE TO FAULTS
102	5-Jun-2020	PART OF I BLOCKS OF SEC-4 DSIDC BAWANA	5	315 kVA	PLANNED OUTAGE	5-Jun-2020	11:52	5-Jun-2020	13:30	98	0.00003	PLANNED OUTAGE
103	5-Jun-2020	PART OF J BLOCKS OF SEC - 4 DSIDC BAWANA	3	315 kVA	PLANNED OUTAGE	5-Jun-2020	14:31	5-Jun-2020	16:26	115	0.00003	PLANNED OUTAGE
104	5-Jun-2020	PART OF I BLOCKS OF SEC-4 DSIDC BAWANA	5	315 kVA	PLANNED OUTAGE	5-Jun-2020	11:27	5-Jun-2020	12:58	91	0.00005	PLANNED OUTAGE
105	5-Jun-2020	PART OF I BLOCKS OF SEC-4 DSIDC BAWANA	8	400 kVA	PLANNED OUTAGE	5-Jun-2020	11:08	5-Jun-2020	12:50	102	0.00003	PLANNED OUTAGE
106	5-Jun-2020	PART OF I BLOCKS OF SEC-4 DSIDC BAWANA	5	315 kVA	PLANNED OUTAGE	5-Jun-2020	11:16	5-Jun-2020	13:32	136	0.00004	PLANNED OUTAGE
107	5-Jun-2020	PART OF J BLOCKS OF SEC - 4 DSIDC BAWANA	4	315 kVA	PLANNED OUTAGE	5-Jun-2020	14:28	5-Jun-2020	16:10	102	0.00003	PLANNED OUTAGE
108	5-Jun-2020	PART OF J BLOCKS OF SEC - 4 DSIDC BAWANA	4	315 kVA	PLANNED OUTAGE	5-Jun-2020	14:35	5-Jun-2020	16:28	113	0.00003	PLANNED OUTAGE
109	5-Jun-2020	PARTS OF VILL-RANI KHERA,VILL- RASOOL PUR, VILL-MUBARAK PUR, BAGYA VIHAR, MEER VIHAR,YOGI RAJ PURAM & PART OF AGAR NAGER	2650	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	16:04	5-Jun-2020	16:32	28	0.00039	INTERRUPTION DUE TO FAULTS
110	5-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	3098	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	06:05	5-Jun-2020	06:58	53	0.00049	INTERRUPTION DUE TO FAULTS
111	5-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	3098	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	12:43	5-Jun-2020	13:28	45	0.00075	INTERRUPTION DUE TO FAULTS
112	5-Jun-2020	PARTS OF C BLK SEC-1 POOTH KHURD BAWANA	159	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	16:14	5-Jun-2020	17:25	71	0.00065	INTERRUPTION DUE TO FAULTS
113	5-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1969	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	18:34	5-Jun-2020	18:56	22	0.00012	INTERRUPTION DUE TO FAULTS
114	5-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1057	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	18:34	5-Jun-2020	21:30	176	0.00059	FORCE MAJEURE DUE TO SABOTAGE
115	5-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1106	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	18:34	5-Jun-2020	21:30	176	0.00054	FORCE MAJEURE DUE TO SABOTAGE
116	5-Jun-2020	PARTS OF MAJRI VILLAGE KARALA BAWANA	2307	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	18:44	5-Jun-2020	19:42	58	0.00145	INTERRUPTION DUE TO FAULTS
117	5-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	102	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	23:08	5-Jun-2020	23:45	37	0.00005	INTERRUPTION DUE TO FAULTS
118	5-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	938	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	23:09	5-Jun-2020	23:45	36	0.00015	INTERRUPTION DUE TO FAULTS
119	5-Jun-2020	PARTS OF POOTH KHURD VILLAGE BAWANA	288	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	09:06	5-Jun-2020	09:35	29	0.00016	INTERRUPTION DUE TO FAULTS
120	5-Jun-2020	PARTS OF MUBARAK PUR VILLAGE, MEER VIHAR & PART OF BHAGYA VIHAR	2100	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	13:43	5-Jun-2020	14:09	26	0.00029	INTERRUPTION DUE TO FAULTS
121	5-Jun-2020	PARTS OF PUNJAB KHOD BAWANA	3001	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	15:39	5-Jun-2020	16:05	26	0.00041	INTERRUPTION DUE TO FAULTS
122	5-Jun-2020	PART OF E BLK SEC-5 POOTHKHURD BAWANA	4	315 kVA	UNPLANNED OUTAGE	5-Jun-2020	12:12	5-Jun-2020	12:44	32	0.00001	SYSTEM SCHEDULE OUTAGE
123	5-Jun-2020	PART OF INTERCONNECTOR - 1 POOTHKHURD BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	17:09	5-Jun-2020	18:00	51	0.00003	INTERRUPTION DUE TO FAULTS
124	5-Jun-2020	PART OF N BLK SEC-1 POOTHKHURD BAWANA	3	315 kVA	UNPLANNED OUTAGE	5-Jun-2020	11:19	5-Jun-2020	11:48	29	0.00001	SYSTEM SCHEDULE OUTAGE
125	5-Jun-2020	PART OF VILLAGE KANJHAWLA BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	10:29	5-Jun-2020	10:40	11	0.000003	SYSTEM SCHEDULE OUTAGE
126	6-Jun-2020	PART OF D-BLOCK SEC-1 DSIDC BAWANA	7	400 kVA	UNPLANNED OUTAGE	6-Jun-2020	10:41	6-Jun-2020	13:58	197	0.00005	FORCE MAJEURE DUE TO SABOTAGE
127	6-Jun-2020	PART OF D-BLOCK SEC-1 DSIDC BAWANA	5	315 kVA	UNPLANNED OUTAGE	6-Jun-2020	11:28	6-Jun-2020	12:51	83	0.00002	SYSTEM SCHEDULE OUTAGE
128	6-Jun-2020	PART OF D-BLOCK SEC-1 DSIDC BAWANA	8	100 kVA	UNPLANNED OUTAGE	6-Jun-2020	11:35	6-Jun-2020	13:07	92	0.00003	SYSTEM SCHEDULE OUTAGE
129	6-Jun-2020	PART OF D-BLOCK SEC-1 DSIDC BAWANA	7	400 kVA	UNPLANNED OUTAGE	6-Jun-2020	11:40	6-Jun-2020	12:15	35	0.00001	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
130	6-Jun-2020	PART OF D-BLOCK SEC-1 DSIDC BAWANA	11	315 kVA	UNPLANNED OUTAGE	6-Jun-2020	11:45	6-Jun-2020	13:51	126	0.00004	FORCE MAJEURE DUE TO SABOTAGE
131	6-Jun-2020	PART OF D-BLOCK SEC-1 DSIDC BAWANA	2	315 kVA	UNPLANNED OUTAGE	6-Jun-2020	12:34	6-Jun-2020	13:21	47	0.00001	SYSTEM SCHEDULE OUTAGE
132	6-Jun-2020	PARTS OF A, D, E, F, G, H, BLOCKS OF SEC - 2 DSIDC BAWANA	311	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	09:16	6-Jun-2020	10:47	91	0.00051	PLANNED OUTAGE
133	6-Jun-2020	PARTS OF L BLOCK SEC-2 DSIDC BAWANA	322	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	09:23	6-Jun-2020	16:39	435	0.00036	PLANNED OUTAGE
134	6-Jun-2020	PARTS OF A- BLOCK SEC-1 POOTH KHURD BAWANA	103	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	09:15	6-Jun-2020	17:56	521	0.00014	PLANNED OUTAGE
135	6-Jun-2020	PARTS OF C BLK SEC-02 POOTH KHURD BAWANA	490	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	10:00	6-Jun-2020	16:49	409	0.00057	PLANNED OUTAGE
136	6-Jun-2020	PART OF N SEC-5 BAWANA	4	315 kVA	PLANNED OUTAGE	6-Jun-2020	11:40	6-Jun-2020	14:55	195	0.00005	PLANNED OUTAGE
137	6-Jun-2020	PARTS OF SEC-5 B, N & O BLOCK BAWANA	261	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	08:16	6-Jun-2020	17:09	533	0.00074	PLANNED OUTAGE
138	6-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1362	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	21:52	6-Jun-2020	22:10	18	0.00007	INTERRUPTION DUE TO FAULTS
139	6-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1057	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	13:48	6-Jun-2020	14:45	57	0.00040	INTERRUPTION DUE TO FAULTS
140	6-Jun-2020	PARTS OF KARALA VILLAGE BAWANA	3956	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	03:46	6-Jun-2020	04:22	36	0.00100	INTERRUPTION DUE TO FAULTS
141	6-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	4132	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	07:57	6-Jun-2020	08:40	43	0.00078	INTERRUPTION DUE TO FAULTS
142	6-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	5198	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	15:36	6-Jun-2020	16:05	29	0.00088	INTERRUPTION DUE TO FAULTS
143	6-Jun-2020	PARTS OF DD MALL SECT-5 POOTH KHURD BAWANA	280	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	17:36	6-Jun-2020	18:20	44	0.00046	INTERRUPTION DUE TO FAULTS
144	6-Jun-2020	PARTS OF F & G BLOCK SEC-3 POOTH KHURD BAWANA	270	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	17:49	6-Jun-2020	18:10	21	0.00023	INTERRUPTION DUE TO FAULTS
145	6-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	1581	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	09:06	6-Jun-2020	09:28	22	0.00009	INTERRUPTION DUE TO FAULTS
146	6-Jun-2020	PART OF CHANPUR MAJRA BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	10:44	6-Jun-2020	11:25	41	0.00001	INTERRUPTION DUE TO FAULTS
147	7-Jun-2020	PART OF C BLK SEC-02 POOTHKHURD BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	06:30	7-Jun-2020	08:15	105	0.00003	INTERRUPTION DUE TO FAULTS
148	7-Jun-2020	PARTS OF VILL-RANI KHERA,VILL- RASOOL PUR, VILL-MUBARAK PUR, BAGYA VIHAR, MEER VIHAR,YOGI RAJ PURAM & PART OF AGAR NAGER	1230	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	13:45	7-Jun-2020	14:05	20	0.00006	INTERRUPTION DUE TO FAULTS
149	7-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	385	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	20:30	7-Jun-2020	22:08	98	0.00027	INTERRUPTION DUE TO FAULTS
150	7-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	1345	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	20:52	7-Jun-2020	22:08	76	0.00032	INTERRUPTION DUE TO FAULTS
151	7-Jun-2020	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	1462	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	07:47	7-Jun-2020	08:00	13	0.00005	INTERRUPTION DUE TO FAULTS
152	7-Jun-2020	PARTS OF DD MALL SECT-5 POOTH KHURD BAWANA	280	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:09	7-Jun-2020	09:35	26	0.00051	INTERRUPTION DUE TO FAULTS
153	7-Jun-2020	PARTS OF N & O BLK SEC-2, N-BLOCK-2 PROMILA FLOUR MILL	414	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:53	7-Jun-2020	11:10	77	0.00150	INTERRUPTION DUE TO FAULTS
154	15-Jun-2020	PARTS OF I-19 SEC-2 NEAR GOL CHAKKAR. BAWANA	175	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	11:11	15-Jun-2020	11:53	42	0.00018	INTERRUPTION DUE TO FAULTS
155	7-Jun-2020	PARTS OF J BLOCK SEC - 2 POOTH KHURD BAWANA	266	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	10:49	7-Jun-2020	11:10	21	0.00041	INTERRUPTION DUE TO FAULTS
156	18-Jun-2020	PART OF DIVYA JYOTI APPARTMENT BAWANA	7	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	13:22	18-Jun-2020	18:00	278	0.00015	FORCE MAJEURE DUE TO SABOTAGE
157	7-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	4132	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	03:01	7-Jun-2020	03:31	30	0.00084	INTERRUPTION DUE TO FAULTS
158	7-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	438	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:39	7-Jun-2020	10:50	70	0.00020	INTERRUPTION DUE TO FAULTS
159	7-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	1292	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:39	7-Jun-2020	11:47	127	0.00106	FORCE MAJEURE DUE TO RAIN/STORM
160	7-Jun-2020	PARTS OF KAMAL KANT JHA TO VIDYA PATI NAGAR	1030	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	10:01	7-Jun-2020	10:45	44	0.00012	INTERRUPTION DUE TO FAULTS
161	7-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	3038	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	10:28	7-Jun-2020	10:55	27	0.00022	INTERRUPTION DUE TO FAULTS
162	7-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1095	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	10:28	7-Jun-2020	11:50	81	0.00034	INTERRUPTION DUE TO FAULTS
163	19-Jun-2020	PART OF DIVYA JYOTI APPARTMENT BAWANA	7	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	08:55	19-Jun-2020	09:36	41	0.00001	INTERRUPTION DUE TO FAULTS
164	7-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1095	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	12:41	7-Jun-2020	13:15	34	0.00014	INTERRUPTION DUE TO FAULTS
165	7-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1723	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	15:32	7-Jun-2020	16:15	43	0.00018	INTERRUPTION DUE TO FAULTS
166	7-Jun-2020	PART OF JJ SAWDA ALL BLOCKS BAWANA	9	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	18:43	7-Jun-2020	19:10	27	0.00001	INTERRUPTION DUE TO FAULTS
167	8-Jun-2020	PART OF B BLOCK SEC-1 POOTHKHURD BAWANA	4	315 kVA	PLANNED OUTAGE	8-Jun-2020	10:57	8-Jun-2020	13:25	148	0.00004	PLANNED OUTAGE
168	8-Jun-2020	PART OF K BLOCK BAWANA	2	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	18:19	8-Jun-2020	18:46	27	0.00001	INTERRUPTION DUE TO FAULTS
169	17-Jun-2020	PART OF DJB RAW WATER PUMP HOUSE, PRAGTI POWER BAWANA	20	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	13:54	17-Jun-2020	16:43	169	0.00038	FORCE MAJEURE DUE TO SABOTAGE
170	17-Jun-2020	PART OF DJB RAW WATER PUMP HOUSE, PRAGTI POWER BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	14:06	17-Jun-2020	16:43	157	0.00009	FORCE MAJEURE DUE TO SABOTAGE
171	8-Jun-2020	PARTS OF KARALA & PASHU AUSHADHALAYA BAWANA	775	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	12:53	8-Jun-2020	13:40	47	0.00013	SYSTEM SCHEDULE OUTAGE
172	8-Jun-2020	PARTS OF UTSAV VIHAR, RAMA VIHAR BAWANA	2600	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	09:03	8-Jun-2020	09:56	53	0.00088	INTERRUPTION DUE TO FAULTS
173	8-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	72	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	09:41	8-Jun-2020	10:20	39	0.00005	INTERRUPTION DUE TO FAULTS
174	8-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2515	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	09:41	8-Jun-2020	10:50	69	0.00096	INTERRUPTION DUE TO FAULTS
175	8-Jun-2020	PART OF D-BLOCK SEC-1 DSIDC BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	14:28	8-Jun-2020	15:34	66	0.00002	INTERRUPTION DUE TO FAULTS
176	8-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2574	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	08:14	8-Jun-2020	08:40	26	0.00043	INTERRUPTION DUE TO FAULTS
177	8-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	6939	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	10:50	8-Jun-2020	12:15	85	0.00188	INTERRUPTION DUE TO FAULTS
178	8-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	1902	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	10:50	8-Jun-2020	12:20	90	0.00050	INTERRUPTION DUE TO FAULTS
179	8-Jun-2020	PART OF D-BLOCK SEC-1 DSIDC BAWANA	6	250 kVA	UNPLANNED OUTAGE	8-Jun-2020	12:00	8-Jun-2020	12:32	32	0.00001	SYSTEM SCHEDULE OUTAGE
180	8-Jun-2020	PART OF I BLOCKS OF SEC-4 DSIDC BAWANA	4	160 kVA	UNPLANNED OUTAGE	8-Jun-2020	12:04	8-Jun-2020	12:29	25	0.00001	SYSTEM SCHEDULE OUTAGE
181	8-Jun-2020	PART OF L BLOCK SEC-2 DSIDC	7	160 kVA	UNPLANNED OUTAGE	8-Jun-2020	13:52	8-Jun-2020	14:13	21	0.00001	SYSTEM SCHEDULE OUTAGE
182	8-Jun-2020	PARTS OF C BLK SEC-1 POOTH KHURD BAWANA	159	OTHER OUTAGE	PLANNED OUTAGE	8-Jun-2020	07:06	8-Jun-2020	11:05	239	0.00013	PLANNED OUTAGE
183	8-Jun-2020	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA LADPUR ROAD MAJRA VILLAGE,JHIMAR PURA VILLAGE,MTNL CHANDPUR,CHANDPUR HARIJAN BASTI BAL KISHAN,BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANJHAWALA SDM COURT KANJHAWALA	520	OTHER OUTAGE	PLANNED OUTAGE	8-Jun-2020	09:58	8-Jun-2020	16:55	417	0.00058	PLANNED OUTAGE
184	8-Jun-2020	PART OF INTERCONNECTOR - 1 POOTHKHURD BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	11:56	8-Jun-2020	14:39	163	0.00005	FORCE MAJEURE DUE TO SABOTAGE
185	8-Jun-2020	PART OF LM BLOCK SEC-1 POOTHKHURD BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	14:21	8-Jun-2020	14:50	29	0.00001	SYSTEM SCHEDULE OUTAGE
186	8-Jun-2020	PART OF N-1 BLOCK SEC-5 BAWANA	4	315 kVA	UNPLANNED OUTAGE	8-Jun-2020	15:53	8-Jun-2020	16:39	46	0.00001	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
187	9-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	5	315 kVA	PLANNED OUTAGE	9-Jun-2020	11:09	9-Jun-2020	13:14	125	0.00003	PLANNED OUTAGE
188	9-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	5	160 kVA	PLANNED OUTAGE	9-Jun-2020	14:14	9-Jun-2020	16:27	133	0.00004	PLANNED OUTAGE
189	9-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	8	160 kVA	PLANNED OUTAGE	9-Jun-2020	13:42	9-Jun-2020	15:41	119	0.00003	PLANNED OUTAGE
190	9-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	3	315 kVA	PLANNED OUTAGE	9-Jun-2020	14:39	9-Jun-2020	16:29	110	0.00003	PLANNED OUTAGE
191	9-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	4	400 kVA	PLANNED OUTAGE	9-Jun-2020	10:53	9-Jun-2020	13:36	163	0.00005	PLANNED OUTAGE
192	9-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	7	315 kVA	PLANNED OUTAGE	9-Jun-2020	14:00	9-Jun-2020	15:39	99	0.00003	PLANNED OUTAGE
193	9-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	3	400 kVA	PLANNED OUTAGE	9-Jun-2020	10:42	9-Jun-2020	12:40	118	0.00003	PLANNED OUTAGE
194	9-Jun-2020	PART OF E BLK SEC-5 POOTHKHURD BAWANA	3	315 kVA	PLANNED OUTAGE	9-Jun-2020	10:51	9-Jun-2020	13:00	129	0.00004	PLANNED OUTAGE
195	9-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	822	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	15:24	9-Jun-2020	16:20	56	0.00023	INTERRUPTION DUE TO FAULTS
196	9-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1106	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	21:17	9-Jun-2020	22:20	63	0.00032	INTERRUPTION DUE TO FAULTS
197	9-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	1902	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	07:05	9-Jun-2020	08:05	60	0.00025	INTERRUPTION DUE TO FAULTS
198	9-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	6939	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	07:17	9-Jun-2020	08:05	48	0.00067	INTERRUPTION DUE TO FAULTS
199	9-Jun-2020	PARTS OF UTSAV VIHAR, RAMA VIHAR BAWANA	3480	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	10:18	9-Jun-2020	10:46	28	0.00047	INTERRUPTION DUE TO FAULTS
200	9-Jun-2020	PARTS OF A,F BLK SEC-2 DSIDC BAWANA	270	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	14:41	9-Jun-2020	15:25	44	0.00097	INTERRUPTION DUE TO FAULTS
201	9-Jun-2020	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	1	OTHER OUTAGE	PLANNED OUTAGE	9-Jun-2020	09:58	9-Jun-2020	17:17	439	0.00012	PLANNED OUTAGE
202	9-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1914	OTHER OUTAGE	PLANNED OUTAGE	9-Jun-2020	08:28	9-Jun-2020	11:05	156	0.00087	PLANNED OUTAGE
203	9-Jun-2020	PART OF P BLOCKS OF SEC.-1 DSIDC BAWANA	1	OTHER OUTAGE	PLANNED OUTAGE	9-Jun-2020	09:57	9-Jun-2020	17:16	439	0.00012	PLANNED OUTAGE
204	9-Jun-2020	PART OF INTERCONNECTOR - 1 POOTHKHURD BAWANA	3	315 kVA	UNPLANNED OUTAGE	9-Jun-2020	12:57	9-Jun-2020	13:44	47	0.00001	SYSTEM SCHEDULE OUTAGE
205	9-Jun-2020	PART OF N BLOCK SEC-2 POOTHKHURD BAWANA	7	315 kVA	UNPLANNED OUTAGE	9-Jun-2020	15:34	9-Jun-2020	16:21	47	0.00001	SYSTEM SCHEDULE OUTAGE
206	9-Jun-2020	PART OF VILLAGE KANJHAWLA BAWANA	1	OTHER OUTAGE	PLANNED OUTAGE	9-Jun-2020	14:43	9-Jun-2020	15:30	47	0.00001	PLANNED OUTAGE
207	10-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	3	315 kVA	UNPLANNED OUTAGE	10-Jun-2020	14:46	10-Jun-2020	14:58	12	0.000003	SYSTEM SCHEDULE OUTAGE
208	10-Jun-2020	PART OF G BLOCK POOTHKHURD BAWANA	3	400 kVA	PLANNED OUTAGE	10-Jun-2020	10:14	10-Jun-2020	13:19	185	0.00005	PLANNED OUTAGE
209	10-Jun-2020	PART OF G BLOCK POOTHKHURD BAWANA	5	315 kVA	PLANNED OUTAGE	10-Jun-2020	10:58	10-Jun-2020	12:18	80	0.00002	PLANNED OUTAGE
210	10-Jun-2020	PART OF G BLOCK POOTHKHURD BAWANA	2	315 kVA	PLANNED OUTAGE	10-Jun-2020	10:09	10-Jun-2020	13:50	221	0.00006	PLANNED OUTAGE
211	10-Jun-2020	PART OF G BLOCK POOTHKHURD BAWANA	4	250 kVA	PLANNED OUTAGE	10-Jun-2020	08:20	10-Jun-2020	12:15	235	0.00007	PLANNED OUTAGE
212	10-Jun-2020	PART OF G BLOCK POOTHKHURD BAWANA	4	400 kVA	PLANNED OUTAGE	10-Jun-2020	07:37	10-Jun-2020	09:30	113	0.00003	PLANNED OUTAGE
213	10-Jun-2020	PART OF G BLOCK POOTHKHURD BAWANA	2	250 kVA	PLANNED OUTAGE	10-Jun-2020	13:55	10-Jun-2020	16:40	165	0.00005	PLANNED OUTAGE
214	10-Jun-2020	PARTS OF NEAR COMMUNITY CENTER(AUCHANDI VILLAGE), MUNGESHPUR	2244	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	14:31	10-Jun-2020	15:23	51	0.00118	SYSTEM SCHEDULE OUTAGE
215	10-Jun-2020	PARTS OF A,F BLK SEC-2 DSIDC BAWANA	296	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	14:45	10-Jun-2020	15:10	25	0.00008	INTERRUPTION DUE TO FAULTS
216	10-Jun-2020	PARTS OF KARALA VILLAGE BAWANA	4173	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	14:56	10-Jun-2020	15:47	51	0.00058	INTERRUPTION DUE TO FAULTS
217	10-Jun-2020	PARTS OF RANI KHERA KARALA BAWANA	2908	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	21:56	10-Jun-2020	22:30	33	0.00106	INTERRUPTION DUE TO FAULTS
218	10-Jun-2020	PARTS OF ASTHAL CLNY, KOTAKHAR RD, RAMESH NAGAR	2062	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	02:55	10-Jun-2020	03:20	25	0.00014	INTERRUPTION DUE TO FAULTS
219	10-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	3243	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	05:50	10-Jun-2020	06:15	25	0.00017	INTERRUPTION DUE TO FAULTS
220	10-Jun-2020	PART OF N SEC-5 BAWANA	2	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	10:46	10-Jun-2020	12:57	131	0.00004	FORCE MAJEURE DUE TO SABOTAGE
221	10-Jun-2020	PART OF JJ SAWDA ALL BLOCKS BAWANA	18	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	11:53	10-Jun-2020	12:22	29	0.00002	INTERRUPTION DUE TO FAULTS
222	22-Jun-2020	PARTS OF KANJHAWLA VILLAGE BAWANA	2583	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	00:43	22-Jun-2020	01:04	20	0.00088	INTERRUPTION DUE TO FAULTS
223	10-Jun-2020	PARTS OF N & O BLK SEC-2, N-BLOCK-2 PROMILA FLOUR MILL	414	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	02:13	10-Jun-2020	02:36	23	0.00033	INTERRUPTION DUE TO FAULTS
224	22-Jun-2020	PARTS OF KANJHAWLA VILLAGE BAWANA	26	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	06:03	22-Jun-2020	06:34	31	0.00004	INTERRUPTION DUE TO FAULTS
225	22-Jun-2020	PARTS OF KANJHAWLA VILLAGE BAWANA	334	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	06:23	22-Jun-2020	07:00	37	0.00005	INTERRUPTION DUE TO FAULTS
226	10-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	1365	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:36	10-Jun-2020	16:50	14	0.00005	INTERRUPTION DUE TO FAULTS
227	10-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	1222	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:36	10-Jun-2020	17:05	29	0.00010	INTERRUPTION DUE TO FAULTS
228	10-Jun-2020	PARTS OF DTC DEPOT AUCHANDI ROAD BAWANA	1636	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:38	10-Jun-2020	17:00	22	0.00010	INTERRUPTION DUE TO FAULTS
229	10-Jun-2020	PARTS OF MBS BAWANA	2831	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:38	10-Jun-2020	17:00	22	0.00017	INTERRUPTION DUE TO FAULTS
230	10-Jun-2020	PARTS OF CHANDPUR MAJRA BAWANA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:41	10-Jun-2020	17:09	28	0.00016	INTERRUPTION DUE TO FAULTS
231	22-Jun-2020	PARTS OF KANJHAWLA VILLAGE BAWANA	26	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	10:53	22-Jun-2020	12:55	121	0.00017	FORCE MAJEURE DUE TO SABOTAGE
232	10-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	4133	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:49	10-Jun-2020	17:30	41	0.00057	INTERRUPTION DUE TO FAULTS
233	10-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	438	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:45	10-Jun-2020	18:44	59	0.00025	INTERRUPTION DUE TO FAULTS
234	10-Jun-2020	PARTS OF RANI KHERA KARALA BAWANA	2908	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:08	10-Jun-2020	18:28	20	0.00016	INTERRUPTION DUE TO FAULTS
235	10-Jun-2020	PARTS OF A,F BLK SEC-2 DSIDC BAWANA	296	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:42	10-Jun-2020	19:05	23	0.00008	INTERRUPTION DUE TO FAULTS
236	10-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2587	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	19:18	10-Jun-2020	19:30	12	0.00008	INTERRUPTION DUE TO FAULTS
237	10-Jun-2020	PART OF G BLOCK POOTHKHURD BAWANA	6	315 kVA	PLANNED OUTAGE	10-Jun-2020	07:56	10-Jun-2020	09:55	119	0.00003	PLANNED OUTAGE
238	10-Jun-2020	PART OF N SEC-5 BAWANA	5	250 kVA	UNPLANNED OUTAGE	10-Jun-2020	15:16	10-Jun-2020	15:39	23	0.00001	SYSTEM SCHEDULE OUTAGE
239	10-Jun-2020	PART OF O-BLOCKS OF SEC-2 DSIDC BAWANA	1	630 kVA	UNPLANNED OUTAGE	10-Jun-2020	15:36	10-Jun-2020	16:04	28	0.00001	SYSTEM SCHEDULE OUTAGE
240	10-Jun-2020	PARTS OF DIVYA JYOTI APPARTMENT BAWANA	226	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	10:34	10-Jun-2020	12:55	141	0.00008	PLANNED OUTAGE
241	10-Jun-2020	PARTS OF ROOPALI ENCLAVE KARALA BAWANA	3243	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	08:14	10-Jun-2020	14:05	351	0.00293	PLANNED OUTAGE
242	10-Jun-2020	PARTS OF A & D BLOCK J J COLONY BAWANA	650	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	11:08	10-Jun-2020	15:40	272	0.00053	PLANNED OUTAGE
243	10-Jun-2020	PART OF O BLK SEC-1 POOTHKHURD BAWANA	6	315 kVA	UNPLANNED OUTAGE	10-Jun-2020	12:25	10-Jun-2020	13:36	71	0.00002	SYSTEM SCHEDULE OUTAGE
244	10-Jun-2020	PART OF N-1 BLOCK SEC-5 BAWANA	2	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	15:04	10-Jun-2020	16:16	72	0.00004	INTERRUPTION DUE TO FAULTS
245	11-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	6	400 kVA	UNPLANNED OUTAGE	11-Jun-2020	15:41	11-Jun-2020	16:23	42	0.00001	SYSTEM SCHEDULE OUTAGE
246	11-Jun-2020	PARTS OF D-BLOCK SEC-1 POOTH KHURD BAWANA	129	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	06:42	11-Jun-2020	07:18	36	0.00011	INTERRUPTION DUE TO FAULTS
247	26-Jun-2020	PARTS OF KANJHAWLA VILLAGE BAWANA	1050	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	09:44	26-Jun-2020	09:56	12	0.00010	INTERRUPTION DUE TO FAULTS
248	11-Jun-2020	PARTS OF CHANDPUR MAJRA BAWANA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	20:20	11-Jun-2020	20:50	30	0.00018	INTERRUPTION DUE TO FAULTS
249	11-Jun-2020	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	1462	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	21:07	11-Jun-2020	21:20	13	0.00027	INTERRUPTION DUE TO FAULTS
250	11-Jun-2020	PARTS OF RANI KHERA KARALA BAWANA	2908	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	13:53	11-Jun-2020	14:37	43	0.00035	INTERRUPTION DUE TO FAULTS
251	11-Jun-2020	PARTS OF MBS BAWANA	358	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	17:54	11-Jun-2020	18:15	21	0.00007	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
252	11-Jun-2020	PART OF HI BLOCK SEC 5 DSIIDC BAWANA	7	250 kVA	UNPLANNED OUTAGE	11-Jun-2020	13:22	11-Jun-2020	13:47	25	0.00001	SYSTEM SCHEDULE OUTAGE
253	30-Jun-20	PART OF F BLK SEC-1 POOTHKHURD BAWANA	5	400 kVA	UNPLANNED OUTAGE	30-Jun-20	11:46	30-Jun-20	12:26	40	0.00001	SYSTEM SCHEDULE OUTAGE
254	11-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	1222	OTHER OUTAGE	PLANNED OUTAGE	11-Jun-2020	09:55	11-Jun-2020	12:00	125	0.00042	PLANNED OUTAGE
255	11-Jun-2020	PART OF SEC-5 B BLOCK BAWANA	4	315 kVA	PLANNED OUTAGE	11-Jun-2020	07:56	11-Jun-2020	09:30	94	0.00003	PLANNED OUTAGE
256	11-Jun-2020	PART OF SEC-5 B BLOCK BAWANA	4	315 kVA	PLANNED OUTAGE	11-Jun-2020	07:39	11-Jun-2020	09:20	101	0.00003	PLANNED OUTAGE
257	11-Jun-2020	PART OF SEC-5 B BLOCK BAWANA	1	400 kVA	PLANNED OUTAGE	11-Jun-2020	08:16	11-Jun-2020	08:55	39	0.00001	PLANNED OUTAGE
258	11-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	52	OTHER OUTAGE	PLANNED OUTAGE	11-Jun-2020	10:22	11-Jun-2020	12:25	123	0.00003	PLANNED OUTAGE
259	11-Jun-2020	PART OF TUBEWELL NO - 1322 POOTHKHURD BAWANA	6	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	11:15	11-Jun-2020	12:20	65	0.00004	INTERRUPTION DUE TO FAULTS
260	11-Jun-2020	PART OF VILLAGE KANJHAWLA BAWANA	11	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	14:10	11-Jun-2020	15:00	50	0.00001	INTERRUPTION DUE TO FAULTS
261	12-Jun-2020	PART OF GARTHI RINDHALA BAWANA	8	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	10:11	12-Jun-2020	14:50	279	0.00008	PLANNED OUTAGE
262	12-Jun-2020	PART OF D BLOCK SEC-2 POOTHKHURD BAWANA	6	63 kVA	UNPLANNED OUTAGE	12-Jun-2020	15:38	12-Jun-2020	16:06	28	0.00001	SYSTEM SCHEDULE OUTAGE
263	12-Jun-2020	PART OF D BLOCK SEC-2 POOTHKHURD BAWANA	4	315 kVA	UNPLANNED OUTAGE	12-Jun-2020	16:08	12-Jun-2020	16:22	14	0.000003	SYSTEM SCHEDULE OUTAGE
264	12-Jun-2020	PARTS OF KARALA & PASHU AUSHADHALAYA BAWANA	3832	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	00:58	12-Jun-2020	01:14	16	0.00033	SYSTEM SCHEDULE OUTAGE
265	12-Jun-2020	PARTS OF C,D,I BLOCKS OF SEC - 4 DSIDC BAWANA	163	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	06:27	12-Jun-2020	07:30	63	0.00044	INTERRUPTION DUE TO FAULTS
266	12-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	4821	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:20	12-Jun-2020	12:40	20	0.00026	INTERRUPTION DUE TO FAULTS
267	12-Jun-2020	PARTS OF DTC DEPOT AUCHANDI ROAD BAWANA	1819	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:28	12-Jun-2020	12:50	22	0.00011	INTERRUPTION DUE TO FAULTS
268	12-Jun-2020	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA LADPUR ROAD MAJRA VILLAGE,JHIMAR PURA VILLAGE,MTNL CHANDPUR,CHANDPUR HARIJAN BASTI BAL KISHAN,BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANJHAWALA SDM COURT KANJHAWALA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:38	12-Jun-2020	13:26	48	0.00029	INTERRUPTION DUE TO FAULTS
269	12-Jun-2020	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	1462	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:49	12-Jun-2020	13:29	40	0.00100	INTERRUPTION DUE TO FAULTS
270	12-Jun-2020	PARTS OF KARALA VILLAGE BAWANA	4321	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:52	12-Jun-2020	14:26	94	0.00112	INTERRUPTION DUE TO FAULTS
271	12-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	3099	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:54	12-Jun-2020	13:52	58	0.00048	INTERRUPTION DUE TO FAULTS
272	12-Jun-2020	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR	1496	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:51	12-Jun-2020	14:16	85	0.00035	INTERRUPTION DUE TO FAULTS
273	12-Jun-2020	PARTS OF POOTH KHURD VILLAGE BAWANA	386	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:59	12-Jun-2020	13:37	38	0.00013	INTERRUPTION DUE TO FAULTS
274	12-Jun-2020	PARTS OF DIVYA JYOTI APPARTMENT BAWANA	25	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:35	12-Jun-2020	14:10	35	0.00012	INTERRUPTION DUE TO FAULTS
275	12-Jun-2020	PART OF JJ CLUSTER BAWANA	15	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	19:55	12-Jun-2020	20:26	31	0.00002	INTERRUPTION DUE TO FAULTS
276	5-Jun-2020	PART OF F BLK SEC-1 POOTHKHURD BAWANA	4	400 kVA	UNPLANNED OUTAGE	5-Jun-2020	14:35	5-Jun-2020	15:42	67	0.00002	SYSTEM SCHEDULE OUTAGE
277	12-Jun-2020	PARTS OF MBS HOSPITAL BAWANA & DISTRICT OFFICE BAWANA	3173	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:45	12-Jun-2020	13:00	15	0.00013	INTERRUPTION DUE TO FAULTS
278	12-Jun-2020	PARTS OF UMRAO FARM TO HARIZAN BASTI KARALA, NDPL OFFICE KARALA TO SARDAREY WALA DT	45	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:50	12-Jun-2020	13:36	46	0.00045	INTERRUPTION DUE TO FAULTS
279	12-Jun-2020	PARTS OF A,F BLK SEC-2 DSIDC BAWANA	270	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:53	12-Jun-2020	13:30	37	0.00012	INTERRUPTION DUE TO FAULTS
280	12-Jun-2020	PARTS OF INTERCONNECTOR - 3&4 AND POOTH VILLAGE	361	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:50	12-Jun-2020	13:50	60	0.00025	INTERRUPTION DUE TO FAULTS
281	12-Jun-2020	PARTS OF MAZRI VILLAGE AND KANJHAWLA VILLAGE	916	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:44	12-Jun-2020	14:58	73	0.00043	INTERRUPTION DUE TO FAULTS
282	12-Jun-2020	PARTS OF MAZRI VILLAGE AND KANJHAWLA VILLAGE	757	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:44	12-Jun-2020	15:45	120	0.00040	INTERRUPTION DUE TO FAULTS
283	12-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	1171	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	14:01	12-Jun-2020	14:45	44	0.00022	INTERRUPTION DUE TO FAULTS
284	12-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	394	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	14:01	12-Jun-2020	14:45	44	0.00010	INTERRUPTION DUE TO FAULTS
285	12-Jun-2020	PARTS OF POOTH KHURD VILLAGE BAWANA	288	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	15:05	12-Jun-2020	15:50	45	0.00015	INTERRUPTION DUE TO FAULTS
286	12-Jun-2020	PART OF KARALA VILLAGE BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	15:08	12-Jun-2020	16:40	92	0.00003	INTERRUPTION DUE TO FAULTS
287	12-Jun-2020	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA LADPUR ROAD MAJRA VILLAGE,JHIMAR PURA VILLAGE,MTNL CHANDPUR,CHANDPUR HARIJAN BASTI BAL KISHAN,BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANJHAWALA SDM COURT KANJHAWALA	521	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	16:48	12-Jun-2020	17:02	13	0.00004	INTERRUPTION DUE TO FAULTS
288	12-Jun-2020	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1	2891	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	16:50	12-Jun-2020	17:04	14	0.00015	INTERRUPTION DUE TO FAULTS
289	12-Jun-2020	PARTS OF INTERCONNECTOR 1 & 2 POOTH KHURD BAWANA	225	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	18:33	12-Jun-2020	19:00	26	0.00009	INTERRUPTION DUE TO FAULTS
290	12-Jun-2020	PART OF BWN INTERCONNECTOR-1	6	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	18:33	12-Jun-2020	19:05	31	0.00004	INTERRUPTION DUE TO FAULTS
291	12-Jun-2020	PARTS OF MBS BAWANA	84	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	18:37	12-Jun-2020	19:45	68	0.00023	INTERRUPTION DUE TO FAULTS
292	12-Jun-2020	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA LADPUR ROAD MAJRA VILLAGE,JHIMAR PURA VILLAGE,MTNL CHANDPUR,CHANDPUR HARIJAN BASTI BAL KISHAN,BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANJHAWALA SDM COURT KANJHAWALA	521	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	20:24	12-Jun-2020	20:46	22	0.00020	INTERRUPTION DUE TO FAULTS
293	12-Jun-2020	PARTS OF SEC -3 D,E BLOCK POOTH KHURD BAWANA	221	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	22:44	12-Jun-2020	23:35	51	0.00048	INTERRUPTION DUE TO FAULTS
294	12-Jun-2020	PARTS OF SEC -3 D,E BLOCK POOTH KHURD BAWANA	293	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	22:44	12-Jun-2020	23:42	57	0.00045	INTERRUPTION DUE TO FAULTS
295	12-Jun-2020	PARTS OF SUBZI MANDI KANJHAWALA ROAD, INDRAJ COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANJHAWALA ROAD	3556	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	23:28	12-Jun-2020	23:37	8	0.00029	INTERRUPTION DUE TO FAULTS
296	19-Jun-2020	PART OF F BLK SEC-1 POOTHKHURD BAWANA	6	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	14:53	19-Jun-2020	15:32	39	0.00005	INTERRUPTION DUE TO FAULTS
297	12-Jun-2020	PART OF F BLOCK SEC-4 DSIDC BAWANA	4	63 kVA	UNPLANNED OUTAGE	12-Jun-2020	11:06	12-Jun-2020	12:03	57	0.00002	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
298	12-Jun-2020	PART OF N SEC-5 BAWANA	3	160 kVA	UNPLANNED OUTAGE	12-Jun-2020	13:29	12-Jun-2020	14:24	55	0.00002	SYSTEM SCHEDULE OUTAGE
299	30-Jun-20	PART OF G BLK SEC-5 POOTHKHURD BAWANA	3	250 kVA	UNPLANNED OUTAGE	30-Jun-20	11:20	30-Jun-20	12:45	85	0.00002	SYSTEM SCHEDULE OUTAGE
300	12-Jun-2020	PART OF M BLOCK SECTOR-1 POOTHKHURD BAWANA	12	400 kVA	UNPLANNED OUTAGE	12-Jun-2020	16:18	12-Jun-2020	16:30	12	0.000003	SYSTEM SCHEDULE OUTAGE
301	12-Jun-2020	PART OF TUBEWELL NO - 1322 POOTHKHURD BAWANA	6	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	11:24	12-Jun-2020	16:45	320	0.00009	PLANNED OUTAGE
302	13-Jun-2020	PART OF GARTHI RINDHALA BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	11:14	13-Jun-2020	12:03	49	0.00004	INTERRUPTION DUE TO FAULTS
303	13-Jun-2020	PART OF E BLK SEC-5 POOTHKHURD BAWANA	3	400 kVA	UNPLANNED OUTAGE	13-Jun-2020	11:26	13-Jun-2020	12:04	38	0.00001	SYSTEM SCHEDULE OUTAGE
304	25-Jun-2020	PART OF G BLK SEC-5 POOTHKHURD BAWANA	5	400 kVA	UNPLANNED OUTAGE	25-Jun-2020	14:24	25-Jun-2020	15:20	56	0.00002	SYSTEM SCHEDULE OUTAGE
305	13-Jun-2020	PARTS OF INTERCONNECTOR 1 & 2 POOTH KHURD BAWANA	231	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:51	13-Jun-2020	17:38	47	0.00039	INTERRUPTION DUE TO FAULTS
306	13-Jun-2020	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	1462	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:16	13-Jun-2020	17:25	9	0.00004	SYSTEM SCHEDULE OUTAGE
307	25-Jun-2020	PART OF G BLK SEC-5 POOTHKHURD BAWANA	1	160 kVA	PLANNED OUTAGE	25-Jun-2020	10:46	25-Jun-2020	12:45	119	0.00003	PLANNED OUTAGE
308	13-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	433	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	11:24	13-Jun-2020	12:03	39	0.00011	INTERRUPTION DUE TO FAULTS
309	13-Jun-2020	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA LADPUR ROAD MAJRA VILLAGE,JHIMAR PURA VILLAGE,MTNL CHANDPUR,CHANDPUR HARIJAN BASTI BAL KISHAN,BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANJHAWALA SDM COURT KANJHAWALA	521	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	12:28	13-Jun-2020	12:50	22	0.00025	INTERRUPTION DUE TO FAULTS
310	13-Jun-2020	PARTS OF RANI KHERA KARALA BAWANA	1487	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	13:35	13-Jun-2020	15:20	105	0.00053	INTERRUPTION DUE TO FAULTS
311	13-Jun-2020	PARTS OF RANI KHERA KARALA BAWANA	1421	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	13:35	13-Jun-2020	16:12	157	0.00070	FORCE MAJEURE DUE TO RAIN/STORM
312	13-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	5016	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	12:58	13-Jun-2020	14:26	88	0.00122	INTERRUPTION DUE TO FAULTS
313	13-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	3825	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	12:58	13-Jun-2020	14:52	114	0.00095	INTERRUPTION DUE TO FAULTS
314	13-Jun-2020	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	1462	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:22	13-Jun-2020	16:49	27	0.00030	INTERRUPTION DUE TO FAULTS
315	13-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	1730	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	19:43	13-Jun-2020	20:15	32	0.00044	INTERRUPTION DUE TO FAULTS
316	13-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2587	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	21:14	13-Jun-2020	21:35	21	0.00047	INTERRUPTION DUE TO FAULTS
317	13-Jun-2020	PARTS OF LM BLOCK SEC-1 POOTH KHURD BAWANA	237	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	23:57	14-Jun-2020	00:30	33	0.00018	INTERRUPTION DUE TO FAULTS
318	13-Jun-2020	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	63	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	02:17	13-Jun-2020	02:58	42	0.00029	INTERRUPTION DUE TO FAULTS
319	13-Jun-2020	PARTS OF UTSAV VIHAR, RAMA VIHAR BAWANA	2488	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	06:35	13-Jun-2020	07:15	40	0.00094	INTERRUPTION DUE TO FAULTS
320	13-Jun-2020	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	63	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:01	13-Jun-2020	15:44	43	0.00030	INTERRUPTION DUE TO FAULTS
321	13-Jun-2020	PARTS OF PUNJAB KHOD BAWANA	4912	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:53	13-Jun-2020	15:20	27	0.00059	INTERRUPTION DUE TO FAULTS
322	13-Jun-2020	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR	1496	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	08:26	13-Jun-2020	13:23	297	0.00124	PLANNED OUTAGE
323	13-Jun-2020	PART OF SEC-5 B BLOCK BAWANA	4	250 kVA	PLANNED OUTAGE	13-Jun-2020	11:24	13-Jun-2020	16:00	276	0.00008	PLANNED OUTAGE
324	13-Jun-2020	PARTS OF O-BLOCK SEC-1 POOTH KHURD BAWANA	226	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	08:51	13-Jun-2020	17:44	532	0.0003	PLANNED OUTAGE
325	13-Jun-2020	PARTS OF A,B,G,E,F,H,J BLOCKS OF SEC - 4 DSIDC BAWANA	273	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	08:16	13-Jun-2020	16:45	509	0.00028	PLANNED OUTAGE
326	13-Jun-2020	PARTS OF INTERCONNECTOR 1 & 2 POOTH KHURD BAWANA	231	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	11:46	13-Jun-2020	12:08	22	0.00001	PLANNED OUTAGE
327	13-Jun-2020	PARTS OF A,F BLK SEC-2 DSIDC BAWANA	296	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	09:35	13-Jun-2020	17:56	501	0.00028	PLANNED OUTAGE
328	13-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	1068	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	08:03	13-Jun-2020	13:14	311	0.00095	PLANNED OUTAGE
329	11-Jun-2020	PART OF G BLOCK SEC-3 POOTHKHURD BAWANA	4	250 kVA	UNPLANNED OUTAGE	11-Jun-2020	15:46	11-Jun-2020	16:42	56	0.00002	SYSTEM SCHEDULE OUTAGE
330	13-Jun-2020	PART OF M BLOCK SECTOR-1 POOTHKHURD BAWANA	3	250 kVA	UNPLANNED OUTAGE	13-Jun-2020	12:33	13-Jun-2020	13:09	36	0.00001	SYSTEM SCHEDULE OUTAGE
331	14-Jun-2020	PARTS OF K-1 BLK.SEC-1 POOTH KHURD BAWANA	60	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	11:54	14-Jun-2020	13:09	75	0.00083	INTERRUPTION DUE TO FAULTS
332	14-Jun-2020	PARTS OF ROOPALI ENCLAVE KARALA BAWANA	777	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	12:25	14-Jun-2020	14:48	144	0.00040	FORCE MAJEURE DUE TO SABOTAGE
333	14-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	1730	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	08:12	14-Jun-2020	09:00	48	0.00067	INTERRUPTION DUE TO FAULTS
334	14-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	440	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	10:39	14-Jun-2020	11:15	36	0.00020	INTERRUPTION DUE TO FAULTS
335	14-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	1290	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	10:39	14-Jun-2020	12:22	103	0.00115	INTERRUPTION DUE TO FAULTS
336	14-Jun-2020	PARTS OF MBS BAWANA	3479	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	13:11	14-Jun-2020	13:50	39	0.00087	INTERRUPTION DUE TO FAULTS
337	14-Jun-2020	PARTS OF MBS BAWANA	3479	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	18:11	14-Jun-2020	18:50	39	0.00065	INTERRUPTION DUE TO FAULTS
338	14-Jun-2020	PARTS OF DHEERAJ VIHAR, RAJEEV NAGAR EXTN	1044	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	18:03	14-Jun-2020	19:20	77	0.00026	INTERRUPTION DUE TO FAULTS
339	14-Jun-2020	PARTS OF CHANDPUR MAJRA BAWANA	1439	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	19:35	14-Jun-2020	19:50	15	0.00006	INTERRUPTION DUE TO FAULTS
340	14-Jun-2020	PARTS OF PUNJAB KHOD BAWANA	758	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	19:30	14-Jun-2020	20:30	60	0.00025	INTERRUPTION DUE TO FAULTS
341	14-Jun-2020	PARTS OF NEAR COMMUNITY CENTER(AUCHANDI VILLAGE), MUNGESHPUR	80	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	22:01	14-Jun-2020	22:30	29	0.00002	INTERRUPTION DUE TO FAULTS
342	14-Jun-2020	PART OF K-1 BLK.SEC-1. POOTHKHURD BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	10:51	14-Jun-2020	14:25	214	0.00030	FORCE MAJEURE DUE TO SABOTAGE
343	15-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	5	315 kVA	UNPLANNED OUTAGE	15-Jun-2020	14:31	15-Jun-2020	15:35	64	0.00002	SYSTEM SCHEDULE OUTAGE
344	15-Jun-2020	PART OF M BLOCK SEC-3 DSIDC BAWANA	4	160 kVA	UNPLANNED OUTAGE	15-Jun-2020	12:01	15-Jun-2020	12:26	25	0.00001	SYSTEM SCHEDULE OUTAGE
345	15-Jun-2020	PART OF J BLOCKS OF SEC - 4 DSIDC BAWANA	6	315 kVA	UNPLANNED OUTAGE	15-Jun-2020	12:11	15-Jun-2020	12:56	45	0.00001	SYSTEM SCHEDULE OUTAGE
346	15-Jun-2020	PART OF O-BLOCKS OF SEC-2 DSIDC BAWANA	5	315 kVA	UNPLANNED OUTAGE	15-Jun-2020	14:11	15-Jun-2020	14:36	25	0.00001	SYSTEM SCHEDULE OUTAGE
347	15-Jun-2020	PARTS OF KARALA VILLAGE BAWANA	4173	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	08:04	15-Jun-2020	13:06	302	0.00352	PLANNED OUTAGE
348	15-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	1910	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	10:14	15-Jun-2020	15:00	286	0.00159	PLANNED OUTAGE
349	15-Jun-2020	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA LADPUR ROAD MAJRA VILLAGE,JHIMAR PURA VILLAGE,MTNL CHANDPUR,CHANDPUR HARIJAN BASTI BAL KISHAN,BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANJHAWALA SDM COURT KANJHAWALA	521	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	10:13	15-Jun-2020	16:45	392	0.00065	PLANNED OUTAGE
350	15-Jun-2020	PART OF SEC-5 B BLOCK BAWANA	5	400 kVA	PLANNED OUTAGE	15-Jun-2020	10:24	15-Jun-2020	12:01	97	0.00003	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
351	15-Jun-2020	PART OF SEC-5 B BLOCK BAWANA	5	315 kVA	PLANNED OUTAGE	15-Jun-2020	09:58	15-Jun-2020	11:25	87	0.00002	PLANNED OUTAGE
352	15-Jun-2020	PART OF SEC-5 B BLOCK BAWANA	1	160 kVA	PLANNED OUTAGE	15-Jun-2020	13:05	15-Jun-2020	14:30	85	0.00002	PLANNED OUTAGE
353	26-Jun-2020	PART OF G BLOCK SEC-3 POOTHKHURD BAWANA	6	315 kVA	UNPLANNED OUTAGE	26-Jun-2020	13:08	26-Jun-2020	14:30	82	0.00002	SYSTEM SCHEDULE OUTAGE
354	15-Jun-2020	PART OF K BLOCK BAWANA	5	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	13:00	15-Jun-2020	15:54	174	0.00005	FORCE MAJEURE DUE TO SABOTAGE
355	15-Jun-2020	PART OF DE BLOCK SEC-3 DSIDC	6	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	18:16	15-Jun-2020	18:40	24	0.00001	INTERRUPTION DUE TO FAULTS
356	15-Jun-2020	PARTS OF G BLK SEC-1 POOTH KHURD BAWANA	131	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	09:53	15-Jun-2020	10:45	52	0.00022	INTERRUPTION DUE TO FAULTS
357	26-Jun-2020	PARTS OF KANJHAWLA VILLAGE BAWANA	1533	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	09:44	26-Jun-2020	10:07	23	0.00032	INTERRUPTION DUE TO FAULTS
358	15-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	82	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	23:13	16-Jun-2020	00:20	67	0.00004	INTERRUPTION DUE TO FAULTS
359	15-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	3099	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	15:37	15-Jun-2020	16:22	45	0.00088	INTERRUPTION DUE TO FAULTS
360	15-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1362	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	17:07	15-Jun-2020	18:15	68	0.00038	INTERRUPTION DUE TO FAULTS
361	15-Jun-2020	PARTS OF C, G, E BLOCK SEC. - 5 DSIDC BAWANA	280	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	18:31	15-Jun-2020	18:36	6	0.00007	INTERRUPTION DUE TO FAULTS
362	15-Jun-2020	PARTS OF CHANDPUR MAJRA BAWANA	296	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	22:36	15-Jun-2020	23:30	54	0.00012	INTERRUPTION DUE TO FAULTS
363	15-Jun-2020	PART OF RAMA VIHAR KARALA BAWANA	7	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	22:05	16-Jun-2020	00:27	142	0.00008	FORCE MAJEURE DUE TO SABOTAGE
364	16-Jun-2020	PART OF METRO VIHAR HOLAMBI KHURD.	3	400 kVA	PLANNED OUTAGE	16-Jun-2020	12:28	16-Jun-2020	13:56	88	0.00002	PLANNED OUTAGE
365	16-Jun-2020	PART OF SEC-5 B BLOCK BAWANA	4	100 kVA	PLANNED OUTAGE	16-Jun-2020	09:55	16-Jun-2020	12:12	137	0.00004	PLANNED OUTAGE
366	16-Jun-2020	PART OF SEC-5 B BLOCK BAWANA	2	250 kVA	PLANNED OUTAGE	16-Jun-2020	07:34	16-Jun-2020	09:49	135	0.00004	PLANNED OUTAGE
367	16-Jun-2020	PART OF SEC-5 B BLOCK BAWANA	4	315 kVA	PLANNED OUTAGE	16-Jun-2020	09:37	16-Jun-2020	12:05	148	0.00004	PLANNED OUTAGE
368	16-Jun-2020	PARTS OF MAJRI VILLAGE KARALA BAWANA	1407	OTHER OUTAGE	PLANNED OUTAGE	16-Jun-2020	08:04	16-Jun-2020	13:00	296	0.00115	PLANNED OUTAGE
369	16-Jun-2020	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1	95	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	13:58	16-Jun-2020	15:05	67	0.00009	SYSTEM SCHEDULE OUTAGE
370	2-Jun-2020	PARTS OF KANJHAWLA VILLAGE BAWANA	2582	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	18:39	2-Jun-2020	19:00	21	0.00041	INTERRUPTION DUE TO FAULTS
371	3-Jun-2020	PARTS OF KANJHAWLA VILLAGE BAWANA	2582	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	07:36	3-Jun-2020	08:00	24	0.00057	INTERRUPTION DUE TO FAULTS
372	16-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	1068	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	18:51	16-Jun-2020	19:40	49	0.00034	INTERRUPTION DUE TO FAULTS
373	16-Jun-2020	PARTS OF KAMAL KANT JHA TO VIDYA PATI NAGAR	4428	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	07:50	16-Jun-2020	08:25	35	0.00039	INTERRUPTION DUE TO FAULTS
374	16-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	2503	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	10:41	16-Jun-2020	10:55	14	0.00008	INTERRUPTION DUE TO FAULTS
375	16-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	1385	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	10:41	16-Jun-2020	11:03	22	0.00006	INTERRUPTION DUE TO FAULTS
376	16-Jun-2020	PART OF POLICE STATION KHANJHAWLA	10	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	11:13	16-Jun-2020	12:00	47	0.00007	INTERRUPTION DUE TO FAULTS
377	16-Jun-2020	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA LADPUR ROAD MAJRA VILLAGE,JHIMAR PURA VILLAGE,MTNL CHANDPUR,CHANDPUR HARIJAN BASTI BAL KISHAN,BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANJHAWALA SDM COURT KANJHAWALA	511	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	11:24	16-Jun-2020	12:00	36	0.00010	INTERRUPTION DUE TO FAULTS
378	16-Jun-2020	PART OF POLICE STATION KHANJHAWLA	2	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	11:02	16-Jun-2020	13:41	159	0.00004	FORCE MAJEURE DUE TO SABOTAGE
379	16-Jun-2020	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA LADPUR ROAD MAJRA VILLAGE,JHIMAR PURA VILLAGE,MTNL CHANDPUR,CHANDPUR HARIJAN BASTI BAL KISHAN,BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANJHAWALA SDM COURT KANJHAWALA	521	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	05:55	16-Jun-2020	06:50	54	0.00030	INTERRUPTION DUE TO FAULTS
380	16-Jun-2020	PART OF POLICE STATION KHANJHAWLA	3	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	05:55	16-Jun-2020	07:44	109	0.00003	INTERRUPTION DUE TO FAULTS
381	16-Jun-2020	PARTS OF CHANDPUR MAJRA BAWANA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	18:22	16-Jun-2020	18:45	23	0.00013	INTERRUPTION DUE TO FAULTS
382	16-Jun-2020	PARTS OF F & G BLOCK SEC-3 POOTH KHURD BAWANA	314	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	18:24	16-Jun-2020	19:00	36	0.00080	INTERRUPTION DUE TO FAULTS
383	16-Jun-2020	PART OF M BLOCK SEC-3 DSIDC BAWANA	5	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	20:16	16-Jun-2020	21:42	86	0.00005	SYSTEM SCHEDULE OUTAGE
384	16-Jun-2020	PARTS OF MAZRI VILLAGE AND KANJHAWLA VILLAGE	916	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	23:57	17-Jun-2020	01:00	63	0.00021	INTERRUPTION DUE TO FAULTS
385	17-Jun-2020	PART OF M BLOCK SEC-3 DSIDC BAWANA	4	250 kVA	UNPLANNED OUTAGE	17-Jun-2020	11:37	17-Jun-2020	12:01	24	0.00001	SYSTEM SCHEDULE OUTAGE
386	17-Jun-2020	PART OF J BLOCKS OF SEC - 4 DSIDC BAWANA	3	250 kVA	UNPLANNED OUTAGE	17-Jun-2020	12:14	17-Jun-2020	13:12	58	0.00002	SYSTEM SCHEDULE OUTAGE
387	17-Jun-2020	PART OF E BLOCK SEC.-5 DSIDC BAWANA	6	315 kVA	PLANNED OUTAGE	17-Jun-2020	09:56	17-Jun-2020	12:30	154	0.00004	PLANNED OUTAGE
388	17-Jun-2020	PART OF E BLOCK SEC.-5 DSIDC BAWANA	4	315 kVA	PLANNED OUTAGE	17-Jun-2020	08:12	17-Jun-2020	09:30	78	0.00002	PLANNED OUTAGE
389	17-Jun-2020	PARTS OF KANJHAWLA VILLAGE BAWANA	187	OTHER OUTAGE	PLANNED OUTAGE	17-Jun-2020	10:08	17-Jun-2020	15:52	344	0.00019	PLANNED OUTAGE
390	17-Jun-2020	PART OF E BLOCK SEC.-5 DSIDC BAWANA	9	315 kVA	PLANNED OUTAGE	17-Jun-2020	10:10	17-Jun-2020	12:52	162	0.00005	PLANNED OUTAGE
391	17-Jun-2020	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR	221	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	15:51	17-Jun-2020	17:16	85	0.00024	SYSTEM SCHEDULE OUTAGE
392	17-Jun-2020	PARTS OF KARALA VILLAGE BAWANA	200	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	16:27	17-Jun-2020	17:28	61	0.00017	INTERRUPTION DUE TO FAULTS
393	17-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	183	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	00:01	17-Jun-2020	00:45	44	0.00015	INTERRUPTION DUE TO FAULTS
394	17-Jun-2020	PARTS OF KAMAL KANT JHA TO VIDYA PATI NAGAR	4428	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	03:05	17-Jun-2020	03:35	30	0.00042	INTERRUPTION DUE TO FAULTS
395	17-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	202	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	05:23	17-Jun-2020	06:25	62	0.00021	INTERRUPTION DUE TO FAULTS
396	17-Jun-2020	PARTS OF E BLK SEC-1 POOTH KHURD BAEANA	195	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	08:41	17-Jun-2020	09:06	25	0.00040	INTERRUPTION DUE TO FAULTS
397	17-Jun-2020	PART OF POCKET C-1 ESS-8 (DP) SECT-37	13	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	09:30	17-Jun-2020	10:14	44	0.00004	INTERRUPTION DUE TO FAULTS
398	17-Jun-2020	PARTS OF POCKET C-1 ESS-8 (DP) SECT-37	23	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	09:30	17-Jun-2020	10:33	63	0.00007	INTERRUPTION DUE TO FAULTS
399	17-Jun-2020	PARTS OF DHEERAJ VIHAR, RAJEEV NAGAR EXTN	200	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	10:02	17-Jun-2020	11:33	91	0.00025	INTERRUPTION DUE TO FAULTS
400	17-Jun-2020	PARTS OF E BLK SEC-5 POOTH KHURD BAWANA	334	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	12:47	17-Jun-2020	13:18	31	0.00043	INTERRUPTION DUE TO FAULTS
401	17-Jun-2020	PARTS OF CHANDPUR MAJRA BAWANA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	14:59	17-Jun-2020	15:16	17	0.00028	INTERRUPTION DUE TO FAULTS
402	17-Jun-2020	PARTS OF VILL-RANI KHERA,VILL- RASOOL PUR, VILL-MUBARAK PUR, BAGYA VIHAR, MEER VIHAR,YOGI RAJ PURAM & PART OF AGAR NAGER	1230	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	14:55	17-Jun-2020	15:28	33	0.00009	INTERRUPTION DUE TO FAULTS
403	17-Jun-2020	PARTS OF C, G, E BLOCK SEC. - 5 DSIDC BAWANA	280	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	18:02	17-Jun-2020	18:28	26	0.00043	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
404	17-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	822	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	19:07	17-Jun-2020	19:25	18	0.00005	INTERRUPTION DUE TO FAULTS
405	17-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	1741	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	19:07	17-Jun-2020	19:35	28	0.00012	INTERRUPTION DUE TO FAULTS
406	17-Jun-2020	PARTS OF E BLK SEC-5 POOTH KHURD BAWANA	334	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	19:38	17-Jun-2020	20:05	27	0.00060	INTERRUPTION DUE TO FAULTS
407	29-Jun-20	PARTS OF KANJHAWLA VILLAGE BAWANA	2583	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:33	29-Jun-20	18:10	36	0.00086	INTERRUPTION DUE TO FAULTS
408	17-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2218	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	23:46	17-Jun-2020	23:59	12	0.00008	INTERRUPTION DUE TO FAULTS
409	18-Jun-2020	PART OF B BLK SEC-2 POOTHKHURD BAWANA	7	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	10:33	18-Jun-2020	10:58	25	0.00001	INTERRUPTION DUE TO FAULTS
410	18-Jun-2020	PART OF INTERCONNECTOR - 1 POOTHKHURD BAWANA	3	315 kVA	UNPLANNED OUTAGE	18-Jun-2020	13:55	18-Jun-2020	14:18	23	0.00001	SYSTEM SCHEDULE OUTAGE
411	18-Jun-2020	PART OF INTERCONNECTOR - 1 POOTHKHURD BAWANA	6	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	14:07	18-Jun-2020	18:10	243	0.00014	FORCE MAJEURE DUE TO SABOTAGE
412	18-Jun-2020	PART OF K BLOCK SEC-2 POOTH KHURD	6	63 kVA	UNPLANNED OUTAGE	18-Jun-2020	11:37	18-Jun-2020	12:07	30	0.00001	SYSTEM SCHEDULE OUTAGE
413	18-Jun-2020	PART OF E BLOCK SEC.-5 DSIDC BAWANA	7	315 kVA	PLANNED OUTAGE	18-Jun-2020	08:07	18-Jun-2020	09:44	97	0.00003	PLANNED OUTAGE
414	18-Jun-2020	PART OF E BLOCK SEC.-5 DSIDC BAWANA	3	250 kVA	PLANNED OUTAGE	18-Jun-2020	10:04	18-Jun-2020	11:54	110	0.00003	PLANNED OUTAGE
415	3-Jun-2020	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	18:46	3-Jun-2020	19:09	23	0.00051	INTERRUPTION DUE TO FAULTS
416	18-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	582	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	00:53	18-Jun-2020	02:26	93	0.00031	INTERRUPTION DUE TO FAULTS
417	18-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	3244	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	01:56	18-Jun-2020	02:26	30	0.00027	INTERRUPTION DUE TO FAULTS
418	18-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1362	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	10:44	18-Jun-2020	11:08	24	0.00030	SYSTEM SCHEDULE OUTAGE
419	18-Jun-2020	PARTS OF SUBZI MANDI KANJHAWALA ROAD, INDRAJ COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANJHAWALA ROAD	376	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	10:51	18-Jun-2020	11:10	19	0.00006	INTERRUPTION DUE TO FAULTS
420	18-Jun-2020	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADWA DT-2	630	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	13:11	18-Jun-2020	14:30	79	0.00033	INTERRUPTION DUE TO FAULTS
421	18-Jun-2020	PARTS OF MAZRI VILLAGE AND KANJHAWLA VILLAGE	1575	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	02:59	18-Jun-2020	03:30	31	0.00013	INTERRUPTION DUE TO FAULTS
422	7-Jun-2020	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	08:03	7-Jun-2020	08:26	23	0.00012	INTERRUPTION DUE TO FAULTS
423	18-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	3466	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	04:47	18-Jun-2020	05:20	32	0.00031	INTERRUPTION DUE TO FAULTS
424	18-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	670	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	04:47	18-Jun-2020	11:41	413	0.00264	FORCE MAJEURE DUE TO SABOTAGE
425	18-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2146	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	08:27	18-Jun-2020	08:50	23	0.00027	INTERRUPTION DUE TO FAULTS
426	18-Jun-2020	PARTS OF UTSAV VIHAR, RAMA VIHAR BAWANA	2600	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	11:25	18-Jun-2020	12:12	46	0.00064	INTERRUPTION DUE TO FAULTS
427	18-Jun-2020	PARTS OF DIVYA JYOTI APPARTMENT BAWANA	219	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	13:22	18-Jun-2020	13:35	13	0.00004	INTERRUPTION DUE TO FAULTS
428	18-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2218	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	15:48	18-Jun-2020	16:00	12	0.00013	INTERRUPTION DUE TO FAULTS
429	18-Jun-2020	PARTS OF MAJRI VILLAGE KARALA BAWANA	2307	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	19:46	18-Jun-2020	20:15	30	0.00042	INTERRUPTION DUE TO FAULTS
430	18-Jun-2020	PART OF O BLOCK SEC-3 POOTHKHURD BAWANA	7	400 kVA	UNPLANNED OUTAGE	18-Jun-2020	12:51	18-Jun-2020	13:30	39	0.00001	SYSTEM SCHEDULE OUTAGE
431	18-Jun-2020	PART OF VILLAGE KANJHAWLA BAWANA	19	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:42	18-Jun-2020	12:55	13	0.00002	INTERRUPTION DUE TO FAULTS
432	19-Jun-2020	PART OF POOTH VILLAGE BAWANA	2	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	15:53	19-Jun-2020	17:06	73	0.00004	INTERRUPTION DUE TO FAULTS
433	19-Jun-2020	PART OF SEC-5 B BLOCK BAWANA	3	315 kVA	UNPLANNED OUTAGE	19-Jun-2020	12:17	19-Jun-2020	12:43	26	0.00001	SYSTEM SCHEDULE OUTAGE
434	19-Jun-2020	PART OF M BLOCK SEC-3 DSIDC BAWANA	2	160 kVA	UNPLANNED OUTAGE	19-Jun-2020	12:26	19-Jun-2020	12:56	30	0.00001	SYSTEM SCHEDULE OUTAGE
435	19-Jun-2020	PARTS OF POOTH KHURD VILLAGE BAWANA	288	OTHER OUTAGE	PLANNED OUTAGE	19-Jun-2020	10:10	19-Jun-2020	17:45	455	0.00038	PLANNED OUTAGE
436	19-Jun-2020	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	318	OTHER OUTAGE	PLANNED OUTAGE	19-Jun-2020	07:37	19-Jun-2020	10:12	155	0.00013	PLANNED OUTAGE
437	19-Jun-2020	PARTS OF VIDYA PATI NAGAR KARALA BAWANA	2870	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	01:10	19-Jun-2020	02:00	50	0.00039	INTERRUPTION DUE TO FAULTS
438	19-Jun-2020	PARTS OF VIDYA PATI NAGAR KARALA BAWANA	401	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	02:12	19-Jun-2020	03:19	66	0.00022	INTERRUPTION DUE TO FAULTS
439	19-Jun-2020	PARTS OF C,D-BLOCK JJ COLONY BAWANA	2287	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	04:16	19-Jun-2020	05:29	73	0.00047	INTERRUPTION DUE TO FAULTS
440	19-Jun-2020	PARTS OF UTSAV VIHAR, RAMA VIHAR BAWANA	2600	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	09:37	19-Jun-2020	10:23	46	0.00086	INTERRUPTION DUE TO FAULTS
441	19-Jun-2020	PARTS OF SUBZI MANDI KANJHAWALA ROAD, INDRAJ COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANJHAWALA ROAD	3775	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	10:30	19-Jun-2020	10:50	20	0.00047	INTERRUPTION DUE TO FAULTS
442	19-Jun-2020	PARTS OF INTERCONNECTOR 1 & 2 POOTH KHURD BAWANA	225	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	14:51	19-Jun-2020	19:00	248	0.00352	FORCE MAJEURE DUE TO SABOTAGE
443	19-Jun-2020	PARTS OF INTERCONNECTOR 1 & 2 POOTH KHURD BAWANA	279	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	17:32	19-Jun-2020	19:00	88	0.00130	INTERRUPTION DUE TO FAULTS
444	19-Jun-2020	PARTS OF INTERCONNECTOR 1 & 2 POOTH KHURD BAWANA	679	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	17:38	19-Jun-2020	18:25	47	0.00081	INTERRUPTION DUE TO FAULTS
445	19-Jun-2020	PARTS OF MUBARAK PUR VILLAGE, MEER VIHAR & PART OF BHAGYA VIHAR	392	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	22:28	20-Jun-2020	00:27	119	0.00026	INTERRUPTION DUE TO FAULTS
446	19-Jun-2020	PARTS OF MUBARAK PUR VILLAGE, MEER VIHAR & PART OF BHAGYA VIHAR	1708	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	23:38	20-Jun-2020	00:27	49	0.00020	INTERRUPTION DUE TO FAULTS
447	19-Jun-2020	PARTS OF KARALA VILLAGE BAWANA	4321	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	00:50	19-Jun-2020	01:38	48	0.00100	INTERRUPTION DUE TO FAULTS
448	19-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	1365	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	11:55	19-Jun-2020	12:00	5	0.00008	INTERRUPTION DUE TO FAULTS
449	19-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	853	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	11:55	19-Jun-2020	12:54	59	0.00054	INTERRUPTION DUE TO FAULTS
450	7-Jun-2020	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	10:07	7-Jun-2020	11:00	53	0.00074	INTERRUPTION DUE TO FAULTS
451	19-Jun-2020	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADWA DT-2	278	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	13:58	19-Jun-2020	14:50	51	0.00007	INTERRUPTION DUE TO FAULTS
452	19-Jun-2020	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	312	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	15:06	19-Jun-2020	15:32	26	0.00082	INTERRUPTION DUE TO FAULTS
453	19-Jun-2020	PART OF M BLOCK SECTOR-1 POOTHKHURD BAWANA	8	400 kVA	UNPLANNED OUTAGE	19-Jun-2020	11:13	19-Jun-2020	12:08	55	0.00002	SYSTEM SCHEDULE OUTAGE
454	19-Jun-2020	PARTS OF NSC-1 INTERCONNECTOR 3 & 4 POOTH KHURD BAWANA	277	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	16:22	19-Jun-2020	17:06	44	0.00117	INTERRUPTION DUE TO FAULTS
455	20-Jun-2020	PART OF GARTHI RINDHALA BAWANA	4	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	12:50	20-Jun-2020	14:37	107	0.00003	PLANNED OUTAGE
456	20-Jun-2020	PART OF GARTHI RINDHALA BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	15:26	20-Jun-2020	16:23	57	0.00002	INTERRUPTION DUE TO FAULTS
457	20-Jun-2020	PART OF M-BLOCK BHORGARH BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	16:04	20-Jun-2020	17:00	56	0.00002	INTERRUPTION DUE TO FAULTS
458	20-Jun-2020	PART OF I-19 SEC-2 NEAR GOL CHAKKAR.	4	250 kVA	UNPLANNED OUTAGE	20-Jun-2020	12:13	20-Jun-2020	12:42	29	0.00001	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
459	20-Jun-2020	PART OF F BLOCK SEC-4 DSIDC BAWANA	7	315 kVA	UNPLANNED OUTAGE	20-Jun-2020	14:18	20-Jun-2020	14:45	27	0.00001	SYSTEM SCHEDULE OUTAGE
460	20-Jun-2020	PARTS OF L-BLOCK SEC-3 POOTH KHURD BAWANA	206	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	10:26	20-Jun-2020	17:50	443	0.00025	PLANNED OUTAGE
461	20-Jun-2020	PARTS OF FG- 27 SEC-3 POOTH KHURD BAWANA	442	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	10:26	20-Jun-2020	11:06	39	0.00011	PLANNED OUTAGE
462	20-Jun-2020	PART OF J BLOCKS OF SEC - 4 DSIDC BAWANA	3	400 kVA	PLANNED OUTAGE	20-Jun-2020	11:43	20-Jun-2020	16:41	298	0.00008	PLANNED OUTAGE
463	20-Jun-2020	PARTS OF F & G BLOCK SEC-3 POOTH KHURD BAWANA	314	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	10:20	20-Jun-2020	17:34	433	0.00036	PLANNED OUTAGE
464	20-Jun-2020	PARTS OF D-BLOCK SEC-1 POOTH KHURD BAWANA	129	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	10:25	20-Jun-2020	17:50	444	0.00025	PLANNED OUTAGE
465	20-Jun-2020	PART OF F-BLK SEC-2 DSIDC	4	315 kVA	PLANNED OUTAGE	20-Jun-2020	11:21	20-Jun-2020	17:05	344	0.0001	PLANNED OUTAGE
466	20-Jun-2020	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA LADPUR ROAD MAJRA VILLAGE,JHIMAR PURA VILLAGE,MTNL CHANDPUR,CHANDPUR HARIJAN BASTI BAL KISHAN,BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANJHAWALA SDM COURT KANJHAWALA	300	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	12:07	20-Jun-2020	12:35	28	0.00009	INTERRUPTION DUE TO FAULTS
467	20-Jun-2020	PARTS OF BLK-A, B, C, K, L, M BHORGARH	190	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	16:04	20-Jun-2020	17:00	56	0.00019	INTERRUPTION DUE TO FAULTS
468	20-Jun-2020	PARTS OF UTSAV VIHAR, RAMA VIHAR BAWANA	1262	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	16:53	20-Jun-2020	17:20	27	0.00011	INTERRUPTION DUE TO FAULTS
469	30-Jun-20	PART OF I BLK SEC-5 POOTHKHURD BAWANA	2	315 kVA	UNPLANNED OUTAGE	30-Jun-20	14:26	30-Jun-20	15:47	81	0.00002	SYSTEM SCHEDULE OUTAGE
470	20-Jun-2020	PARTS OF A & D BLOCK J J COLONY BAWANA	4292	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:10	20-Jun-2020	05:00	50	0.00111	INTERRUPTION DUE TO FAULTS
471	20-Jun-2020	PARTS OF MBS HOSPITAL BAWANA & DISTRICT OFFICE BAWANA	3239	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:28	20-Jun-2020	04:58	31	0.00127	INTERRUPTION DUE TO FAULTS
472	20-Jun-2020	PARTS OF SUBZI MANDI KANJHAWALA ROAD, INDRAJ COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANJHAWALA ROAD	4714	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:47	20-Jun-2020	04:54	7	0.00010	INTERRUPTION DUE TO FAULTS
473	20-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	1385	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	12:15	20-Jun-2020	12:48	33	0.00012	INTERRUPTION DUE TO FAULTS
474	20-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1059	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	21:15	20-Jun-2020	22:17	62	0.00014	INTERRUPTION DUE TO FAULTS
475	20-Jun-2020	PARTS OF UTSAV VIHAR, RAMA VIHAR BAWANA	243	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	01:54	20-Jun-2020	03:30	96	0.00027	INTERRUPTION DUE TO FAULTS
476	20-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	1725	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:12	20-Jun-2020	04:43	31	0.00043	INTERRUPTION DUE TO FAULTS
477	20-Jun-2020	PARTS OF BLK-A, B, C, K, L, M BHORGARH	194	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:11	20-Jun-2020	04:50	39	0.00022	INTERRUPTION DUE TO FAULTS
478	20-Jun-2020	PARTS OF DHEERAJ VIHAR, RAJEEV NAGAR EXTN	400	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:20	20-Jun-2020	05:43	83	0.00023	INTERRUPTION DUE TO FAULTS
479	20-Jun-2020	PARTS OF CHANDPUR MAJRA BAWANA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	07:32	20-Jun-2020	08:00	28	0.00047	INTERRUPTION DUE TO FAULTS
480	20-Jun-2020	PARTS OF DHEERAJ VIHAR, RAJEEV NAGAR EXTN	1045	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	06:26	20-Jun-2020	08:25	119	0.00050	INTERRUPTION DUE TO FAULTS
481	20-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	8841	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	17:06	20-Jun-2020	18:06	59	0.00144	INTERRUPTION DUE TO FAULTS
482	20-Jun-2020	PARTS OF DTC DEPOT AUCHANDI ROAD BAWANA	1636	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	18:10	20-Jun-2020	18:42	32	0.00014	INTERRUPTION DUE TO FAULTS
483	20-Jun-2020	PART OF O-BLOCK SEC-1 POOTHKHURD BAWANA	6	250 kVA	UNPLANNED OUTAGE	20-Jun-2020	11:21	20-Jun-2020	12:11	50	0.00001	SYSTEM SCHEDULE OUTAGE
484	21-Jun-2020	PARTS OF L-BLOCK SEC-5 POOTH KHURD BAWANA	208	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	03:24	21-Jun-2020	06:45	201	0.00195	FORCE MAJEURE DUE TO SABOTAGE
485	21-Jun-2020	PARTS OF I BLK SEC-1 POOTH KHURD BAWANA	223	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	04:14	21-Jun-2020	06:20	126	0.00193	FORCE MAJEURE DUE TO RAIN/STORM
486	21-Jun-2020	PARTS OF MAJRI VILLAGE KARALA BAWANA	2308	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	07:55	21-Jun-2020	08:26	31	0.00048	INTERRUPTION DUE TO FAULTS
487	21-Jun-2020	PARTS OF J,K,L,M,N,O BLOCKS OF SEC - 2 DSIDC BAWANA	218	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	08:00	21-Jun-2020	08:20	20	0.00020	INTERRUPTION DUE TO FAULTS
488	21-Jun-2020	PARTS OF MBS BAWANA	3479	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	08:02	21-Jun-2020	08:40	38	0.00090	INTERRUPTION DUE TO FAULTS
489	21-Jun-2020	PARTS OF I BLK SEC-1 POOTH KHURD BAWANA	223	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	10:53	21-Jun-2020	11:30	37	0.00010	INTERRUPTION DUE TO FAULTS
490	21-Jun-2020	PARTS OF MBS BAWANA	3479	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	11:11	21-Jun-2020	11:45	34	0.00071	INTERRUPTION DUE TO FAULTS
491	8-Jun-2020	PART OF I BLK SEC-5 POOTHKHURD BAWANA	3	160 kVA	UNPLANNED OUTAGE	8-Jun-2020	14:41	8-Jun-2020	15:27	46	0.00001	SYSTEM SCHEDULE OUTAGE
492	21-Jun-2020	PARTS OF MBS BAWANA	358	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	15:16	21-Jun-2020	15:40	24	0.00003	SYSTEM SCHEDULE OUTAGE
493	21-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	358	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	00:22	21-Jun-2020	01:00	38	0.00011	INTERRUPTION DUE TO FAULTS
494	21-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	358	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	05:10	21-Jun-2020	05:50	39	0.00017	INTERRUPTION DUE TO FAULTS
495	21-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	358	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	07:51	21-Jun-2020	08:30	39	0.00008	INTERRUPTION DUE TO FAULTS
496	21-Jun-2020	PARTS OF DE BLOCK SEC-3 POOTH KHURD BAWANA	158	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	09:04	21-Jun-2020	09:40	36	0.00005	INTERRUPTION DUE TO FAULTS
497	21-Jun-2020	PARTS OF J,K,L,M,N,O BLOCKS OF SEC - 2 DSIDC BAWANA	218	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	09:02	21-Jun-2020	09:40	38	0.00074	INTERRUPTION DUE TO FAULTS
498	21-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	2732	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	13:44	21-Jun-2020	14:05	21	0.00018	INTERRUPTION DUE TO FAULTS
499	21-Jun-2020	PARTS OF AGAR NAGAR KARALA BAWANA	11926	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	15:08	21-Jun-2020	15:45	37	0.00207	INTERRUPTION DUE TO FAULTS
500	21-Jun-2020	PART OF VILLAGE KANJHAWLA BAWANA	2	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	18:25	21-Jun-2020	18:44	19	0.00001	INTERRUPTION DUE TO FAULTS
501	22-Jun-2020	PART OF RANI KHERA BAWANA	6	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	10:10	22-Jun-2020	13:42	212	0.00012	FORCE MAJEURE DUE TO SABOTAGE
502	22-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1072	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	12:36	22-Jun-2020	13:45	69	0.00023	INTERRUPTION DUE TO FAULTS
503	10-Jun-2020	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:43	10-Jun-2020	17:13	30	0.00013	INTERRUPTION DUE TO FAULTS
504	22-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2590	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	02:17	22-Jun-2020	02:50	33	0.00060	INTERRUPTION DUE TO FAULTS
505	22-Jun-2020	PARTS OF UTSAV VIHAR, RAMA VIHAR BAWANA	2600	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:34	22-Jun-2020	06:59	84	0.00152	INTERRUPTION DUE TO FAULTS
506	22-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1915	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:40	22-Jun-2020	07:30	110	0.00098	INTERRUPTION DUE TO FAULTS
507	22-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1115	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:40	22-Jun-2020	08:20	160	0.00098	FORCE MAJEURE DUE TO RAIN/STORM
508	22-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1109	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:40	22-Jun-2020	10:41	301	0.00092	FORCE MAJEURE DUE TO RAIN/STORM
509	13-Jun-2020	PART OF I BLK SEC-5 POOTHKHURD BAWANA	9	400 kVA	UNPLANNED OUTAGE	13-Jun-2020	12:43	13-Jun-2020	13:41	58	0.00002	SYSTEM SCHEDULE OUTAGE
510	22-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	670	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	10:00	22-Jun-2020	10:41	41	0.00009	INTERRUPTION DUE TO FAULTS
511	17-Jun-2020	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	23:03	17-Jun-2020	23:22	19	0.00009	INTERRUPTION DUE TO FAULTS
512	18-Jun-2020	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	04:32	18-Jun-2020	04:50	18	0.00009	INTERRUPTION DUE TO FAULTS
513	19-Jun-2020	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	12:27	19-Jun-2020	12:45	18	0.00062	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
514	29-Jun-20	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:44	29-Jun-20	18:30	46	0.00077	INTERRUPTION DUE TO FAULTS
515	22-Jun-2020	PARTS OF A,F BLK SEC-2 DSIDC BAWANA	296	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	16:06	22-Jun-2020	16:20	14	0.00011	INTERRUPTION DUE TO FAULTS
516	22-Jun-2020	PARTS OF MBS HOSPITAL BAWANA & DISTRICT OFFICE BAWANA	2861	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	22:02	22-Jun-2020	22:20	18	0.00035	INTERRUPTION DUE TO FAULTS
517	22-Jun-2020	PARTS OF N,O & P BLOCKS OF SEC. - 1 DSIDC BAWANA	248	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	00:20	22-Jun-2020	02:20	120	0.00150	INTERRUPTION DUE TO FAULTS
518	22-Jun-2020	PARTS OF MBS HOSPITAL BAWANA & DISTRICT OFFICE BAWANA	3045	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:12	22-Jun-2020	06:26	74	0.00227	INTERRUPTION DUE TO FAULTS
519	22-Jun-2020	PARTS OF FG- 27 SEC-3 POOTH KHURD BAWANA	442	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	08:50	22-Jun-2020	09:10	20	0.00036	INTERRUPTION DUE TO FAULTS
520	22-Jun-2020	PARTS OF DE BLOCK SEC-3 POOTH KHURD BAWANA	158	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	09:21	22-Jun-2020	10:25	64	0.00021	INTERRUPTION DUE TO FAULTS
521	22-Jun-2020	PARTS OF MAZRI VILLAGE AND KANJHAWLA VILLAGE	1674	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	10:34	22-Jun-2020	11:54	80	0.00036	INTERRUPTION DUE TO FAULTS
522	22-Jun-2020	PARTS OF MAZRI VILLAGE AND KANJHAWLA VILLAGE	757	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	11:58	22-Jun-2020	12:33	35	0.00008	INTERRUPTION DUE TO FAULTS
523	22-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	650	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	10:04	22-Jun-2020	11:40	96	0.00032	INTERRUPTION DUE TO FAULTS
524	22-Jun-2020	PARTS OF C,D-BLOCK JJ COLONY BAWANA	2287	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	11:06	22-Jun-2020	12:00	54	0.00033	INTERRUPTION DUE TO FAULTS
525	29-Jun-20	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	19:21	29-Jun-20	20:20	59	0.00074	INTERRUPTION DUE TO FAULTS
526	29-Jun-20	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	07:10	29-Jun-20	07:31	21	0.00009	INTERRUPTION DUE TO FAULTS
527	24-Jun-2020	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	20:35	24-Jun-2020	21:00	25	0.00012	INTERRUPTION DUE TO FAULTS
528	18-Jun-2020	PART OF I BLK SEC-5 POOTHKHURD BAWANA	3	160 kVA	UNPLANNED OUTAGE	18-Jun-2020	13:52	18-Jun-2020	14:14	22	0.00001	SYSTEM SCHEDULE OUTAGE
529	22-Jun-2020	PART OF F BLOCK SEC-4 DSIDC BAWANA	10	400 kVA	UNPLANNED OUTAGE	22-Jun-2020	12:01	22-Jun-2020	12:28	27	0.00001	SYSTEM SCHEDULE OUTAGE
530	22-Jun-2020	PART OF F BLOCK SEC-4 DSIDC BAWANA	3	160 kVA	UNPLANNED OUTAGE	22-Jun-2020	12:32	22-Jun-2020	13:30	58	0.00002	SYSTEM SCHEDULE OUTAGE
531	22-Jun-2020	PART OF H BLOCKS OF SEC - 2 DSIDC BAWANA	3	315 kVA	UNPLANNED OUTAGE	22-Jun-2020	15:03	22-Jun-2020	15:48	45	0.00001	SYSTEM SCHEDULE OUTAGE
532	22-Jun-2020	PARTS OF NEAR COMMUNITY CENTER(AUCHANDI VILLAGE), MUNGESHPUR	1208	OTHER OUTAGE	PLANNED OUTAGE	22-Jun-2020	10:13	22-Jun-2020	12:25	132	0.00044	PLANNED OUTAGE
533	22-Jun-2020	PARTS OF INTERCONNECTOR - 1 & 2 AND POOTH VILLAGE	329	OTHER OUTAGE	PLANNED OUTAGE	22-Jun-2020	07:30	22-Jun-2020	10:02	152	0.00017	PLANNED OUTAGE
534	18-Jun-2020	PART OF I BLK SEC-5 POOTHKHURD BAWANA	3	315 kVA	UNPLANNED OUTAGE	18-Jun-2020	15:09	18-Jun-2020	15:36	27	0.00001	SYSTEM SCHEDULE OUTAGE
535	22-Jun-2020	PARTS OF NSC-1 INTERCONNECTOR 3 & 4 POOTH KHURD BAWANA	504	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	12:05	22-Jun-2020	15:00	175	0.00058	FORCE MAJEURE DUE TO SABOTAGE
536	29-Jun-20	PART OF INTERCONNECTOR - 3 POOTHKHURD BAWANA	4	400 kVA	UNPLANNED OUTAGE	29-Jun-20	11:25	29-Jun-20	13:00	95	0.00003	SYSTEM SCHEDULE OUTAGE
537	23-Jun-2020	PART OF POOTH VILLAGE BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	11:14	23-Jun-2020	11:30	16	0.000004	INTERRUPTION DUE TO FAULTS
538	23-Jun-2020	PART OF J BLOCK SEC - 2 POOTHKHURD BAWANA	5	160 kVA	UNPLANNED OUTAGE	23-Jun-2020	11:47	23-Jun-2020	12:11	24	0.00001	SYSTEM SCHEDULE OUTAGE
539	23-Jun-2020	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR	359	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	00:06	23-Jun-2020	01:50	104	0.00009	SYSTEM SCHEDULE OUTAGE
540	23-Jun-2020	PARTS OF KARALA & PASHU AUSHADHALAYA BAWANA	136	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	10:48	23-Jun-2020	12:36	108	0.00036	INTERRUPTION DUE TO FAULTS
541	23-Jun-2020	PARTS OF KARALA & PASHU AUSHADHALAYA BAWANA	3696	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	12:15	23-Jun-2020	12:36	21	0.00025	INTERRUPTION DUE TO FAULTS
542	4-Jun-2020	PART OF INTERCONNECTOR - 3 POOTHKHURD BAWANA	4	315 kVA	PLANNED OUTAGE	4-Jun-2020	14:37	4-Jun-2020	16:17	100	0.00003	PLANNED OUTAGE
543	23-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1072	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	21:37	23-Jun-2020	22:02	25	0.00013	INTERRUPTION DUE TO FAULTS
544	23-Jun-2020	PARTS OF DIVYA JYOTI APPARTMENT BAWANA	226	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	22:31	23-Jun-2020	22:55	24	0.00008	INTERRUPTION DUE TO FAULTS
545	23-Jun-2020	PARTS OF MAZRI VILLAGE AND KANJHAWLA VILLAGE	757	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	15:03	23-Jun-2020	15:38	35	0.00012	INTERRUPTION DUE TO FAULTS
546	23-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	8841	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	06:35	23-Jun-2020	07:00	25	0.00056	INTERRUPTION DUE TO FAULTS
547	23-Jun-2020	PARTS OF KARALA & PASHU AUSHADHALAYA BAWANA	3832	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	06:48	23-Jun-2020	07:45	57	0.00079	INTERRUPTION DUE TO FAULTS
548	23-Jun-2020	PARTS OF MBS BAWANA	3479	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	07:00	23-Jun-2020	07:28	28	0.00039	INTERRUPTION DUE TO FAULTS
549	23-Jun-2020	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	1463	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	08:22	23-Jun-2020	08:40	18	0.00010	INTERRUPTION DUE TO FAULTS
550	23-Jun-2020	PARTS OF POOTH KHURD VILLAGE BAWANA	386	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	09:41	23-Jun-2020	10:05	24	0.00010	INTERRUPTION DUE TO FAULTS
551	23-Jun-2020	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	262	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	09:52	23-Jun-2020	12:30	158	0.00430	FORCE MAJEURE DUE TO SABOTAGE
552	23-Jun-2020	PARTS OF AGAR NAGAR AND PREM NAGAR III	762	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	07:55	23-Jun-2020	09:40	105	0.00044	INTERRUPTION DUE TO FAULTS
553	23-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	3781	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	12:00	23-Jun-2020	12:10	10	0.00011	INTERRUPTION DUE TO FAULTS
554	23-Jun-2020	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	262	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	14:52	23-Jun-2020	16:24	91	0.00064	INTERRUPTION DUE TO FAULTS
555	23-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1362	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	17:05	23-Jun-2020	17:40	35	0.00013	INTERRUPTION DUE TO FAULTS
556	23-Jun-2020	PARTS OF POOTH KHURD VILLAGE BAWANA	98	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	17:14	23-Jun-2020	17:46	32	0.00007	INTERRUPTION DUE TO FAULTS
557	23-Jun-2020	PARTS OF POOTH KHURD VILLAGE BAWANA	288	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	17:14	23-Jun-2020	17:52	38	0.00015	INTERRUPTION DUE TO FAULTS
558	25-Jun-2020	PARTS OF LADPUR VILLAGE KANJHAWALA BAWANA	1618	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	13:57	25-Jun-2020	14:18	21	0.00041	INTERRUPTION DUE TO FAULTS
559	4-Jun-2020	PART OF INTERCONNECTOR - 3 POOTHKHURD BAWANA	8	315 kVA	PLANNED OUTAGE	4-Jun-2020	14:29	4-Jun-2020	16:29	120	0.00003	PLANNED OUTAGE
560	23-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	3915	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	19:48	23-Jun-2020	20:03	14	0.00015	INTERRUPTION DUE TO FAULTS
561	23-Jun-2020	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	4	63 kVA	UNPLANNED OUTAGE	23-Jun-2020	12:38	23-Jun-2020	13:33	55	0.00002	SYSTEM SCHEDULE OUTAGE
562	23-Jun-2020	PART OF HI BLOCK SEC 5 DSIIDC BAWANA	7	250 kVA	UNPLANNED OUTAGE	23-Jun-2020	12:47	23-Jun-2020	13:28	41	0.00001	SYSTEM SCHEDULE OUTAGE
563	23-Jun-2020	PART OF O-BLOCK SEC-1 POOTH KHURD	3	315 kVA	UNPLANNED OUTAGE	23-Jun-2020	15:52	23-Jun-2020	16:34	42	0.00001	SYSTEM SCHEDULE OUTAGE
564	4-Jun-2020	PART OF INTERCONNECTOR - 3 POOTHKHURD BAWANA	5	315 kVA	PLANNED OUTAGE	4-Jun-2020	14:32	4-Jun-2020	16:53	141	0.00004	PLANNED OUTAGE
565	23-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	2031	OTHER OUTAGE	PLANNED OUTAGE	23-Jun-2020	08:19	23-Jun-2020	13:10	291	0.00162	PLANNED OUTAGE
566	23-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	1367	OTHER OUTAGE	PLANNED OUTAGE	23-Jun-2020	10:25	23-Jun-2020	14:30	245	0.00095	PLANNED OUTAGE
567	24-Jun-2020	PART OF B BLK SEC-2 POOTHKHURD BAWANA	3	250 kVA	PLANNED OUTAGE	24-Jun-2020	08:34	24-Jun-2020	11:44	190	0.00005	PLANNED OUTAGE
568	24-Jun-2020	PART OF L BLOCK SEC-3 POOTHKHURD BAWANA	4	315 kVA	UNPLANNED OUTAGE	24-Jun-2020	15:48	24-Jun-2020	16:00	12	0.000003	SYSTEM SCHEDULE OUTAGE
569	24-Jun-2020	PART OF M BLOCK SECTOR-1 POOTHKHURD BAWANA	3	250 kVA	UNPLANNED OUTAGE	24-Jun-2020	14:16	24-Jun-2020	14:50	34	0.00001	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
570	24-Jun-2020	PARTS OF AGAR NAGAR KARALA BAWANA	3085	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	10:44	24-Jun-2020	11:23	39	0.00033	INTERRUPTION DUE TO FAULTS
571	24-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	3102	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	07:25	24-Jun-2020	08:09	44	0.00049	INTERRUPTION DUE TO FAULTS
572	24-Jun-2020	PART OF HI BLOCK SEC 5 DSIIDC BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	11:48	24-Jun-2020	12:30	42	0.00001	INTERRUPTION DUE TO FAULTS
573	24-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1095	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	14:06	24-Jun-2020	14:39	33	0.00014	INTERRUPTION DUE TO FAULTS
574	24-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	24	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	13:39	24-Jun-2020	15:35	116	0.00016	INTERRUPTION DUE TO FAULTS
575	24-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	497	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	15:05	24-Jun-2020	15:35	30	0.00013	INTERRUPTION DUE TO FAULTS
576	24-Jun-2020	PART OF POLICE STATION KHANJHAWLA	4	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	16:37	24-Jun-2020	18:07	90	0.00005	SYSTEM SCHEDULE OUTAGE
577	24-Jun-2020	PARTS OF A, D, E, F, G, H, BLOCKS OF SEC - 2 DSIDC BAWANA	311	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	18:34	24-Jun-2020	19:09	35	0.00012	INTERRUPTION DUE TO FAULTS
578	24-Jun-2020	PARTS OF BLK-B,C,H,I,J,K & N SEC-5 BAWANA	333	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	20:24	24-Jun-2020	20:58	34	0.00014	INTERRUPTION DUE TO FAULTS
579	24-Jun-2020	PARTS OF LM BLOCK SEC-1 POOTH KHURD BAWANA	237	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	00:00	24-Jun-2020	00:30	30	0.00025	INTERRUPTION DUE TO FAULTS
580	24-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	2734	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	06:34	24-Jun-2020	07:00	26	0.00011	INTERRUPTION DUE TO FAULTS
581	24-Jun-2020	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1	2988	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	11:03	24-Jun-2020	11:25	22	0.00018	INTERRUPTION DUE TO FAULTS
582	24-Jun-2020	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	1463	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	11:38	24-Jun-2020	12:10	32	0.00013	INTERRUPTION DUE TO FAULTS
583	24-Jun-2020	PARTS OF KARALA VILLAGE BAWANA	4323	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	11:43	24-Jun-2020	12:26	43	0.00053	INTERRUPTION DUE TO FAULTS
584	24-Jun-2020	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1	236	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	13:10	24-Jun-2020	14:25	75	0.00025	INTERRUPTION DUE TO FAULTS
585	24-Jun-2020	PARTS OF MUBARAK PUR VILLAGE, MEER VIHAR & PART OF BHAGYA VIHAR	2101	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	15:14	24-Jun-2020	15:49	35	0.00020	INTERRUPTION DUE TO FAULTS
586	24-Jun-2020	PARTS OF D-BLK SEC-4 POOTH KHURD BAWANA	175	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	16:26	24-Jun-2020	16:40	14	0.00005	INTERRUPTION DUE TO FAULTS
587	24-Jun-2020	PARTS OF MBS BAWANA	3480	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	17:58	24-Jun-2020	18:15	17	0.00016	INTERRUPTION DUE TO FAULTS
588	24-Jun-2020	PART OF L-BLOCK SEC-3 POOTH KHURD	8	315 kVA	UNPLANNED OUTAGE	24-Jun-2020	11:34	24-Jun-2020	12:30	56	0.00002	SYSTEM SCHEDULE OUTAGE
589	24-Jun-2020	PART OF K BLOCK BAWANA	4	315 kVA	UNPLANNED OUTAGE	24-Jun-2020	12:13	24-Jun-2020	12:34	21	0.00001	SYSTEM SCHEDULE OUTAGE
590	24-Jun-2020	PART OF BWN INTERCONNECTOR-1	4	315 kVA	UNPLANNED OUTAGE	24-Jun-2020	13:02	24-Jun-2020	13:59	57	0.00002	SYSTEM SCHEDULE OUTAGE
591	24-Jun-2020	PART OF K BLOCK SEC-2 POOTH KHURD	4	315 kVA	UNPLANNED OUTAGE	24-Jun-2020	14:55	24-Jun-2020	15:47	52	0.00001	SYSTEM SCHEDULE OUTAGE
592	3-Jun-2020	PARTS OF LM BLOCK SEC-1 DSIDC POOTH KHURD BAWANA	235	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	11:59	3-Jun-2020	12:37	38	0.00011	INTERRUPTION DUE TO FAULTS
593	24-Jun-2020	PARTS OF KARALA WATER SUPPLY AND PART OF BAWANA	918	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	08:18	24-Jun-2020	13:10	292	0.00073	PLANNED OUTAGE
594	24-Jun-2020	PARTS OF C, G, E BLOCK SEC. - 5 DSIDC BAWANA	280	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	07:21	24-Jun-2020	09:50	148	0.00012	PLANNED OUTAGE
595	24-Jun-2020	PART OF K BLOCK SEC-2 POOTH KHURD	6	63 kVA	PLANNED OUTAGE	24-Jun-2020	08:07	24-Jun-2020	10:35	148	0.00004	PLANNED OUTAGE
596	25-Jun-2020	PART OF C BLK SEC-02 POOTHKHURD BAWANA	7	315 kVA	UNPLANNED OUTAGE	25-Jun-2020	11:44	25-Jun-2020	12:29	45	0.00001	SYSTEM SCHEDULE OUTAGE
597	27-Jun-2020	PART OF RAW WATER WITH T-OFFS BAWANA	2	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	00:39	27-Jun-2020	02:32	113	0.00063	INTERRUPTION DUE TO FAULTS
598	25-Jun-2020	PART OF INTERCONNECTOR - 1 POOTHKHURD BAWANA	6	400 kVA	UNPLANNED OUTAGE	25-Jun-2020	11:49	25-Jun-2020	12:39	50	0.00001	SYSTEM SCHEDULE OUTAGE
599	25-Jun-2020	PARTS OF CHANPUR MAJRA KANJHAWALA BAWANA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	09:20	25-Jun-2020	09:48	28	0.00062	INTERRUPTION DUE TO FAULTS
600	25-Jun-2020	PARTS OF CHANPUR MAJRA KANJHAWALA BAWANA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	10:23	25-Jun-2020	10:34	11	0.00024	INTERRUPTION DUE TO FAULTS
601	25-Jun-2020	PARTS OF VIDYA PATI NAGAR KARALA BAWANA	2257	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	15:40	25-Jun-2020	16:05	25	0.00021	SYSTEM SCHEDULE OUTAGE
602	25-Jun-2020	PART OF BWN INTERCONNECTOR-1	2	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	12:33	25-Jun-2020	18:00	327	0.00009	FORCE MAJEURE DUE TO SABOTAGE
603	25-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	47	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	15:35	25-Jun-2020	17:40	125	0.00017	FORCE MAJEURE DUE TO SABOTAGE
604	25-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	1535	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	16:58	25-Jun-2020	17:40	42	0.00018	INTERRUPTION DUE TO FAULTS
605	25-Jun-2020	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADWA DT-2	66	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	17:00	25-Jun-2020	17:54	54	0.00012	INTERRUPTION DUE TO FAULTS
606	25-Jun-2020	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADWA DT-2	2499	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	17:12	25-Jun-2020	17:54	42	0.00035	INTERRUPTION DUE TO FAULTS
607	25-Jun-2020	PARTS OF MBS BAWANA	85	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	22:02	25-Jun-2020	22:45	43	0.00014	INTERRUPTION DUE TO FAULTS
608	25-Jun-2020	PARTS OF JOHAR WALA, INDIAN OIL CORPORATION LTD, MCD PARK, M.B. HOSPITAL NO-1	2988	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	06:38	25-Jun-2020	07:20	42	0.00058	INTERRUPTION DUE TO FAULTS
609	25-Jun-2020	PARTS OF MBS BAWANA	3480	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	12:40	25-Jun-2020	13:03	23	0.00051	INTERRUPTION DUE TO FAULTS
610	25-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	1912	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	13:31	25-Jun-2020	14:10	39	0.00017	INTERRUPTION DUE TO FAULTS
611	25-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2590	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	13:49	25-Jun-2020	14:30	41	0.00068	INTERRUPTION DUE TO FAULTS
612	25-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA, DTS OF LADPUR-NIZAM PUR ROAD	1729	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	13:56	25-Jun-2020	14:25	29	0.00052	INTERRUPTION DUE TO FAULTS
613	25-Jun-2020	PARTS OF DTC DEPOT AUCHANDI ROAD BAWANA	1820	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:11	25-Jun-2020	14:40	29	0.00040	INTERRUPTION DUE TO FAULTS
614	25-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	1582	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:26	25-Jun-2020	15:10	44	0.00037	INTERRUPTION DUE TO FAULTS
615	25-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	1582	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	17:55	25-Jun-2020	18:10	15	0.00006	INTERRUPTION DUE TO FAULTS
616	25-Jun-2020	PART OF F BLOCK SEC-4 DSIDC BAWANA	5	250 kVA	UNPLANNED OUTAGE	25-Jun-2020	11:11	25-Jun-2020	12:06	55	0.00002	SYSTEM SCHEDULE OUTAGE
617	25-Jun-2020	PART OF F-BLK SEC-2 DSIDC	2	315 kVA	UNPLANNED OUTAGE	25-Jun-2020	12:42	25-Jun-2020	13:08	26	0.00001	SYSTEM SCHEDULE OUTAGE
618	25-Jun-2020	PART OF DE BLOCK SEC-3 DSIDC	6	250 kVA	UNPLANNED OUTAGE	25-Jun-2020	12:59	25-Jun-2020	14:08	69	0.00002	SYSTEM SCHEDULE OUTAGE
619	25-Jun-2020	PART OF K BLOCK SEC-2 POOTH KHURD	4	315 kVA	UNPLANNED OUTAGE	25-Jun-2020	14:12	25-Jun-2020	14:55	43	0.00001	SYSTEM SCHEDULE OUTAGE
620	26-Jun-2020	PART OF JYONTI VILLAGE BAWANA	14	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	11:45	26-Jun-2020	12:24	39	0.00004	INTERRUPTION DUE TO FAULTS
621	26-Jun-2020	PART OF JYONTI VILLAGE BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	13:23	26-Jun-2020	14:20	57	0.00003	INTERRUPTION DUE TO FAULTS
622	26-Jun-2020	PART OF D BLK SEC-5 POOTHKHURD BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	12:45	26-Jun-2020	16:11	206	0.00011	FORCE MAJEURE DUE TO SABOTAGE
623	26-Jun-2020	PART OF E BLK SEC-1 POOTHKHURD BAWANA	7	315 kVA	UNPLANNED OUTAGE	26-Jun-2020	14:41	26-Jun-2020	15:29	48	0.00003	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
624	26-Jun-2020	PART OF E BLK SEC-5 POOTHKHURD BAWANA	2	63 kVA	UNPLANNED OUTAGE	26-Jun-2020	12:01	26-Jun-2020	12:39	38	0.00001	SYSTEM SCHEDULE OUTAGE
625	26-Jun-2020	PART OF INTERCONNECTOR - 1 POOTHKHURD BAWANA	2	160 kVA	UNPLANNED OUTAGE	26-Jun-2020	12:51	26-Jun-2020	13:30	39	0.00001	SYSTEM SCHEDULE OUTAGE
626	26-Jun-2020	PARTS OF JYONTI VILLAGE KANJHAWALA BAWANA	40	OTHER OUTAGE	PLANNED OUTAGE	26-Jun-2020	10:45	26-Jun-2020	17:20	395	0.00011	PLANNED OUTAGE
627	26-Jun-2020	PARTS OF POOTH KHURD VILLAGE BAWANA	1629	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	09:24	26-Jun-2020	09:31	7	0.00010	SYSTEM SCHEDULE OUTAGE
628	26-Jun-2020	PARTS OF POOTH KHURD VILLAGE BAWANA	1629	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	14:13	26-Jun-2020	16:33	140	0.00194	FORCE MAJEURE DUE TO SABOTAGE
629	26-Jun-2020	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADWA DT-2	2733	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	06:36	26-Jun-2020	07:10	34	0.00047	INTERRUPTION DUE TO FAULTS
630	26-Jun-2020	PARTS OF SUBZI MANDI KANJHAWALA ROAD, INDRAJ COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANJHAWALA ROAD	1172	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	02:06	26-Jun-2020	02:30	24	0.00008	INTERRUPTION DUE TO FAULTS
631	26-Jun-2020	PARTS OF MBS BAWANA	84	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	10:06	26-Jun-2020	11:00	54	0.00012	INTERRUPTION DUE TO FAULTS
632	26-Jun-2020	PARTS OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	349	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	11:08	26-Jun-2020	12:00	52	0.00087	INTERRUPTION DUE TO FAULTS
633	26-Jun-2020	PARTS OF D-BLK SEC-4 POOTH KHURD BAWANA	175	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	16:11	26-Jun-2020	17:10	59	0.00082	INTERRUPTION DUE TO FAULTS
634	26-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	3915	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	18:21	26-Jun-2020	18:45	24	0.00067	INTERRUPTION DUE TO FAULTS
635	26-Jun-2020	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	262	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	20:03	26-Jun-2020	21:00	56	0.00141	INTERRUPTION DUE TO FAULTS
636	26-Jun-2020	PARTS OF JAIN NAGAR HVDS & SUKHBIR NAGAR HVDS	1081	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	20:06	26-Jun-2020	20:42	36	0.00015	INTERRUPTION DUE TO FAULTS
637	26-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	3105	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	22:33	26-Jun-2020	23:08	34	0.00048	INTERRUPTION DUE TO FAULTS
638	26-Jun-2020	PART OF L-BLOCK SEC-3 POOTH KHURD	11	400 kVA	UNPLANNED OUTAGE	26-Jun-2020	11:15	26-Jun-2020	12:09	54	0.00002	SYSTEM SCHEDULE OUTAGE
639	26-Jun-2020	PART OF B-BLOCK SEC-3 POOTH KHURD	5	160 kVA	UNPLANNED OUTAGE	26-Jun-2020	15:05	26-Jun-2020	15:47	42	0.00001	SYSTEM SCHEDULE OUTAGE
640	26-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	1378	OTHER OUTAGE	PLANNED OUTAGE	26-Jun-2020	15:40	26-Jun-2020	17:20	100	0.00036	PLANNED OUTAGE
641	27-Jun-2020	PART OF GANGA TOLI ROAD BAWANA	4	250 kVA	UNPLANNED OUTAGE	27-Jun-2020	12:32	27-Jun-2020	13:54	82	0.00002	SYSTEM SCHEDULE OUTAGE
642	27-Jun-2020	PART OF JYONTI VILLAGE BAWANA	10	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	12:07	27-Jun-2020	13:00	53	0.00002	INTERRUPTION DUE TO FAULTS
643	27-Jun-2020	PART OF JYONTI VILLAGE BAWANA	18	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	22:26	27-Jun-2020	23:40	74	0.00004	INTERRUPTION DUE TO FAULTS
644	27-Jun-2020	PART OF G BLOCK POOTHKHURD BAWANA	6	400 kVA	UNPLANNED OUTAGE	27-Jun-2020	12:57	27-Jun-2020	13:57	60	0.00002	SYSTEM SCHEDULE OUTAGE
645	27-Jun-2020	PART OF I BLK SEC-1 POOTHKHURD BAWANA	8	315 kVA	UNPLANNED OUTAGE	27-Jun-2020	15:37	27-Jun-2020	16:22	45	0.00001	SYSTEM SCHEDULE OUTAGE
646	27-Jun-2020	PART OF LM BLOCK SEC-1 POOTHKHURD BAWANA	4	315 kVA	UNPLANNED OUTAGE	27-Jun-2020	13:00	27-Jun-2020	14:23	83	0.00002	SYSTEM SCHEDULE OUTAGE
647	27-Jun-2020	PART OF M BLOCK SECTOR-1 POOTHKHURD BAWANA	8	160 kVA	UNPLANNED OUTAGE	27-Jun-2020	16:25	27-Jun-2020	17:12	47	0.00001	SYSTEM SCHEDULE OUTAGE
648	27-Jun-2020	PARTS OF CHANPUR MAJRA KANJHAWALA BAWANA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	10:17	27-Jun-2020	10:30	13	0.00018	INTERRUPTION DUE TO FAULTS
649	27-Jun-2020	PARTS OF CHANPUR MAJRA KANJHAWALA BAWANA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	10:54	27-Jun-2020	11:30	36	0.00060	INTERRUPTION DUE TO FAULTS
650	27-Jun-2020	PARTS OF JYONTI VILLAGE KANJHAWALA BAWANA	1367	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	23:05	27-Jun-2020	23:40	35	0.00029	INTERRUPTION DUE TO FAULTS
651	27-Jun-2020	PARTS OF E BLK SEC-5 POOTH KHURD BAWANA	334	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	00:35	27-Jun-2020	02:32	117	0.00130	INTERRUPTION DUE TO FAULTS
652	27-Jun-2020	PARTS OF E BLK SEC-5 POOTH KHURD BAWANA	323	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	00:36	27-Jun-2020	02:29	113	0.00126	INTERRUPTION DUE TO FAULTS
653	27-Jun-2020	PARTS OF DJB RAW WATER PUMP HOUSE POOTH KHURD BAWANA	333	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	01:02	27-Jun-2020	02:03	61	0.00034	INTERRUPTION DUE TO FAULTS
654	27-Jun-2020	PARTS OF DJB RAW WATER PUMP HOUSE POOTH KHURD BAWANA	261	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	01:15	27-Jun-2020	01:57	42	0.00023	INTERRUPTION DUE TO FAULTS
655	27-Jun-2020	PARTS OF DJB RAW WATER PUMP HOUSE POOTH KHURD BAWANA	300	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	02:36	27-Jun-2020	03:31	56	0.00031	INTERRUPTION DUE TO FAULTS
656	27-Jun-2020	PARTS OF F & G BLOCK SEC-3 POOTH KHURD BAWANA	270	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	02:38	27-Jun-2020	03:31	53	0.00059	INTERRUPTION DUE TO FAULTS
657	27-Jun-2020	PARTS OF F & G BLOCK SEC-3 POOTH KHURD BAWANA	531	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	02:55	27-Jun-2020	03:05	10	0.00011	INTERRUPTION DUE TO FAULTS
658	27-Jun-2020	PART OF O-BLOCK SEC-1 POOTH KHURD	5	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	13:28	27-Jun-2020	13:50	22	0.00001	INTERRUPTION DUE TO FAULTS
659	27-Jun-2020	PARTS OF VIDYA PATI NAGAR KARALA BAWANA	544	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	14:50	27-Jun-2020	15:40	50	0.00014	INTERRUPTION DUE TO FAULTS
660	27-Jun-2020	PART OF POLICE STATION KHANJHAWLA	2	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	15:32	27-Jun-2020	17:00	88	0.00005	SYSTEM SCHEDULE OUTAGE
661	27-Jun-2020	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADWA DT-2	2733	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	08:41	27-Jun-2020	09:00	19	0.00011	INTERRUPTION DUE TO FAULTS
662	27-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	1912	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	12:20	27-Jun-2020	13:50	90	0.00037	INTERRUPTION DUE TO FAULTS
663	27-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	2591	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	13:23	27-Jun-2020	13:50	27	0.00023	INTERRUPTION DUE TO FAULTS
664	27-Jun-2020	PART OF POLICE STATION KHANJHAWLA	2	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	12:22	27-Jun-2020	13:20	58	0.00003	INTERRUPTION DUE TO FAULTS
665	27-Jun-2020	PART OF JJ CLUSTER BAWANA	7	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	15:30	27-Jun-2020	16:20	50	0.00006	INTERRUPTION DUE TO FAULTS
666	27-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	1912	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	16:57	27-Jun-2020	17:20	23	0.00010	INTERRUPTION DUE TO FAULTS
667	27-Jun-2020	PARTS OF F BLOCK SEC-4 DSIDC BAWANA	452	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	19:52	27-Jun-2020	21:40	107	0.00119	INTERRUPTION DUE TO FAULTS
668	27-Jun-2020	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	1463	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	22:47	27-Jun-2020	23:00	13	0.00022	INTERRUPTION DUE TO FAULTS
669	27-Jun-2020	PARTS OF VIDYA PATI NAGAR KARALA BAWANA	614	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	23:09	28-Jun-2020	00:12	63	0.00035	INTERRUPTION DUE TO FAULTS
670	27-Jun-2020	PART OF J BLOCKS OF SEC - 4 DSIDC BAWANA	11	250 kVA	UNPLANNED OUTAGE	27-Jun-2020	11:23	27-Jun-2020	12:20	57	0.00002	SYSTEM SCHEDULE OUTAGE
671	27-Jun-2020	PART OF I BLOCKS OF SEC-4 DSIDC BAWANA	4	315 kVA	PLANNED OUTAGE	27-Jun-2020	11:25	27-Jun-2020	16:45	320	0.00009	PLANNED OUTAGE
672	27-Jun-2020	PART OF F-BLK SEC-2 DSIDC	4	315 kVA	PLANNED OUTAGE	27-Jun-2020	11:28	27-Jun-2020	17:51	383	0.00011	PLANNED OUTAGE
673	27-Jun-2020	PARTS OF SEC-5 B, N & O BLOCK BAWANA	261	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	10:14	27-Jun-2020	14:30	256	0.00021	PLANNED OUTAGE
674	27-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	2228	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	10:09	27-Jun-2020	10:22	13	0.00008	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
675	9-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR	26	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	11:22	9-Jun-2020	16:50	328	0.00046	FORCE MAJEURE DUE TO SABOTAGE
676	27-Jun-2020	PARTS OF J & K BLOCK POOTHKHURD BAWANA	531	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	12:14	27-Jun-2020	16:00	226	0.00038	PLANNED OUTAGE
677	27-Jun-2020	PARTS OF F BLOCK SEC-4 DSIDC BAWANA	452	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	10:06	27-Jun-2020	17:52	466	0.00052	PLANNED OUTAGE
678	27-Jun-2020	PARTS OF C, G, E BLOCK SEC. - 5 DSIDC BAWANA	280	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	09:17	27-Jun-2020	17:46	509	0.00042	PLANNED OUTAGE
679	28-Jun-2020	PART OF N BLOCK SEC-2 POOTHKHURD BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	10:28	28-Jun-2020	12:00	92	0.00003	INTERRUPTION DUE TO FAULTS
680	28-Jun-2020	PARTS OF AGAR NAGAR KARALA BAWANA	3086	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	06:24	28-Jun-2020	07:24	60	0.00067	INTERRUPTION DUE TO FAULTS
681	28-Jun-2020	PARTS OF CHANPUR MAJRA KANJHAWALA BAWANA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	00:10	28-Jun-2020	00:22	12	0.00057	INTERRUPTION DUE TO FAULTS
682	28-Jun-2020	PARTS OF C,D-BLOCK JJ COLONY BAWANA	2288	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	02:17	28-Jun-2020	02:55	38	0.00042	INTERRUPTION DUE TO FAULTS
683	28-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	2462	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	18:20	28-Jun-2020	18:42	22	0.00031	INTERRUPTION DUE TO FAULTS
684	13-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR	26	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	10:39	13-Jun-2020	14:46	247	0.00034	FORCE MAJEURE DUE TO SABOTAGE
685	16-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR	26	OTHER OUTAGE	PLANNED OUTAGE	16-Jun-2020	10:11	16-Jun-2020	15:35	324	0.00009	PLANNED OUTAGE
686	28-Jun-2020	PARTS OF LM BLOCK SEC-1 POOTH KHURD BAWANA	237	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	00:41	28-Jun-2020	01:10	29	0.00024	INTERRUPTION DUE TO FAULTS
687	28-Jun-2020	PARTS OF DD MALL SECT-5 POOTH KHURD BAWANA	333	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	07:35	28-Jun-2020	08:20	45	0.00188	INTERRUPTION DUE TO FAULTS
688	28-Jun-2020	PARTS OF KARALA VILLAGE BAWANA	1464	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	08:04	28-Jun-2020	08:44	40	0.00050	INTERRUPTION DUE TO FAULTS
689	28-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	2530	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	00:43	28-Jun-2020	00:58	15	0.00064	INTERRUPTION DUE TO FAULTS
690	28-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	2503	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	10:42	28-Jun-2020	11:25	43	0.00179	INTERRUPTION DUE TO FAULTS
691	27-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR	27	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	10:58	27-Jun-2020	17:55	417	0.00012	PLANNED OUTAGE
692	28-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	2503	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	12:54	28-Jun-2020	13:57	63	0.00273	INTERRUPTION DUE TO FAULTS
693	28-Jun-2020	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2591	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	10:35	28-Jun-2020	11:05	30	0.00067	INTERRUPTION DUE TO FAULTS
694	28-Jun-2020	PARTS OF MBS BAWANA	85	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	10:48	28-Jun-2020	11:20	32	0.00009	INTERRUPTION DUE TO FAULTS
695	28-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	1640	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	08:40	28-Jun-2020	09:33	53	0.00074	INTERRUPTION DUE TO FAULTS
696	28-Jun-2020	PARTS OF LM BLOCK SEC-1 POOTH KHURD BAWANA	233	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	11:44	28-Jun-2020	12:15	31	0.00102	INTERRUPTION DUE TO FAULTS
697	28-Jun-2020	PARTS OF C,D-BLOCK JJ COLONY BAWANA	1046	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	12:33	28-Jun-2020	13:18	45	0.00044	INTERRUPTION DUE TO FAULTS
698	28-Jun-2020	PARTS OF DJB RAW WATER PUMP HOUSE, PRAGTI POWER	24	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	14:14	28-Jun-2020	16:06	112	0.00012	INTERRUPTION DUE TO FAULTS
699	28-Jun-2020	PARTS OF C,D,I BLOCKS OF SEC - 4 DSIDC BAWANA	356	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	14:14	28-Jun-2020	15:49	94	0.00144	SYSTEM SCHEDULE OUTAGE
700	28-Jun-2020	PARTS OF F BLOCK SEC-4 DSIDC BAWANA	269	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	17:07	28-Jun-2020	17:20	13	0.00037	INTERRUPTION DUE TO FAULTS
701	28-Jun-2020	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	3105	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	18:12	28-Jun-2020	18:55	43	0.00066	INTERRUPTION DUE TO FAULTS
702	28-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	53	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	19:07	28-Jun-2020	20:20	73	0.00020	INTERRUPTION DUE TO FAULTS
703	28-Jun-2020	PARTS OF MBS BAWANA	3480	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	19:27	28-Jun-2020	20:05	38	0.00164	INTERRUPTION DUE TO FAULTS
704	28-Jun-2020	PARTS OF KARALA VILLAGE BAWANA	4324	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	19:34	28-Jun-2020	20:02	28	0.00096	INTERRUPTION DUE TO FAULTS
705	28-Jun-2020	PARTS OF MBS BAWANA	1161	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	20:49	28-Jun-2020	21:05	16	0.00005	INTERRUPTION DUE TO FAULTS
706	28-Jun-2020	PARTS OF GAS AGENCY NARELA ROAD, VIJAY NAGAR, KRISHNA MARKET, MAIN BUS STAND BAWANA, SHIV MANDIR AUCHANDI, PSS-400-MB HOSPITAL,KRISHNA MARKET NO-1	2734	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	21:31	28-Jun-2020	21:40	8	0.00007	INTERRUPTION DUE TO FAULTS
707	28-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	1582	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	22:48	28-Jun-2020	23:31	43	0.00018	INTERRUPTION DUE TO FAULTS
708	28-Jun-2020	PARTS OF LCH-896 POOTH KHURD BAWANA	378	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	22:13	29-Jun-2020	00:12	119	0.00049	INTERRUPTION DUE TO FAULTS
709	28-Jun-2020	PARTS OF JJ SAWDA ALL BLOCKS KANJHAWALA BAWANA	1065	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	23:51	29-Jun-2020	00:13	22	0.00007	INTERRUPTION DUE TO FAULTS
710	28-Jun-2020	PARTS OF LCH 1184 POOTH KHURD BAWANA	869	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	23:34	29-Jun-2020	01:00	86	0.00036	INTERRUPTION DUE TO FAULTS
711	29-Jun-20	PART OF INTERCONNECTOR-1 BAWANA	3	160 kVA	UNPLANNED OUTAGE	29-Jun-20	11:29	29-Jun-20	11:49	20	0.00001	SYSTEM SCHEDULE OUTAGE
712	29-Jun-20	PART OF B-BLOCK SEC-3 POOTH BAWANA	1	160 kVA	UNPLANNED OUTAGE	29-Jun-20	14:27	29-Jun-20	14:59	32	0.00001	SYSTEM SCHEDULE OUTAGE
713	29-Jun-20	PART OF F-BLK SEC-2 DSIDC	4	160 kVA	UNPLANNED OUTAGE	29-Jun-20	15:05	29-Jun-20	15:21	16	0.000005	SYSTEM SCHEDULE OUTAGE
714	29-Jun-20	PARTS OF MAIN ROAD KARALA & SUKHBIR NAGAR	1496	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	08:29	29-Jun-20	14:00	331	0.00138	PLANNED OUTAGE
715	29-Jun-20	PARTS OF KARALA VILLAVE BAWANA	5820	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:33	29-Jun-20	18:25	51	0.00256	INTERRUPTION DUE TO FAULTS
716	29-Jun-20	PARTS OF C-BLK SEC-4 POOTH KHURD BAWANA	548	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:23	29-Jun-20	18:15	52	0.00121	INTERRUPTION DUE TO FAULTS
717	28-Jun-2020	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR	27	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	10:42	28-Jun-2020	13:57	195	0.00027	FORCE MAJEURE DUE TO SABOTAGE
718	29-Jun-20	PARTS OF ASTHAL CLNY, KOTAKHAR RD, RAMESH NAGAR BAWANA	2064	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	21:05	29-Jun-20	21:40	35	0.00019	INTERRUPTION DUE TO FAULTS
719	29-Jun-20	PARTS OF CHANPUR MAJRA AND KANJHAWALA VILLAGE BAWANA	2109	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:27	29-Jun-20	18:22	55	0.00115	INTERRUPTION DUE TO FAULTS
720	29-Jun-20	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	1463	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:33	29-Jun-20	17:50	17	0.00031	INTERRUPTION DUE TO FAULTS
721	29-Jun-20	PARTS OF C, G, E BLOCK SEC. - 5 DSIDC BAWANA	280	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:33	29-Jun-20	17:50	17	0.00026	INTERRUPTION DUE TO FAULTS
722	29-Jun-20	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2591	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:23	29-Jun-20	18:05	42	0.00089	INTERRUPTION DUE TO FAULTS
723	29-Jun-20	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	2530	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:28	29-Jun-20	18:20	52	0.00101	INTERRUPTION DUE TO FAULTS
724	29-Jun-20	PARTS OF CHOTU RAM POLYTECHNIC, UPKAR COLONY NO-1, SAWADA VILLAGE, SHIV MANDIR WALA, UPKAR COLONY NO-2,UPKAR COLONY SADWA DT-2	2733	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:37	29-Jun-20	21:00	203	0.00220	FORCE MAJEURE DUE TO RAIN/STORM
725	29-Jun-20	PARTS OF AGAR NAGAR AND PREM NAGAR III	6378	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	01:50	29-Jun-20	02:45	55	0.00096	INTERRUPTION DUE TO FAULTS
726	29-Jun-20	PARTS OF AGAR NAGAR AND PREM NAGAR III	2465	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	01:50	29-Jun-20	03:58	128	0.00089	FORCE MAJEURE DUE TO SABOTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
727	29-Jun-20	PART OF JYONTI VILLAGE BAWANA	13	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	08:27	29-Jun-20	09:10	43	0.00001	INTERRUPTION DUE TO FAULTS
728	29-Jun-20	PART OF F BLOCK SEC-4 DSIDC BAWANA	2	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	12:02	29-Jun-20	14:35	153	0.00004	FORCE MAJEURE DUE TO SABOTAGE
729	29-Jun-20	PARTS OF A,B,G,E,F,H,J BLOCKS OF SEC - 4 DSIDC BAWANA	272	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	10:47	29-Jun-20	11:58	71	0.00061	INTERRUPTION DUE TO FAULTS
730	29-Jun-20	PARTS OF POOTH KHURD VILLAGE BAWANA	288	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	11:07	29-Jun-20	11:35	29	0.00027	INTERRUPTION DUE TO FAULTS
731	29-Jun-20	PARTS OF F BLOCK SEC-4 DSIDC BAWANA	266	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	13:38	29-Jun-20	14:00	22	0.00042	INTERRUPTION DUE TO FAULTS
732	29-Jun-20	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2591	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	14:01	29-Jun-20	14:22	21	0.00071	INTERRUPTION DUE TO FAULTS
733	29-Jun-20	PARTS OF PUNJAB KHOD BAWANA	3003	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:02	29-Jun-20	18:25	23	0.00028	INTERRUPTION DUE TO FAULTS
734	29-Jun-20	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	4502	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	16:43	29-Jun-20	17:40	56	0.00062	INTERRUPTION DUE TO FAULTS
735	29-Jun-20	PARTS OF UMRAO FARM TO HARIZAN BASTI KARALA, NDPL OFFICE KARALA TO SARDAREY WALA DT	45	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:11	29-Jun-20	21:20	249	0.00028	FORCE MAJEURE DUE TO RAIN/STORM
736	29-Jun-20	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	318	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:28	29-Jun-20	18:10	42	0.00106	INTERRUPTION DUE TO FAULTS
737	29-Jun-20	PARTS OF N-1 BLOCK SEC-5 POOTHKHURD BAWANA	349	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:28	29-Jun-20	18:40	72	0.00030	INTERRUPTION DUE TO FAULTS
738	29-Jun-20	PARTS OF C-BLK SEC-4 POOTH KHURD BAWANA	187	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	20:05	29-Jun-20	21:50	105	0.00044	INTERRUPTION DUE TO FAULTS
739	29-Jun-20	PARTS OF C-BLK SEC-4 POOTH KHURD BAWANA	62	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	21:07	29-Jun-20	21:50	43	0.00010	INTERRUPTION DUE TO FAULTS
740	29-Jun-20	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	288	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	20:02	29-Jun-20	22:35	153	0.00051	FORCE MAJEURE DUE TO SABOTAGE
741	29-Jun-20	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	30	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	22:11	29-Jun-20	22:35	24	0.00003	INTERRUPTION DUE TO FAULTS
742	29-Jun-20	PARTS OF F BLK SEC-1 POOTH KHURD BAWANA	103	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	22:12	29-Jun-20	22:35	23	0.00010	INTERRUPTION DUE TO FAULTS
743	29-Jun-20	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2591	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	22:18	29-Jun-20	22:30	11	0.00008	INTERRUPTION DUE TO FAULTS
744	29-Jun-20	PARTS OF D BLK SEC-5 POOTH KHURD BAWANA	323	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:31	29-Jun-20	18:30	59	0.00070	INTERRUPTION DUE TO FAULTS
745	29-Jun-20	PART OF N SEC-5 BAWANA	6	315 kVA	UNPLANNED OUTAGE	29-Jun-20	13:38	29-Jun-20	14:31	53	0.00001	SYSTEM SCHEDULE OUTAGE
746	29-Jun-20	PART OF N SEC-5 BAWANA	6	250 kVA	UNPLANNED OUTAGE	29-Jun-20	15:24	29-Jun-20	16:24	60	0.00002	SYSTEM SCHEDULE OUTAGE
747	29-Jun-20	PART OF SUKHBIR NAGAR KARALA BAWANA	4	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	07:48	29-Jun-20	14:05	377	0.00010	PLANNED OUTAGE
748	29-Jun-20	PART OF SUKHBIR NAGAR KARALA BAWANA	18	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:46	29-Jun-20	19:25	38	0.00002	INTERRUPTION DUE TO FAULTS
749	29-Jun-20	PARTS OF POLICE STATION KHANJHAWLA, JAI BHAGWAN AT DEPOT ROAD,HARIJAN BASTI- KHANJHAWLA,HARISH CHAUHAN,KANJHAWALA LADPUR ROAD MAJRA VILLAGE,JHIMAR PURA VILLAGE,MTNL CHANDPUR,CHANDPUR HARIJAN BASTI BAL KISHAN,BRICK FACTORY CHANDPUR KALAN SINDHU CHAWALA KANJHAWALA SDM COURT KANJHAWALA	524	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	10:04	29-Jun-20	16:28	383	0.00064	PLANNED OUTAGE
750	1-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	13	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	22:04	1-Jun-2020	22:40	36	0.00002	INTERRUPTION DUE TO FAULTS
751	1-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	08:30	1-Jun-2020	11:12	161	0.00009	FORCE MAJEURE DUE TO SABOTAGE
752	29-Jun-20	PARTS OF MBS BAWANA	3200	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:24	29-Jun-20	17:50	26	0.00047	INTERRUPTION DUE TO FAULTS
753	29-Jun-20	PARTS OF VIDYA PATI NAGAR KARALA BAWANA	2871	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	10:26	29-Jun-20	11:18	52	0.00052	INTERRUPTION DUE TO FAULTS
754	29-Jun-20	PARTS OF PASHU AUSHADHALAYA KARALA BAWANA	3833	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:42	29-Jun-20	18:10	28	0.00077	INTERRUPTION DUE TO FAULTS
755	4-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	14	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	09:56	4-Jun-2020	10:20	24	0.00001	INTERRUPTION DUE TO FAULTS
756	5-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	17	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	23:08	6-Jun-2020	00:55	107	0.00015	INTERRUPTION DUE TO FAULTS
757	6-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	7	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	15:08	6-Jun-2020	16:45	97	0.00003	SYSTEM SCHEDULE OUTAGE
758	30-Jun-20	PARTS OF KARALA VILLAVE BAWANA	5820	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	18:56	30-Jun-20	20:05	69	0.00132	INTERRUPTION DUE TO FAULTS
759	30-Jun-20	PARTS OF KARALA VILLAVE BAWANA	1496	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	22:16	30-Jun-20	22:58	42	0.00017	INTERRUPTION DUE TO FAULTS
760	30-Jun-20	PARTS OF KARALA VILLAVE BAWANA	4325	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	22:16	1-Jul-20	00:55	159	0.00203	FORCE MAJEURE DUE TO SABOTAGE
761	6-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	8	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	19:57	6-Jun-2020	21:15	78	0.00004	INTERRUPTION DUE TO FAULTS
762	30-Jun-20	PARTS OF MAJRI VILLAGE AND KARALA BAWANA	580	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	07:49	30-Jun-20	09:25	96	0.00040	INTERRUPTION DUE TO FAULTS
763	30-Jun-20	PARTS OF MAJRI VILLAGE AND KARALA BAWANA	918	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	07:58	30-Jun-20	09:20	82	0.00021	INTERRUPTION DUE TO FAULTS
764	30-Jun-20	PARTS OF MAJRI VILLAGE AND KARALA BAWANA	1728	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	11:14	30-Jun-20	11:24	10	0.00008	INTERRUPTION DUE TO FAULTS
765	30-Jun-20	PARTS OF MAJRI VILLAGE AND KARALA BAWANA	2308	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	05:39	30-Jun-20	07:25	105	0.00067	INTERRUPTION DUE TO FAULTS
766	7-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	5	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	10:28	7-Jun-2020	13:15	166	0.00005	FORCE MAJEURE DUE TO RAIN/STORM
767	12-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	6	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	05:58	12-Jun-2020	07:56	118	0.00003	INTERRUPTION DUE TO FAULTS
768	30-Jun-20	PART OF I BLOCKS OF SEC-4 DSIDC BAWANA	6	250 kVA	UNPLANNED OUTAGE	30-Jun-20	11:36	30-Jun-20	12:49	73	0.00002	SYSTEM SCHEDULE OUTAGE
769	13-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	4	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	11:10	13-Jun-2020	13:52	162	0.00005	PLANNED OUTAGE
770	30-Jun-20	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	3	160 kVA	UNPLANNED OUTAGE	30-Jun-20	14:22	30-Jun-20	14:59	37	0.00001	SYSTEM SCHEDULE OUTAGE
771	30-Jun-20	PART OF SEC-5 B BLOCK BAWANA	4	315 kVA	UNPLANNED OUTAGE	30-Jun-20	14:52	30-Jun-20	15:46	54	0.00002	SYSTEM SCHEDULE OUTAGE
772	30-Jun-20	PARTS OF DHEERAJ VIHAR, RAJEEV NAGAR EXTN	4956	OTHER OUTAGE	PLANNED OUTAGE	30-Jun-20	10:09	30-Jun-20	13:01	171	0.00233	PLANNED OUTAGE
773	22-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	5	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	08:45	22-Jun-2020	12:53	248	0.00014	FORCE MAJEURE DUE TO RAIN/STORM
774	5-Jun-2020	PARTS OF VILLAGE NIZAM PUR, VILLAGE GADI RANDHALA	30	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	12:30	5-Jun-2020	13:07	37	0.00005	INTERRUPTION DUE TO FAULTS
775	30-Jun-20	PARTS OF B BLK SEC-1 POOTH KHURD BAWANA	262	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	23:18	1-Jul-20	00:00	42	0.00018	INTERRUPTION DUE TO FAULTS
776	25-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	3	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	01:20	25-Jun-2020	01:55	35	0.00001	INTERRUPTION DUE TO FAULTS
777	12-Jun-2020	PARTS OF VILL-RANI KHERA,VILL- RASOOL PUR, VILL-MUBARAK PUR	21	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	08:21	12-Jun-2020	13:00	278	0.00008	PLANNED OUTAGE
778	26-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	14	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	19:50	26-Jun-2020	20:42	52	0.00007	INTERRUPTION DUE TO FAULTS
779	28-Jun-2020	PART OF SUKHBIR NAGAR KARALA BAWANA	2	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	09:50	28-Jun-2020	10:55	65	0.00002	INTERRUPTION DUE TO FAULTS
780	30-Jun-20	PARTS OF VILLAGE KANJHAWLA, BULLA COLONY, PARTS OF MAHAVIR VIHAR, UDAY VIHAR, ZONAL OFFICE BUILDING	2530	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	11:48	30-Jun-20	12:05	17	0.00014	INTERRUPTION DUE TO FAULTS
781	30-Jun-20	PART OF I BLOCKS OF SEC-1 DSIDC BAWANA	4	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	16:43	30-Jun-20	17:10	27	0.00001	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
782	30-Jun-20	PARTS OF BAWANA STADIUM AND BAWANA INDS. AREA	2586	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	16:51	30-Jun-20	17:05	14	0.00037	INTERRUPTION DUE TO FAULTS
783	30-Jun-20	PARTS OF SHARMA COLONY, PART OF AGAR NAGAR, PART OF INDER ENCLAVE PH II, ROOP VIHAR, PART OF MAJRI VILLAGE AND PART OF RAMA VIHAR D BLOCK	2465	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	16:25	30-Jun-20	17:00	35	0.00146	INTERRUPTION DUE TO FAULTS
784	30-Jun-20	PARTS OF D BLK SEC-5 POOTH KHURD BAWANA	323	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	06:48	30-Jun-20	07:00	12	0.00005	INTERRUPTION DUE TO FAULTS
785	30-Jun-20	PARTS OF OLD ZONAL OFFICE POOTH KHURD VILLAGE, DJB PUMP HOUSE, SULTANPUR NO-3, LACHMAN SARUP NARULA, JAI HIND SCHOOL	1463	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	07:40	30-Jun-20	07:44	4	0.00002	INTERRUPTION DUE TO FAULTS
786	30-Jun-20	PARTS OF SUBZI MANDI KANJHAWALA ROAD, INDRAJ COLONY NO-3, BPCL NEAR SHRI KRISHNA GAUSHALA, ISHWAR COLONY NO-3, MTNL KANJHAWALA ROAD	3547	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	07:48	30-Jun-20	08:05	17	0.00017	INTERRUPTION DUE TO FAULTS
787	30-Jun-20	PARTS OF C,D,I BLOCKS OF SEC - 4 DSIDC BAWANA	356	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	10:36	30-Jun-20	11:10	33	0.00014	INTERRUPTION DUE TO FAULTS
788	30-Jun-20	PARTS OF POOTH KHURD VILLAGE BAWANA	288	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	12:20	30-Jun-20	12:50	30	0.00051	INTERRUPTION DUE TO FAULTS
					CIVIL LINES							
1	1-Jun-2020	PARTS OF ST. STEPHENS HOSPITAL AND SWISS APPARTMENT CIVIL LINE	458	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	12:29	1-Jun-2020	13:15	46	0.00013	INTERRUPTION DUE TO FAULTS
2	1-Jun-2020	PARTS OF DU SPORTS COMPLEX CIVIL LINE	79	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	21:40	1-Jun-2020	22:10	30	0.00004	INTERRUPTION DUE TO FAULTS
3	1-Jun-2020	PARTS OF MALARIA, NICD, 1 UNDERHILL ROAD, PNB STAFF QUARTER, RAJPUR ROAD, UNDER HILL LANE	872	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	06:34	1-Jun-2020	06:50	15	0.00017	INTERRUPTION DUE TO FAULTS
4	1-Jun-2020	PARTS OF MALARIA, NICD, 1 UNDERHILL ROAD, PNB STAFF QUARTER, RAJPUR ROAD, UNDER HILL LANE	72	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	06:34	1-Jun-2020	07:25	50	0.00014	INTERRUPTION DUE TO FAULTS
5	2-Jun-2020	PARTS OF ROOP NAGAR BLOCK-2, D BLOCK KAMLANAGER	1695	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	14:37	2-Jun-2020	14:48	11	0.00005	INTERRUPTION DUE TO FAULTS
6	2-Jun-2020	PART OF D BLOCK KAMLANAGER CIVIL LINES	4	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	14:37	2-Jun-2020	15:15	38	0.00002	INTERRUPTION DUE TO FAULTS
7	3-Jun-2020	PARTS OF DU STAFF QTRS, KHALSA COLLEGE, SFS FLATS, RIVERA APPARTMENTS, ISM, PATEL CHEST, MIRANDA HOUSE, ART FACULITY	503	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	07:21	3-Jun-2020	07:35	13	0.00002	INTERRUPTION DUE TO FAULTS
8	4-Jun-2020	PARTS OF HINDU RAO HOSPITAL, PART OF MALKA GANJ O,P,C1,C2,B,A,BLOCB MALKAGANJ	295	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	12:35	4-Jun-2020	12:52	17	0.00001	PLANNED OUTAGE
9	4-Jun-2020	PARTS OF NEW KIRORI MAL COLLEGE AND KAMALA NAGAR MKT	2066	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:16	4-Jun-2020	17:34	17	0.00029	INTERRUPTION DUE TO FAULTS
10	4-Jun-2020	PARTS OF NEW KIRORI MAL COLLEGE AND KAMALA NAGAR MKT	85	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:16	4-Jun-2020	17:42	25	0.00004	INTERRUPTION DUE TO FAULTS
11	4-Jun-2020	PARTS OF DU SPORTS COMPLEX CIVIL LINE	1152	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	09:54	4-Jun-2020	10:14	20	0.00008	INTERRUPTION DUE TO FAULTS
12	4-Jun-2020	PARTS OF DU SPORTS COMPLEX CIVIL LINE	802	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	09:58	4-Jun-2020	10:14	16	0.00007	INTERRUPTION DUE TO FAULTS
13	4-Jun-2020	PARTS OF R P BAGH, JAIN COLONY, PART OF C C COLONY.	1781	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	18:28	4-Jun-2020	18:45	17	0.00005	INTERRUPTION DUE TO FAULTS
14	5-Jun-2020	PARTS OF C C COLONY, PART OF GURMANDI,KHATIK BASTI AND JAIN COLONY	974	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	07:06	5-Jun-2020	07:33	27	0.00011	INTERRUPTION DUE TO FAULTS
15	6-Jun-2020	PARTS OF DU SPORTS COMPLEX CIVIL LINE	1222	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	18:35	6-Jun-2020	18:54	19	0.00016	INTERRUPTION DUE TO FAULTS
16	6-Jun-2020	PARTS OF MALKA GANJ & UNIVERSITY AREA	1851	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	12:49	6-Jun-2020	15:50	181	0.00201	FORCE MAJEURE DUE TO SABOTAGE
17	7-Jun-2020	PARTS OF R P BAGH, JAIN COLONY, PART OF C C COLONY.	1425	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	17:23	7-Jun-2020	17:40	18	0.00015	INTERRUPTION DUE TO FAULTS
18	7-Jun-2020	PARTS OF R P BAGH, JAIN COLONY, PART OF C C COLONY.	356	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	17:23	7-Jun-2020	18:30	67	0.00019	INTERRUPTION DUE TO FAULTS
19	8-Jun-2020	PARTS OF INDIRA MKT KAMALA NAGAR CIVIL LINE	260	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	12:50	8-Jun-2020	13:30	40	0.00011	INTERRUPTION DUE TO FAULTS
20	8-Jun-2020	PARTS OF C C COLONY, PART OF GURMANDI,KHATIK BASTI AND JAIN COLONY	974	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	19:08	8-Jun-2020	19:30	22	0.00019	INTERRUPTION DUE TO FAULTS
21	8-Jun-2020	PARTS OF INDIRA MKT KAMALA NAGAR CIVIL LINE	895	630 kVA	PLANNED OUTAGE	8-Jun-2020	10:45	8-Jun-2020	12:18	93	0.00023	PLANNED OUTAGE
22	9-Jun-2020	PARTS OF DVB COLONY, PART OF R P BAGH, PART OF KABIR NAGAR, PART OF OM NAGAR, KISHOR NAGAR.	1815	OTHER OUTAGE	PLANNED OUTAGE	9-Jun-2020	09:52	9-Jun-2020	11:45	113	0.0006	PLANNED OUTAGE
23	10-Jun-2020	PARTS OF DRDO & TIMARPUR CIVIL LINE	3264	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	06:18	10-Jun-2020	06:32	14	0.00018	INTERRUPTION DUE TO FAULTS
24	10-Jun-2020	PARTS OF LUCKNOW ROAD, BD ESTATE, ROAD NO - 45, NEW TIMAR CAMP, SINDHI BABA, MOTHER TERESA, SUR GHAT, DMRC, OLD TIBITIAN CAMP.	59	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:20	10-Jun-2020	18:10	50	0.00017	INTERRUPTION DUE TO FAULTS
25	10-Jun-2020	PARTS OF TILAK CHOWK AND KAMALA NAGAR CIVIL LINE	664	630 kVA	PLANNED OUTAGE	10-Jun-2020	11:06	10-Jun-2020	12:08	62	0.00012	PLANNED OUTAGE
26	11-Jun-2020	PARTS OF CLOCK TOWER & MKT SHAKTI NAGAR	752	990 kVA	PLANNED OUTAGE	11-Jun-2020	11:10	11-Jun-2020	12:19	69	0.00013	PLANNED OUTAGE
27	12-Jun-2020	PARTS OF ST. STEPHENS HOSPITAL AND SWISS APPARTMENT CIVIL LINE	458	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	11:28	12-Jun-2020	11:39	11	0.00004	INTERRUPTION DUE TO FAULTS
28	12-Jun-2020	PARTS OF HUDSON LINE,VIJAY NAGAR DOUBLE STOREY,ASHOKA MANUFACTURING,KIRPAL ASHRAM,VIJAY NAGAR 8-9 BLOCK,GURMANDI DUPLEX FLATS	128	400 kVA	UNPLANNED OUTAGE	12-Jun-2020	14:41	12-Jun-2020	14:55	14	0.000004	SYSTEM SCHEDULE OUTAGE
29	13-Jun-2020	PARTS OF FLAGSTAFF ROAD, 16 RAJPUR ROAD, 21 RAJPUR ROAD,24 RAJPUR ROAD,4 BATTERY LANE, TIRATH RAM HOSPITAL,	97	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	11:40	13-Jun-2020	12:30	50	0.00007	SYSTEM SCHEDULE OUTAGE
30	13-Jun-2020	PARTS OF MALARIA, NICD, 1 UNDERHILL ROAD, PNB STAFF QUARTER, RAJPUR ROAD, UNDER HILL LANE	715	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:32	13-Jun-2020	15:50	18	0.00006	INTERRUPTION DUE TO FAULTS
31	13-Jun-2020	PARTS OF MALARIA, NICD, 1 UNDERHILL ROAD, PNB STAFF QUARTER, RAJPUR ROAD, UNDER HILL LANE	603	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:32	13-Jun-2020	16:00	28	0.00008	INTERRUPTION DUE TO FAULTS
32	13-Jun-2020	PARTS OF C C COLONY, PART OF GURMANDI,KHATIK BASTI AND JAIN COLONY	2192	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:38	13-Jun-2020	14:42	4	0.00009	INTERRUPTION DUE TO FAULTS
33	13-Jun-2020	PARTS OF WAZIRABAD WATER WORKS TIMAR PUR CIVIL LINE	123	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:04	13-Jun-2020	16:30	26	0.00004	INTERRUPTION DUE TO FAULTS
34	17-Jun-2020	PARTS OF KALYAN VIHAR, SFS FLATS KALYAN VIHAR, MASHWARI SADAN, PART OF NEW GUPTA COLONY, PART OF OLD GUPTA COLONY, PART OF SINGLE STORY VIJAY NAGAR, POLO ROAD, ISHWAR COLONY &MAA KALYANI KUNJ	458	630 kVA	PLANNED OUTAGE	17-Jun-2020	11:02	17-Jun-2020	11:15	13	0.00002	PLANNED OUTAGE
35	17-Jun-2020	PARTS OF PARAG ICE FACTORY AND KAMALA NAGAR	503	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	04:22	17-Jun-2020	04:55	33	0.00003	SYSTEM SCHEDULE OUTAGE
36	17-Jun-2020	PARTS OF PARAG ICE FACTORY AND KAMALA NAGAR	503	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	20:33	17-Jun-2020	21:03	30	0.00008	SYSTEM SCHEDULE OUTAGE
37	17-Jun-2020	PARTS OF 6 ALIPUR ROAD. MAIDNS HOTEL, PSS 17 ALIPUR ROAD, 10 & 12 ALIPUR ROAD	254	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	13:51	17-Jun-2020	14:15	24	0.00007	INTERRUPTION DUE TO FAULTS
38	18-Jun-2020	PARTS OF DU SPORTS COMPLEX CIVIL LINE	79	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	20:20	18-Jun-2020	20:40	20	0.00004	INTERRUPTION DUE TO FAULTS
39	18-Jun-2020	PARTS OF DU SPORTS COMPLEX CIVIL LINE	271	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	20:20	18-Jun-2020	20:45	25	0.00008	INTERRUPTION DUE TO FAULTS
40	20-Jun-2020	PARTS OF NEW KIRORI MAL COLLEGE AND KAMALA NAGAR MKT	1872	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	17:06	20-Jun-2020	17:18	12	0.00006	INTERRUPTION DUE TO FAULTS
41	20-Jun-2020	PARTS OF NEW KIRORI MAL COLLEGE AND KAMALA NAGAR MKT	279	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	17:36	20-Jun-2020	18:05	29	0.00010	INTERRUPTION DUE TO FAULTS
42	21-Jun-2020	PARTS OF SANGAM PARK OLD ,DSIDC SANGAM PARK, MCD SCHOOL R P BAGH.	298	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	06:21	21-Jun-2020	06:55	34	0.00008	SYSTEM SCHEDULE OUTAGE
43	21-Jun-2020	PARTS OF JUBILEE HALL, BIO CHEM, SFS MALL APPARTMENTS, REVIERA APPARTMENT, MES	76	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	08:07	21-Jun-2020	08:22	15	0.00002	INTERRUPTION DUE TO FAULTS
44	21-Jun-2020	PARTS OF JUBILEE HALL, BIO CHEM, SFS MALL APPARTMENTS, REVIERA APPARTMENT, MES	68	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	08:07	21-Jun-2020	09:10	63	0.00009	INTERRUPTION DUE TO FAULTS
45	22-Jun-2020	PARTS OF NARMADA SWITCHING AND KAMALA NAGAR CIVIL LINE	2762	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:40	22-Jun-2020	06:10	30	0.00038	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
46	23-Jun-2020	PARTS OF KABIR BASTI, PART OF MALKA GANJ, PART OF JAWAHAR NAGAR.	842	OTHER OUTAGE	PLANNED OUTAGE	23-Jun-2020	11:13	23-Jun-2020	12:45	92	0.00023	PLANNED OUTAGE
47	24-Jun-2020	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN	477	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	13:39	24-Jun-2020	13:55	16	0.00003	INTERRUPTION DUE TO FAULTS
48	24-Jun-2020	PARTS OF ROSHANARACLUB,ESI,NANGIA PARK, SINGH SABHA ROAD ,10A, 11, 13,16, 22, 27 & 33 BLOCKS SHAKTI NAGAR, TRAFIC PARK.,SITASARAN COLONY,SUBJIMANDI,HARPHOOL SINGH BUILDING	1532	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	20:54	24-Jun-2020	21:12	19	0.00012	INTERRUPTION DUE TO FAULTS
49	24-Jun-2020	PARTS OF ROSHANARACLUB,ESI,NANGIA PARK, SINGH SABHA ROAD ,10A, 11, 13,16, 22, 27 & 33 BLOCKS SHAKTI NAGAR, TRAFIC PARK.,SITASARAN COLONY,SUBJIMANDI,HARPHOOL SINGH BUILDING	531	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	20:54	24-Jun-2020	21:21	28	0.00009	INTERRUPTION DUE TO FAULTS
50	24-Jun-2020	PARTS OF ROSHANARACLUB,ESI,NANGIA PARK, SINGH SABHA ROAD ,10A, 11, 13,16, 22, 27 & 33 BLOCKS SHAKTI NAGAR, TRAFIC PARK.,SITASARAN COLONY,SUBJIMANDI,HARPHOOL SINGH BUILDING	449	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	20:54	24-Jun-2020	21:37	44	0.00018	INTERRUPTION DUE TO FAULTS
51	25-Jun-2020	PARTS OF C C COLONY, PART OF GURMANDI,KHATIK BASTI AND JAIN COLONY	332	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	16:13	25-Jun-2020	16:25	12	0.00003	INTERRUPTION DUE TO FAULTS
52	26-Jun-2020	PARTS OF INDRA MARKET CIVIL LINE	1168	OTHER OUTAGE	PLANNED OUTAGE	26-Jun-2020	10:32	26-Jun-2020	13:04	152	0.00034	PLANNED OUTAGE
53	27-Jun-2020	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN	361	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	21:02	27-Jun-2020	22:30	88	0.00025	INTERRUPTION DUE TO FAULTS
54	28-Jun-2020	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN	626	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	09:20	28-Jun-2020	09:26	6	0.00002	INTERRUPTION DUE TO FAULTS
55	28-Jun-2020	PARTS OF MAHAVIR ICE FACTORY, PWD UNDER BRIDGE, GOKHLE MARKET, ISBT, QUEDASIA GARDEN	361	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	09:20	28-Jun-2020	10:40	80	0.00016	INTERRUPTION DUE TO FAULTS
56	29-Jun-20	PART OF -19 RAJ PUR ROAD CIVIL LINES.	3	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	13:50	29-Jun-20	16:30	160	0.00004	FORCE MAJEURE DUE TO SABOTAGE
57	29-Jun-20	PARTS OF 4, 17, 19 RAJ PUR ROAD, DCP OFFICE	481	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	06:10	29-Jun-20	06:25	15	0.00006	INTERRUPTION DUE TO FAULTS
58	29-Jun-20	PARTS OF 4, 17, 19 RAJ PUR ROAD, DCP OFFICE	34	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	06:10	29-Jun-20	06:43	33	0.00005	INTERRUPTION DUE TO FAULTS
59	29-Jun-20	PARTS OF 4, 17, 19 RAJ PUR ROAD, DCP OFFICE	515	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:09	29-Jun-20	18:39	30	0.00013	INTERRUPTION DUE TO FAULTS
60	29-Jun-20	PARTS OF ROOP NAGAR BLOCK-2, D BLOCK KAMLA NAGAR CIVIL LINE	289	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	13:44	29-Jun-20	14:26	42	0.00006	INTERRUPTION DUE TO FAULTS
61	29-Jun-20	PARTS OF TIKONA PARK SHAKTI NAGAR, OLD COMPLAINT CENTRE SHAKTI NAGAR, LEGACY HOTEL, 20 - BLOCK SHAKTI NAGAR	1073	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:42	29-Jun-20	17:50	8	0.00003	INTERRUPTION DUE TO FAULTS
62	29-Jun-20	PARTS OF TIKONA PARK SHAKTI NAGAR, OLD COMPLAINT CENTRE SHAKTI NAGAR, LEGACY HOTEL, 20 - BLOCK SHAKTI NAGAR	126	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:42	29-Jun-20	17:52	9	0.00001	INTERRUPTION DUE TO FAULTS
63	30-Jun-20	PART OF GOKHLE MARKET CIVIL LINES	16	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	16:49	30-Jun-20	17:45	56	0.00002	INTERRUPTION DUE TO FAULTS
64	30-Jun-20	PARTS OF RUB SANGAM PARK GTK ROAD	784	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	21:06	30-Jun-20	21:13	7	0.00002	INTERRUPTION DUE TO FAULTS
65	30-Jun-20	PARTS OF 4, 17, 19 RAJ PUR ROAD, DCP OFFICE	357	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	19:23	30-Jun-20	19:38	15	0.00004	INTERRUPTION DUE TO FAULTS
66	30-Jun-20	PARTS OF NEW ST. STEPHENS HOSPITAL AND SWISS APARTMENT CIVIL LINES	1991	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	09:33	30-Jun-20	10:15	41	0.00103	INTERRUPTION DUE TO FAULTS
					KESHAV PURAM							
1	30-Jun-20	PART OF B/66 WAZIR PUR KESHAV PURAM	8	250 kVA	UNPLANNED OUTAGE	30-Jun-20	11:55	30-Jun-20	12:22	27	0.00001	SYSTEM SCHEDULE OUTAGE
2	22-Jun-2020	PART OF B/66 WAZIR PUR KESHAV PURAM	5	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	20:40	24-Jun-2020	15:00	2540	0.00282	FORCE MAJEURE DUE TO FIRE
3	25-Jun-2020	PART OF B/66 WAZIR PUR KESHAV PURAM	2	250 kVA	UNPLANNED OUTAGE	25-Jun-2020	15:56	25-Jun-2020	16:55	59	0.00002	SYSTEM SCHEDULE OUTAGE
4	3-Jun-2020	PART OF G-40 LAWARNCE ROAD INDUSTRIAL AREA KESHAV PURAM	5	250 kVA	UNPLANNED OUTAGE	3-Jun-2020	13:09	3-Jun-2020	13:51	42	0.00001	SYSTEM SCHEDULE OUTAGE
5	3-Jun-2020	PART OF WAZIR PUR INDUSTRIAL AREA	2	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	15:09	3-Jun-2020	15:50	41	0.00001	SYSTEM SCHEDULE OUTAGE
6	3-Jun-2020	PARTS OF HVDS DSIDC CKT.1 CKT.2, B - 71, B - 40	28	OTHER OUTAGE	PLANNED OUTAGE	3-Jun-2020	15:57	3-Jun-2020	16:42	45	0.00001	PLANNED OUTAGE
7	3-Jun-2020	PARTS OF NAFFED, C.E.T, ESSEL HOUSE, MODERN FOOD, B-3, B-2	86	OTHER OUTAGE	PLANNED OUTAGE	3-Jun-2020	11:15	3-Jun-2020	12:55	100	0.00003	PLANNED OUTAGE
8	3-Jun-2020	PARTS OF HIMACHAL COLD STORE, JASWANT, HARYANA, C-12, MODERN COLD STORE, C - 9/2, C - 9/3, C - 12, C - 7, C - 6/1 TO C - 6/12 INDUSTRIAL AREA LAWRENCE ROAD	55	OTHER OUTAGE	PLANNED OUTAGE	3-Jun-2020	08:34	3-Jun-2020	10:44	130	0.00004	PLANNED OUTAGE
9	3-Jun-2020	PARTS OF K, L,J1, J2 AND SANJAY MARKET WAZIRPUR JJ COLONY	507	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	07:52	3-Jun-2020	08:10	18	0.00006	INTERRUPTION DUE TO FAULTS
10	3-Jun-2020	PARTS OF WAZIR PUR INDUSTRIAL AREA (A - BLOCK)	29	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	17:04	3-Jun-2020	17:17	13	0.00002	SYSTEM SCHEDULE OUTAGE
11	3-Jun-2020	PARTS OF INFRONT OF D/538, L-BLK JJ COLONY, INFRONT OF C/417	56	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	07:47	3-Jun-2020	08:20	33	0.00004	INTERRUPTION DUE TO FAULTS
12	4-Jun-2020	PARTS OF RAMPURA VILLAGE , RAM PURA MAIN ROAD, LIG FLATS RAM PURA	170	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	11:52	4-Jun-2020	13:30	98	0.00003	PLANNED OUTAGE
13	4-Jun-2020	PARTS OF HVDS MANSOORI, C - 1 TO C - 31 LAWARANCE ROAD INDUSTRIAL. AREA	72	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	10:45	4-Jun-2020	11:00	15	0.00006	INTERRUPTION DUE TO FAULTS
14	4-Jun-2020	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA	3	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	11:38	4-Jun-2020	12:15	37	0.00001	INTERRUPTION DUE TO FAULTS
15	4-Jun-2020	PARTS OF NIMIRI COLONY, PART OF BHARAT NAGAR PH-4	270	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	14:52	4-Jun-2020	15:07	15	0.00010	SYSTEM SCHEDULE OUTAGE
16	4-Jun-2020	PARTS OF HVDS DSIDC CKT.1 CKT.2, B - 71, B - 40	28	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	19:08	4-Jun-2020	19:31	23	0.00003	INTERRUPTION DUE TO FAULTS
17	22-Jun-2020	PARTS OF B/66 & B/65 WAZIR PUR KESHAV PURAM	1351	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	20:40	22-Jun-2020	21:05	25	0.00024	INTERRUPTION DUE TO FAULTS
18	4-Jun-2020	PARTS OF K, L,J1, J2 AND SANJAY MARKET WAZIRPUR JJ COLONY	1149	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	00:57	4-Jun-2020	01:29	32	0.00011	INTERRUPTION DUE TO FAULTS
19	4-Jun-2020	PARTS OF H & I BLOCK ASHOK VIHAR PH - 1, MAHA RAJA AGARSEN SCHOOL	193	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	08:16	4-Jun-2020	09:30	74	0.00031	INTERRUPTION DUE TO FAULTS
20	29-Jun-20	PART OF C-48 LAWRENCE ROAD KESHAV PURAM	2	160 kVA	UNPLANNED OUTAGE	29-Jun-20	10:39	29-Jun-20	11:01	22	0.00001	SYSTEM SCHEDULE OUTAGE
21	15-Jun-2020	PART OF C-48 LAWRENCE ROAD KESHAV PURAM	7	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	11:44	15-Jun-2020	12:05	21	0.00001	INTERRUPTION DUE TO FAULTS
22	27-Jun-2020	PART OF C-48 LAWRENCE ROAD KESHAV PURAM	6	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	14:19	27-Jun-2020	15:12	53	0.00002	INTERRUPTION DUE TO FAULTS
23	5-Jun-2020	PART OF A-93 WPIA KESHAV PURAM	5	400 kVA	UNPLANNED OUTAGE	5-Jun-2020	11:04	5-Jun-2020	12:40	96	0.00003	SYSTEM SCHEDULE OUTAGE
24	5-Jun-2020	PARTS OF KANHIYA NAGAR, PART OF GANESH PURA	126	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	15:58	5-Jun-2020	16:10	12	0.00005	SYSTEM SCHEDULE OUTAGE
25	5-Jun-2020	PART OF SALONA (A-9/3) KESHAV PURAM	4	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	08:13	5-Jun-2020	08:35	22	0.00001	INTERRUPTION DUE TO FAULTS
26	6-Jun-2020	PART OF A BLOCK GROUP INDUSTRIAL AREA	1	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	07:42	6-Jun-2020	08:05	23	0.00001	SYSTEM SCHEDULE OUTAGE
27	6-Jun-2020	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA	5	400 kVA	PLANNED OUTAGE	6-Jun-2020	11:23	6-Jun-2020	13:15	112	0.00003	PLANNED OUTAGE
28	6-Jun-2020	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA	5	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	10:55	6-Jun-2020	11:32	37	0.00001	INTERRUPTION DUE TO FAULTS
29	6-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	56	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	14:51	6-Jun-2020	15:30	39	0.00002	INTERRUPTION DUE TO FAULTS
30	6-Jun-2020	PART OF C-34 INDUSTRIAL AREA KESHAV PURAM	15	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	18:15	6-Jun-2020	19:50	94	0.00058	INTERRUPTION DUE TO FAULTS
31	7-Jun-2020	PARTS OF COMMUNITY CENTRE, PART OF STRIPLEX RAMPURA	52	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	19:22	7-Jun-2020	19:46	23	0.00002	INTERRUPTION DUE TO FAULTS
32	7-Jun-2020	PARTS OF PUNJAB KESRI, HINDU, C-6, C-5 KESHAV PURAM	22	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	01:51	7-Jun-2020	02:25	34	0.00011	INTERRUPTION DUE TO FAULTS
33	22-Jun-2020	PARTS OF B/66 & B/65 WAZIR PUR KESHAV PURAM	39	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	20:40	22-Jun-2020	22:59	139	0.00019	FORCE MAJEURE DUE TO FIRE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
34	7-Jun-2020	PART OF C-5 KESHAV PURAM	5	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	01:51	7-Jun-2020	02:20	29	0.00002	INTERRUPTION DUE TO FAULTS
35	8-Jun-2020	PARTS OF COMMUNITY CENTRE, PART OF STRIPLEX RAMPURA	52	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	07:32	8-Jun-2020	08:00	28	0.00006	INTERRUPTION DUE TO FAULTS
36	8-Jun-2020	PARTS OF A BLOCK GROUP INDUSTRIAL AREA	189	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	09:05	8-Jun-2020	09:15	10	0.00008	INTERRUPTION DUE TO FAULTS
37	8-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	113	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	08:25	8-Jun-2020	08:32	8	0.00002	INTERRUPTION DUE TO FAULTS
38	8-Jun-2020	PARTS OF B & C - BLOCK WAZIRPUR INDUSTRIAL AREA	53	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	09:47	8-Jun-2020	10:03	17	0.00002	INTERRUPTION DUE TO FAULTS
39	8-Jun-2020	PARTS OF INFRONT OF D/538, L-BLK JJ COLONY, INFRONT OF C/417	634	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	14:12	8-Jun-2020	15:49	97	0.00022	INTERRUPTION DUE TO FAULTS
40	8-Jun-2020	PARTS OF INFRONT OF D/538, L-BLK JJ COLONY, INFRONT OF C/417	134	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	15:04	8-Jun-2020	15:49	45	0.00003	INTERRUPTION DUE TO FAULTS
41	9-Jun-2020	PARTS OF WAZIR PUR INDUSTRIAL AREA (A - BLOCK)	32	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	12:19	9-Jun-2020	12:34	15	0.00001	INTERRUPTION DUE TO FAULTS
42	29-Jun-20	PART OF DSIDC CKT.1 KESHAV PURAM	2	63 kVA	UNPLANNED OUTAGE	29-Jun-20	12:08	29-Jun-20	12:27	19	0.00001	SYSTEM SCHEDULE OUTAGE
43	4-Jun-2020	PART OF DSIDC CKT.1 KESHAV PURAM	7	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:04	4-Jun-2020	17:15	10	0.000003	INTERRUPTION DUE TO FAULTS
44	5-Jun-2020	PART OF DSIDC CKT.1 KESHAV PURAM	5	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	12:47	5-Jun-2020	13:00	13	0.000004	SYSTEM SCHEDULE OUTAGE
45	23-Jun-2020	PART OF DSIDC CKT.1 KESHAV PURAM	2	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	16:17	23-Jun-2020	16:35	18	0.00001	INTERRUPTION DUE TO FAULTS
46	9-Jun-2020	PARTS OF INFRONT OF D/538, L-BLK JJ COLONY, INFRONT OF C/417	394	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	17:14	9-Jun-2020	17:35	21	0.00003	INTERRUPTION DUE TO FAULTS
47	26-Jun-2020	PART OF DSIDC CKT.1 KESHAV PURAM	4	250 kVA	UNPLANNED OUTAGE	26-Jun-2020	14:57	26-Jun-2020	15:30	33	0.00001	SYSTEM SCHEDULE OUTAGE
48	9-Jun-2020	PART OF B-BLOCK INDUSTRIAL AREA WAZIR PUR	4	400 kVA	UNPLANNED OUTAGE	9-Jun-2020	11:19	9-Jun-2020	13:18	119	0.00003	SYSTEM SCHEDULE OUTAGE
49	9-Jun-2020	PART OF DSIDC SHEDS KESHAV PURAM	7	250 kVA	UNPLANNED OUTAGE	9-Jun-2020	14:16	9-Jun-2020	15:24	68	0.00002	SYSTEM SCHEDULE OUTAGE
50	9-Jun-2020	PART OF A BLOCK GROUP INDUSTRIAL AREA	4	400 kVA	UNPLANNED OUTAGE	9-Jun-2020	15:38	9-Jun-2020	16:26	48	0.00001	SYSTEM SCHEDULE OUTAGE
51	9-Jun-2020	PART OF SALONA (A-9/3) KESHAV PURAM	4	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	14:22	9-Jun-2020	14:40	18	0.00003	INTERRUPTION DUE TO FAULTS
52	10-Jun-2020	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA	7	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	08:30	10-Jun-2020	09:30	60	0.00008	INTERRUPTION DUE TO FAULTS
53	10-Jun-2020	PARTS OF A BLOCK GROUP INDUSTRIAL AREA	189	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	21:00	10-Jun-2020	21:15	15	0.00008	INTERRUPTION DUE TO FAULTS
54	10-Jun-2020	PARTS OF NIMIRI COLONY, PART OF BHARAT NAGAR PH-4	189	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	12:40	10-Jun-2020	13:40	60	0.00008	SYSTEM SCHEDULE OUTAGE
55	10-Jun-2020	PARTS OF B & C BLOCK WAZIR PUR INDUSTRIAL AREA	106	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	11:02	10-Jun-2020	14:00	178	0.0001	PLANNED OUTAGE
56	10-Jun-2020	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTRIAL AREA	95	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	11:15	10-Jun-2020	14:02	167	0.00005	PLANNED OUTAGE
57	10-Jun-2020	PARTS OF C - 35 TO C - 48 LAWRENCE ROAD INDUSTRIAL AREA	84	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	15:11	10-Jun-2020	15:45	34	0.00001	PLANNED OUTAGE
58	10-Jun-2020	PARTS OF HVDS MANSOORI, C - 1 TO C - 31 LAWARANCE ROAD INDUSTRIAL. AREA	58	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	10:43	10-Jun-2020	14:05	202	0.00006	PLANNED OUTAGE
59	11-Jun-2020	PART OF C-33 WAZIRPUR KESHAV PURAM	4	250 kVA	UNPLANNED OUTAGE	11-Jun-2020	12:56	11-Jun-2020	13:15	19	0.00001	SYSTEM SCHEDULE OUTAGE
60	11-Jun-2020	PARTS OF KANHIYA NAGAR, SHANTI NAGAR & DEVA RAM PARK	527	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	17:12	11-Jun-2020	17:19	7	0.00002	INTERRUPTION DUE TO FAULTS
61	11-Jun-2020	PART OF C-33 WAZIRPUR KESHAV PURAM	6	250 kVA	PLANNED OUTAGE	11-Jun-2020	10:25	11-Jun-2020	12:20	115	0.00003	PLANNED OUTAGE
62	11-Jun-2020	PART OF G-40 LAWARNCE ROAD INDUSTRIAL AREA KESHAV PURAM	3	400 kVA	UNPLANNED OUTAGE	11-Jun-2020	13:39	11-Jun-2020	14:04	25	0.00001	SYSTEM SCHEDULE OUTAGE
63	12-Jun-2020	PART OF A-93 WPIA KESHAV PURAM	1	250 kVA	UNPLANNED OUTAGE	12-Jun-2020	07:24	12-Jun-2020	07:39	15	0.000004	SYSTEM SCHEDULE OUTAGE
64	12-Jun-2020	PART OF C-31 LAWARANCE ROAD INDUSTRIAL. AREA KESHAV PURAM	6	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	17:13	12-Jun-2020	19:05	112	0.00016	SYSTEM SCHEDULE OUTAGE
65	12-Jun-2020	PARTS OF IP TOWER, COMMUNITY CENTRE, MOHAN TOWER	122	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	09:18	12-Jun-2020	09:28	10	0.00002	INTERRUPTION DUE TO FAULTS
66	12-Jun-2020	PARTS OF IP TOWER, COMMUNITY CENTRE, MOHAN TOWER	34	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	09:18	12-Jun-2020	09:30	12	0.00002	INTERRUPTION DUE TO FAULTS
67	13-Jun-2020	PART OF C-33 WAZIRPUR KESHAV PURAM	4	315 kVA	UNPLANNED OUTAGE	13-Jun-2020	10:53	13-Jun-2020	11:59	66	0.00002	SYSTEM SCHEDULE OUTAGE
68	13-Jun-2020	PARTS OF D, E, H & J BLOCK ASHOK VIHAR PH - 1	179	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:23	13-Jun-2020	17:08	45	0.00006	INTERRUPTION DUE TO FAULTS
69	13-Jun-2020	PARTS OF WAZIR PUR INDUSTRIAL AREA (A - BLOCK)	103	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:03	13-Jun-2020	16:50	47	0.00026	INTERRUPTION DUE TO FAULTS
70	13-Jun-2020	PARTS OF MASZID PARK, J3/380,NAGAR NIGAM SCHOOL	190	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:29	13-Jun-2020	17:40	11	0.00001	INTERRUPTION DUE TO FAULTS
71	13-Jun-2020	PARTS OF MASZID PARK, J3/380,NAGAR NIGAM SCHOOL	673	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:54	13-Jun-2020	18:15	21	0.00009	INTERRUPTION DUE TO FAULTS
72	13-Jun-2020	PART OF SANJAY MARKET WAZIRPUR JJ COLONY	2	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	19:45	13-Jun-2020	19:50	5	0.000001	INTERRUPTION DUE TO FAULTS
73	13-Jun-2020	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTRIAL AREA	95	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	07:04	13-Jun-2020	07:30	27	0.00004	INTERRUPTION DUE TO FAULTS
74	13-Jun-2020	PARTS OF MASZID PARK, J3/380,NAGAR NIGAM SCHOOL	673	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:18	13-Jun-2020	16:50	32	0.00013	INTERRUPTION DUE TO FAULTS
75	13-Jun-2020	PARTS OF COMMUNITY CENTRE, PART OF STRIPLEX RAMPURA	121	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	10:31	13-Jun-2020	12:40	129	0.00007	PLANNED OUTAGE
76	14-Jun-2020	PARTS OF K, L,J1, J2 AND SANJAY MARKET WAZIRPUR JJ COLONY	215	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	15:31	14-Jun-2020	15:58	27	0.00011	INTERRUPTION DUE TO FAULTS
77	15-Jun-2020	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA	3	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	15:34	15-Jun-2020	16:13	39	0.00002	INTERRUPTION DUE TO FAULTS
78	15-Jun-2020	PARTS OF A BLOCK GROUP INDUSTRIAL AREA	23	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	11:50	15-Jun-2020	12:56	65	0.00009	INTERRUPTION DUE TO FAULTS
79	15-Jun-2020	PART OF C-BLOCK WAZIRPUR INDUSTRIAL AREA	4	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	18:40	15-Jun-2020	19:44	64	0.00004	INTERRUPTION DUE TO FAULTS
80	15-Jun-2020	PARTS OF B & C - BLOCK WAZIRPUR INDUSTRIAL AREA	49	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	19:14	15-Jun-2020	19:44	30	0.00008	INTERRUPTION DUE TO FAULTS
81	15-Jun-2020	PART OF C-34 INDUSTRIAL AREA KESHAV PURAM	19	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	20:29	15-Jun-2020	20:50	21	0.00001	INTERRUPTION DUE TO FAULTS
82	16-Jun-2020	PART OF RAMPURA VILLAGE KESHAV PURAM	7	250 kVA	UNPLANNED OUTAGE	16-Jun-2020	14:37	16-Jun-2020	16:20	103	0.00003	SYSTEM SCHEDULE OUTAGE
83	16-Jun-2020	PARTS OF KANHIYA NAGAR, PART OF GANESH PURA	352	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	23:50	17-Jun-2020	00:06	16	0.00005	INTERRUPTION DUE TO FAULTS
84	17-Jun-2020	PART OF B-69 LAW RD IND AREA. KESHAV PURAM	7	250 kVA	UNPLANNED OUTAGE	17-Jun-2020	15:41	17-Jun-2020	16:15	34	0.00001	SYSTEM SCHEDULE OUTAGE
85	17-Jun-2020	PARTS OF C - 35 TO C - 48 LAWRENCE ROAD INDUSTRIAL AREA	224	OTHER OUTAGE	PLANNED OUTAGE	17-Jun-2020	14:25	17-Jun-2020	17:25	180	0.00015	PLANNED OUTAGE
86	17-Jun-2020	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA	6	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	15:25	17-Jun-2020	15:51	26	0.00001	INTERRUPTION DUE TO FAULTS
87	17-Jun-2020	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA	9	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	16:02	17-Jun-2020	16:21	19	0.00001	INTERRUPTION DUE TO FAULTS
88	17-Jun-2020	PARTS OF MASZID PARK, J3/380,NAGAR NIGAM SCHOOL	173	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	20:19	17-Jun-2020	20:46	28	0.00011	INTERRUPTION DUE TO FAULTS
89	18-Jun-2020	PARTS OF NARANG COLONY & CHANDER NAGAR	382	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	00:25	18-Jun-2020	00:45	20	0.00003	INTERRUPTION DUE TO FAULTS
90	18-Jun-2020	PARTS OF NIMIRI COLONY, PART OF BHARAT NAGAR PH-4	130	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:16	18-Jun-2020	13:10	54	0.00008	INTERRUPTION DUE TO FAULTS
91	18-Jun-2020	PARTS OF GANESH PURA, DEVA RAM PARK, LEKHU NAGAR, SHANTI NAGAR & ANAJ MANDI	515	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:48	18-Jun-2020	12:56	8	0.00001	SYSTEM SCHEDULE OUTAGE
92	19-Jun-2020	PART OF C-BLOCK WAZIRPUR INDUSRTRIAL AREA	5	400 kVA	UNPLANNED OUTAGE	19-Jun-2020	14:36	19-Jun-2020	15:44	68	0.00002	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
93	19-Jun-2020	PARTS OF H & I BLOCK ASHOK VIHAR PH - 1, MAHA RAJA AGARSEN SCHOOL	885	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	11:09	19-Jun-2020	11:21	12	0.00004	INTERRUPTION DUE TO FAULTS
94	19-Jun-2020	PARTS OF CHANDER NAGAR, BUS STAND, VISHRAM NAGAR	421	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	11:48	19-Jun-2020	12:02	14	0.00004	INTERRUPTION DUE TO FAULTS
95	19-Jun-2020	PARTS OF C - 3 KESHAV PURAM, C-3 MIG FLATS KESHAV PURAM, C-4 (PART) KESHAV PURAM	390	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	13:29	19-Jun-2020	13:37	8	0.00002	SYSTEM SCHEDULE OUTAGE
96	19-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	74	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	15:43	19-Jun-2020	16:10	27	0.00004	INTERRUPTION DUE TO FAULTS
97	19-Jun-2020	PARTS OF B & C - BLOCK WAZIRPUR INDUSTRIAL AREA	349	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	17:47	19-Jun-2020	18:32	45	0.00010	INTERRUPTION DUE TO FAULTS
98	19-Jun-2020	PART OF J3/380 W.PUR INDL.A-BLK	12	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	21:34	19-Jun-2020	22:18	44	0.00006	INTERRUPTION DUE TO FAULTS
99	19-Jun-2020	PART OF SALONA (A-9/3) KESHAV PURAM	18	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	14:52	19-Jun-2020	15:13	21	0.00001	SYSTEM SCHEDULE OUTAGE
100	20-Jun-2020	PARTS OF G - 5, G - 29 TO G - 40 LAWARNCE ROAD INDUSTRIAL AREA, G - 41 TO G - 59, B - 38, 39, B - 34, B - 35, B - 36	72	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	10:38	20-Jun-2020	12:43	125	0.00003	PLANNED OUTAGE
101	20-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	878	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	14:12	20-Jun-2020	14:42	30	0.00007	INTERRUPTION DUE TO FAULTS
102	20-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	103	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	14:14	20-Jun-2020	14:42	28	0.00002	INTERRUPTION DUE TO FAULTS
103	20-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	90	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	11:59	20-Jun-2020	12:18	19	0.00006	INTERRUPTION DUE TO FAULTS
104	20-Jun-2020	PARTS OF H & I BLOCK ASHOK VIHAR PH - 1, MAHA RAJA AGARSEN SCHOOL	147	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	02:04	20-Jun-2020	02:30	26	0.00026	INTERRUPTION DUE TO FAULTS
105	20-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	45	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:18	20-Jun-2020	09:05	46	0.00046	INTERRUPTION DUE TO FAULTS
106	20-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	35	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:18	20-Jun-2020	12:30	251	0.00084	FORCE MAJEURE DUE TO RAIN/STORM
107	20-Jun-2020	PARTS OF INFRONT OF D/538, L-BLK JJ COLONY, INFRONT OF C/417	136	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:33	20-Jun-2020	08:53	21	0.00006	INTERRUPTION DUE TO FAULTS
108	20-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	90	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	11:37	20-Jun-2020	11:59	22	0.00024	INTERRUPTION DUE TO FAULTS
109	20-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	141	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	11:52	20-Jun-2020	12:20	29	0.00001	INTERRUPTION DUE TO FAULTS
110	6-Jun-2020	PARTS OF RAJDHANI, SUSHIL, C - 32, JAGDIISH, DARSHAN, HINDUSTAN	22	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	18:15	6-Jun-2020	18:38	22	0.00028	INTERRUPTION DUE TO FAULTS
111	21-Jun-2020	PART OF C-34 INDUSTRIAL AREA KESHAV PURAM	19	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	05:31	21-Jun-2020	05:38	7	0.000002	INTERRUPTION DUE TO FAULTS
112	22-Jun-2020	PARTS OF C & A- BLOCK WAZIRPUR INDUSRTRIAL AREA	47	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	09:47	22-Jun-2020	11:30	103	0.00014	SYSTEM SCHEDULE OUTAGE
113	22-Jun-2020	PART OF A BLOCK GROUP INDUSTRIAL AREA	4	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	11:27	22-Jun-2020	12:00	33	0.00004	INTERRUPTION DUE TO FAULTS
114	22-Jun-2020	PARTS OF A BLOCK GROUP INDUSTRIAL AREA	46	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	13:56	22-Jun-2020	14:40	43	0.00005	INTERRUPTION DUE TO FAULTS
115	22-Jun-2020	PARTS OF C - 1, A - 2 MIG A - 2 LIG, A - 1	24	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	15:43	22-Jun-2020	16:10	27	0.00002	INTERRUPTION DUE TO FAULTS
116	22-Jun-2020	PARTS OF C - 1, A - 2 MIG A - 2 LIG, A - 1	24	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	18:23	22-Jun-2020	18:43	20	0.00002	INTERRUPTION DUE TO FAULTS
117	22-Jun-2020	PARTS OF BUS STAND ROAD, TOTA RAM BAZAR & ZOOR BAGH	144	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	06:54	22-Jun-2020	07:18	25	0.00004	INTERRUPTION DUE TO FAULTS
118	22-Jun-2020	PARTS OF A BLOCK GROUP INDUSTRIAL AREA	163	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	07:36	22-Jun-2020	08:10	34	0.00024	INTERRUPTION DUE TO FAULTS
119	22-Jun-2020	PARTS OF INFRONT OF D/538, L-BLK JJ COLONY, INFRONT OF C/417	130	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	11:58	22-Jun-2020	12:55	58	0.00006	INTERRUPTION DUE TO FAULTS
120	22-Jun-2020	PARTS OF INFRONT OF D/538, L-BLK JJ COLONY, INFRONT OF C/417	406	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	12:44	22-Jun-2020	12:55	11	0.00003	INTERRUPTION DUE TO FAULTS
121	22-Jun-2020	PARTS OF B BLOCK WAZIR PUR INDUSTRIAL AREA	160	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	21:00	22-Jun-2020	21:10	10	0.00008	INTERRUPTION DUE TO FAULTS
122	22-Jun-2020	PART OF A BLOCK GROUP INDUSTRIAL AREA	4	250 kVA	UNPLANNED OUTAGE	22-Jun-2020	13:31	22-Jun-2020	14:02	31	0.00001	SYSTEM SCHEDULE OUTAGE
123	23-Jun-2020	PARTS OF JA BLK MURGA MKT AND PART OF J-BLOCK ASHOK VIHAR PH-1	183	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	17:14	23-Jun-2020	17:35	21	0.00005	INTERRUPTION DUE TO FAULTS
124	23-Jun-2020	PARTS OF INFRONT OF D/538, L-BLK JJ COLONY, INFRONT OF C/417	21	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	08:36	23-Jun-2020	09:01	25	0.00001	INTERRUPTION DUE TO FAULTS
125	23-Jun-2020	PARTS OF INFRONT OF D/538, L-BLK JJ COLONY, INFRONT OF C/417	107	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	17:24	23-Jun-2020	17:42	18	0.00006	INTERRUPTION DUE TO FAULTS
126	23-Jun-2020	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA	1	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	07:47	23-Jun-2020	07:59	12	0.000003	SYSTEM SCHEDULE OUTAGE
127	23-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA AND PART OF A BLOCK GROUP INDUSTRIAL AREA	104	400 kVA	UNPLANNED OUTAGE	23-Jun-2020	08:05	23-Jun-2020	08:29	24	0.00001	SYSTEM SCHEDULE OUTAGE
128	23-Jun-2020	PART OF B BLOCK WAZIR PUR INDUSTRIAL AREA	3	250 kVA	UNPLANNED OUTAGE	23-Jun-2020	11:59	23-Jun-2020	12:25	26	0.00001	SYSTEM SCHEDULE OUTAGE
129	29-Jun-20	PART OF NAFFED KESHAV PURAM	12	63 kVA	UNPLANNED OUTAGE	29-Jun-20	12:50	29-Jun-20	13:14	24	0.00001	SYSTEM SCHEDULE OUTAGE
130	2-Jun-2020	PART OF NAFFED KESHAV PURAM	4	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	15:38	2-Jun-2020	18:00	142	0.00008	FORCE MAJEURE DUE TO SABOTAGE
131	24-Jun-2020	PARTS OF INFRONT OF D/538, L-BLK JJ COLONY, INFRONT OF C/417	106	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	08:28	24-Jun-2020	08:46	18	0.00002	INTERRUPTION DUE TO FAULTS
132	24-Jun-2020	PARTS OF I A-BLOCK, PART OF H & J BLOCK ASHOK VIHAR PH - 1 , POLICE COLONY & SPORTS COMPLEX, TRANSFORMER WORK SHOP J BLOCK	387	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	15:42	24-Jun-2020	15:57	15	0.00003	INTERRUPTION DUE TO FAULTS
133	24-Jun-2020	PARTS OF NAFFED, C.E.T, ESSEL HOUSE, MODERN FOOD, B-3, B-2	99	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	08:11	24-Jun-2020	10:01	110	0.00037	INTERRUPTION DUE TO FAULTS
134	24-Jun-2020	PARTS OF NAFFED, C.E.T, ESSEL HOUSE, MODERN FOOD, B-3, B-2	77	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	16:47	24-Jun-2020	17:56	69	0.00013	INTERRUPTION DUE TO FAULTS
135	16-Jun-2020	PART OF NAFFED KESHAV PURAM	4	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	08:48	16-Jun-2020	09:35	47	0.00001	INTERRUPTION DUE TO FAULTS
136	24-Jun-2020	PARTS OF A BLOCK GROUP INDUSTRIAL AREA	23	400 kVA	UNPLANNED OUTAGE	24-Jun-2020	11:23	24-Jun-2020	11:37	14	0.000004	SYSTEM SCHEDULE OUTAGE
137	24-Jun-2020	PARTS OF WAZIRPUR COURT, B - BLOCK INDUSTRIAL AREA WAZIR PUR	92	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	09:06	24-Jun-2020	11:40	154	0.00004	PLANNED OUTAGE
138	24-Jun-2020	PARTS OF B BLOCK WAZIR PUR INDUSTRIAL AREA	25	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	09:20	24-Jun-2020	11:59	159	0.00004	PLANNED OUTAGE
139	24-Jun-2020	PARTS OF H & I BLOCK ASHOK VIHAR PH - 1, MAHA RAJA AGARSEN SCHOOL	251	250 kVA	PLANNED OUTAGE	24-Jun-2020	10:26	24-Jun-2020	11:55	89	0.00005	PLANNED OUTAGE
140	25-Jun-2020	PART OF A-93 WPIA KESHAV PURAM	6	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	12:46	25-Jun-2020	13:20	34	0.00001	INTERRUPTION DUE TO FAULTS
141	25-Jun-2020	PARTS OF ONKAR NAGAR B AND C	50	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	15:45	25-Jun-2020	15:58	13	0.00001	INTERRUPTION DUE TO FAULTS
142	25-Jun-2020	PARTS OF B & C BLOCK WAZIR PUR INDUSTRIAL AREA	65	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	06:06	25-Jun-2020	06:40	33	0.00002	INTERRUPTION DUE TO FAULTS
143	25-Jun-2020	PARTS OF C-33 & B-32 WAZIRPUR KESHAV PURAM	269	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	16:51	25-Jun-2020	17:13	22	0.00004	INTERRUPTION DUE TO FAULTS
144	25-Jun-2020	PARTS OF C-33 & B-32 WAZIRPUR KESHAV PURAM	70	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	16:51	25-Jun-2020	18:01	70	0.00004	INTERRUPTION DUE TO FAULTS
145	25-Jun-2020	PARTS OF C-33 & B-32 WAZIRPUR KESHAV PURAM	36	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	17:25	25-Jun-2020	18:01	36	0.00002	INTERRUPTION DUE TO FAULTS
146	25-Jun-2020	PARTS OF IP TOWER, COMMUNITY CENTRE, MOHAN TOWER	225	630 kVA	PLANNED OUTAGE	25-Jun-2020	10:30	25-Jun-2020	10:52	22	0.00001	PLANNED OUTAGE
147	26-Jun-2020	PARTS OF B - BLOCK WAZIRPUR INDUSTRIAL AREA	46	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	16:37	26-Jun-2020	18:01	84	0.00007	INTERRUPTION DUE TO FAULTS
148	26-Jun-2020	PART OF DSIDC SHEDS KESHAV PURAM	3	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	17:17	26-Jun-2020	19:14	117	0.00010	INTERRUPTION DUE TO FAULTS
149	26-Jun-2020	PARTS OF C-5, C-6 & C-7 KESHAV PURAM	1506	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	04:05	26-Jun-2020	04:22	17	0.00024	INTERRUPTION DUE TO FAULTS
150	26-Jun-2020	PARTS OF NAFFED, C.E.T, ESSEL HOUSE, MODERN FOOD, B-3, B-2	27	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	09:30	26-Jun-2020	09:40	9	0.00001	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
151	27-Jun-2020	PARTS OF NIMIRI COLONY, PART OF BHARAT NAGAR PH-4	530	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	10:59	27-Jun-2020	11:20	21	0.00003	INTERRUPTION DUE TO FAULTS
152	27-Jun-2020	PARTS OF SHAKTI NAGAR EXT, SFS, RITES FLATS ASHOK VIHAR PH - 3, SATYAWATI COLONY, L BL COLLEGE,JANTA FLAT ASHOK VIHAR PH - 3	384	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	13:15	27-Jun-2020	13:40	25	0.00001	INTERRUPTION DUE TO FAULTS
153	27-Jun-2020	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA	7	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	13:00	27-Jun-2020	13:54	54	0.00008	SYSTEM SCHEDULE OUTAGE
154	27-Jun-2020	PARTS OF BUS STAND ROAD, TOTA RAM BAZAR & ZOOR BAGH	731	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	16:17	27-Jun-2020	16:35	18	0.00005	INTERRUPTION DUE TO FAULTS
155	27-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	75	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	16:43	27-Jun-2020	16:56	13	0.00006	INTERRUPTION DUE TO FAULTS
156	27-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	24	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	16:43	27-Jun-2020	16:59	16	0.00004	INTERRUPTION DUE TO FAULTS
157	27-Jun-2020	PARTS OF A BLOCK WAZIRPUR INDUSTRIAL AREA	90	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	16:43	27-Jun-2020	17:10	26	0.00015	INTERRUPTION DUE TO FAULTS
158	28-Jun-2020	PART OF A BLOCK GROUP INDUSTRIAL AREA	2	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	12:36	28-Jun-2020	12:54	18	0.00001	SYSTEM SCHEDULE OUTAGE
159	28-Jun-2020	PARTS OF OLD SAWAN PARK, SL JAIN HOSPITAL, LSC MARKET, PKT B-4	577	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	16:24	28-Jun-2020	16:40	16	0.00004	INTERRUPTION DUE TO FAULTS
160	28-Jun-2020	PART OF C-BLOCK WAZIRPUR INDUSRTRIAL AREA	12	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	09:14	28-Jun-2020	10:12	58	0.00003	SYSTEM SCHEDULE OUTAGE
161	28-Jun-2020	PARTS OF WAZIRPUR COURT, B - BLOCK INDUSTRIAL AREA WAZIR PUR	92	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	12:08	28-Jun-2020	12:22	14	0.00005	INTERRUPTION DUE TO FAULTS
162	28-Jun-2020	PARTS OF MASZID PARK, J3/380,NAGAR NIGAM SCHOOL	144	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	22:25	28-Jun-2020	22:56	31	0.00008	INTERRUPTION DUE TO FAULTS
163	28-Jun-2020	PARTS OF NIMIRI COLONY, PART OF BHARAT NAGAR PH-4	130	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	21:33	28-Jun-2020	22:45	73	0.00024	INTERRUPTION DUE TO FAULTS
164	29-Jun-20	PARTS OF INFRONT OF D/538, L-BLK JJ COLONY, INFRONT OF C/417	48	63 kVA	PLANNED OUTAGE	29-Jun-20	11:45	29-Jun-20	14:40	175	0.00005	PLANNED OUTAGE
165	29-Jun-20	PART OF A BLOCK WAZIRPUR INDUSTRIAL AREA	1	250 kVA	PLANNED OUTAGE	29-Jun-20	11:06	29-Jun-20	15:07	241	0.00007	PLANNED OUTAGE
166	29-Jun-20	PARTS OF G-2 TO G-19, B-44 TO B-69 LAW RD IND AREA.	419	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:40	29-Jun-20	18:10	30	0.00021	INTERRUPTION DUE TO FAULTS
167	30-Jun-20	PARTS OF OLD SAWAN PARK, SL JAIN HOSPITAL, LSC MARKET, PKT B-4	420	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	11:41	30-Jun-20	12:00	19	0.00003	INTERRUPTION DUE TO FAULTS
168	30-Jun-20	PARTS OF BUS STAND ROAD, TOTA RAM BAZAR & ZOOR BAGH	40	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	12:59	30-Jun-20	13:37	38	0.00005	INTERRUPTION DUE TO FAULTS
					MANGOLPURI							
1	1-Jun-2020	PARTS OF C BLOCK, DDA SLUM , G BLOCK H BLOCK, Y BLOCK	707	OTHER OUTAGE	PLANNED OUTAGE	1-Jun-2020	07:54	1-Jun-2020	09:30	96	0.00021	PLANNED OUTAGE
2	1-Jun-2020	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21	1074	OTHER OUTAGE	PLANNED OUTAGE	1-Jun-2020	09:54	1-Jun-2020	12:38	164	0.00032	PLANNED OUTAGE
3	1-Jun-2020	PARTS OF E-1,2,3,4,5 BLKS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY , LOHA MKT. EAST FRIENDS ENCLAVE.	451	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	11:05	1-Jun-2020	11:40	35	0.00006	INTERRUPTION DUE TO FAULTS
4	1-Jun-2020	PARTS OF SOM BAJAR AND ROHINI SEC 20	41	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	14:19	1-Jun-2020	16:10	111	0.00015	SYSTEM SCHEDULE OUTAGE
5	1-Jun-2020	PARTS OF GAURI SHANKER ENCLAVE , TRIPATHI ENCLAVE SHUKHI NAHAR , SARDA ENCLAVE, HIND VIHAR, SUKHI NAHAR MUBARAKPUR	7830	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	14:42	1-Jun-2020	14:55	13	0.00019	INTERRUPTION DUE TO FAULTS
6	1-Jun-2020	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL PKT-8	346	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	21:05	1-Jun-2020	21:18	13	0.00003	INTERRUPTION DUE TO FAULTS
7	1-Jun-2020	PARTS OF PKT-16 SEC-20 AND POOTHKALAN VILLAGE	67	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	22:00	1-Jun-2020	22:24	24	0.00005	INTERRUPTION DUE TO FAULTS
8	1-Jun-2020	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR	4595	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	05:03	1-Jun-2020	05:50	47	0.00034	INTERRUPTION DUE TO FAULTS
9	1-Jun-2020	PARTS OF T-1 & T-4 MPIA MANGOL PURI INDUSTRIAL AREA PH. - 1	75	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	12:14	1-Jun-2020	12:30	16	0.00005	INTERRUPTION DUE TO FAULTS
10	1-Jun-2020	PARTS OF WORK CENTRE SULTAN PURI, I & II BOTH PART OF C-3 BLOCK.	2781	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	14:59	1-Jun-2020	15:25	26	0.00033	INTERRUPTION DUE TO FAULTS
11	1-Jun-2020	PARTS OF GAURI SHANKER ENCLAVE , TRIPATHI ENCLAVE SHUKHI NAHAR , SARDA ENCLAVE, HIND VIHAR, SUKHI NAHAR MUBARAKPUR	2621	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	18:12	1-Jun-2020	18:36	24	0.00030	INTERRUPTION DUE TO FAULTS
12	1-Jun-2020	PARTS OF F-1,2,3,4,5 BLKS. S. PURI , GH BLK S. PURI ,RATAN VIHAR , KIRARI FURNITURE MKT. BALBEER NAGAR, H-2,3 BLKS. S. PURI	908	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	19:24	1-Jun-2020	20:30	66	0.00046	INTERRUPTION DUE TO FAULTS
13	1-Jun-2020	PARTS OF PKT-16 SEC-20 AND POOTHKALAN VILLAGE	3124	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	20:56	1-Jun-2020	21:30	34	0.00088	INTERRUPTION DUE TO FAULTS
14	1-Jun-2020	PART OF S/S NO -22 MANGOL PURI	8	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	11:22	1-Jun-2020	12:30	68	0.00006	INTERRUPTION DUE TO FAULTS
15	1-Jun-2020	PART OF SOM BAJAR MANGOLPURI	13	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	13:29	1-Jun-2020	13:59	30	0.00004	INTERRUPTION DUE TO FAULTS
16	1-Jun-2020	PART OF G-BLK RAJIV NAGAR MANGOLPURI	8	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	21:17	1-Jun-2020	22:10	53	0.00002	INTERRUPTION DUE TO FAULTS
17	2-Jun-2020	PARTS OF SOM BAZAR KIRARI MANGOL PURI	824	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	07:46	2-Jun-2020	08:10	24	0.00008	INTERRUPTION DUE TO FAULTS
18	2-Jun-2020	PART OF T-4 MANGOL PURI INDUSTRIAL AREA PH-1	13	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	11:36	2-Jun-2020	13:15	99	0.00003	INTERRUPTION DUE TO FAULTS
19	2-Jun-2020	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR	1811	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	18:35	2-Jun-2020	21:20	165	0.00115	FORCE MAJEURE DUE TO SABOTAGE
20	2-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	1404	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	08:19	2-Jun-2020	09:00	41	0.00040	INTERRUPTION DUE TO FAULTS
21	2-Jun-2020	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21	2499	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	16:37	2-Jun-2020	17:25	48	0.00069	INTERRUPTION DUE TO FAULTS
22	2-Jun-2020	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21	285	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	16:37	2-Jun-2020	18:05	88	0.00037	INTERRUPTION DUE TO FAULTS
23	2-Jun-2020	PARTS OF AMAN VIHAR AND SHIV CHOWK	2365	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	16:37	2-Jun-2020	16:48	10	0.00013	INTERRUPTION DUE TO FAULTS
24	2-Jun-2020	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR	3312	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	18:10	2-Jun-2020	18:25	16	0.00024	INTERRUPTION DUE TO FAULTS
25	2-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	517	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	17:51	2-Jun-2020	18:24	33	0.00023	INTERRUPTION DUE TO FAULTS
26	2-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	887	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	17:51	2-Jun-2020	18:24	33	0.00028	INTERRUPTION DUE TO FAULTS
27	2-Jun-2020	PARTS OF WORK CENTRE SULTAN PURI, I & II BOTH PART OF C-3 BLOCK.	2781	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	19:32	2-Jun-2020	19:46	14	0.00016	INTERRUPTION DUE TO FAULTS
28	2-Jun-2020	PART OF DHURVA ENCL. MANGOLPURI	4	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	15:30	2-Jun-2020	16:10	40	0.00002	INTERRUPTION DUE TO FAULTS
29	2-Jun-2020	PARTS OF KRISHNA VIHAR NO.1 & 2 HVDS, O & P BLOCK , HARSHDEV PARK	2807	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	07:32	2-Jun-2020	08:19	47	0.00055	INTERRUPTION DUE TO FAULTS
30	3-Jun-2020	PART OF B-BLK. PREM NAGAR MANGOLPURI	15	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	12:21	3-Jun-2020	13:27	66	0.00009	INTERRUPTION DUE TO FAULTS
31	3-Jun-2020	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR HVDS	623	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	12:57	3-Jun-2020	13:45	48	0.00020	INTERRUPTION DUE TO FAULTS
32	4-Jun-2020	PART OF B-BLK. PREM NAGAR MANGOLPURI	7	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	11:02	4-Jun-2020	11:22	20	0.00001	INTERRUPTION DUE TO FAULTS
33	4-Jun-2020	PART OF B-BLK. PREM NAGAR MANGOLPURI	3	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	13:55	4-Jun-2020	14:40	46	0.00001	INTERRUPTION DUE TO FAULTS
34	4-Jun-2020	PARTS OF K BLOCK, X BLOCK, K-2 BLOCK,J BLOCK, P&QBLOCK, R BLOCK, S BLOCK, L BLOCK JUGGI	775	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	10:02	4-Jun-2020	11:20	78	0.00015	PLANNED OUTAGE
35	4-Jun-2020	PARTS OF NITHARI, LAKHI RAM PARK, NITHARI DJB BOOSTER PUMP SUKHI NAHAR TALAB	1296	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	12:07	4-Jun-2020	13:20	73	0.00030	INTERRUPTION DUE TO FAULTS
36	4-Jun-2020	PARTS OF NITHARI, LAKHI RAM PARK, NITHARI DJB BOOSTER PUMP SUKHI NAHAR TALAB	203	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	18:35	4-Jun-2020	19:20	45	0.00031	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
37	4-Jun-2020	PARTS OF NITHARI, LAKHI RAM PARK, NITHARI DJB BOOSTER PUMP SUKHI NAHAR TALAB	203	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	06:54	4-Jun-2020	07:10	16	0.00002	INTERRUPTION DUE TO FAULTS
38	4-Jun-2020	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 RHN	680	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	11:48	4-Jun-2020	12:48	60	0.00025	INTERRUPTION DUE TO FAULTS
39	4-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	1712	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	13:55	4-Jun-2020	14:20	26	0.00011	INTERRUPTION DUE TO FAULTS
40	4-Jun-2020	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR HVDS	3192	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	18:16	4-Jun-2020	19:05	49	0.00034	INTERRUPTION DUE TO FAULTS
41	4-Jun-2020	PARTS OF AMAN VIHAR, BALBIR VIHAR NO-1, P.V-3 (NALE WALA),PRATAP VIHAR-3 (NALE WALA), RAMESH ENCLAVE	3100	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	15:38	4-Jun-2020	15:55	17	0.00017	INTERRUPTION DUE TO FAULTS
42	4-Jun-2020	PARTS OF POOTHKALAN NO.7, 12 HVDS, D-4 SEC-20	9067	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:14	4-Jun-2020	18:20	65	0.00082	INTERRUPTION DUE TO FAULTS
43	5-Jun-2020	PARTS OF PKT-16 SEC-20 AND POOTHKALAN VILLAGE	664	OTHER OUTAGE	PLANNED OUTAGE	5-Jun-2020	11:02	5-Jun-2020	14:00	178	0.00124	PLANNED OUTAGE
44	5-Jun-2020	PARTS OF GAURI SHANKER ENCLAVE , TRIPATHI ENCLAVE SHUKHI NAHAR , SARDA ENCLAVE, HIND VIHAR, SUKHI NAHAR MUBARAKPUR	855	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	12:04	5-Jun-2020	12:55	51	0.00035	INTERRUPTION DUE TO FAULTS
45	5-Jun-2020	PARTS OF F-1,2,3,4,5 BLKS. S. PURI , GH BLK S. PURI ,RATAN VIHAR , KIRARI FURNITURE MKT. BALBEER NAGAR, H-2,3 BLKS. S. PURI	939	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	13:25	5-Jun-2020	14:55	90	0.00063	INTERRUPTION DUE TO FAULTS
46	5-Jun-2020	PARTS OF POOTHKALAN NO.1 AND POOTHKALAN NO.5 HVDS, MANDIR WALI GALI	2340	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	15:34	5-Jun-2020	16:05	30	0.00021	INTERRUPTION DUE TO FAULTS
47	5-Jun-2020	PARTS OF E-1,2,3,4,5 BLKS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY , LOHA MKT. EAST FRIENDS ENCLAVE.	404	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	08:42	5-Jun-2020	09:30	48	0.00033	INTERRUPTION DUE TO FAULTS
48	5-Jun-2020	PARTS OF BUDH VIHAR PH-2 SHYAM COLONY , BRAHM SHAKTI HOSPITAL, MTNL	2493	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	17:37	5-Jun-2020	18:05	27	0.00019	INTERRUPTION DUE TO FAULTS
49	5-Jun-2020	PARTS OF BUDH VIHAR PH-2 SHYAM COLONY , BRAHM SHAKTI HOSPITAL, MTNL	123	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	17:37	5-Jun-2020	18:35	57	0.00024	INTERRUPTION DUE TO FAULTS
50	5-Jun-2020	PART OF S/S NO -22 MANGOL PURI	2	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	15:37	5-Jun-2020	16:15	38	0.00001	INTERRUPTION DUE TO FAULTS
51	5-Jun-2020	PART OF RATAN VIHAR MONGAL PURI	9	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	13:44	5-Jun-2020	15:26	102	0.00003	SYSTEM SCHEDULE OUTAGE
52	6-Jun-2020	PART OF B-BLK. PREM NAGAR MANGOLPURI	10	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	12:22	6-Jun-2020	12:36	14	0.000004	INTERRUPTION DUE TO FAULTS
53	6-Jun-2020	PARTS OF RMU OUTDOOR ,JAL BOARD PUMP HOUSE.	721	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	07:53	6-Jun-2020	08:36	43	0.00008	PLANNED OUTAGE
54	6-Jun-2020	PARTS OF BUDH VIHAR PH-2 SHYAM COLONY , BRAHM SHAKTI HOSPITAL, MTNL	721	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	12:20	6-Jun-2020	12:59	39	0.00055	PLANNED OUTAGE
55	6-Jun-2020	PARTS OF N BLOCK, A BLOCK, O BLOCK,M BLOCK, P&QBLOCK,	1014	630 kVA	PLANNED OUTAGE	6-Jun-2020	11:47	6-Jun-2020	13:40	113	0.00031	PLANNED OUTAGE
56	6-Jun-2020	PARTS OF N BLOCK, A BLOCK, O BLOCK,M BLOCK, P&QBLOCK,	896	630 kVA	PLANNED OUTAGE	6-Jun-2020	10:14	6-Jun-2020	12:30	136	0.00193	PLANNED OUTAGE
57	6-Jun-2020	PARTS OF HINDU MUSLIM AMAN VIHAR, RAMESH ENCLAVE, TATA TOWER, BITTOO WALA, KAILASH VIHAR NO-1, RAJ BIR AMAN VIAHR	182	315 kVA	PLANNED OUTAGE	6-Jun-2020	11:05	6-Jun-2020	12:30	85	0.00005	PLANNED OUTAGE
58	6-Jun-2020	PARTS OF WORK CENTRE AND SULTANPURI	1383	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	15:35	6-Jun-2020	15:52	17	0.00006	INTERRUPTION DUE TO FAULTS
59	6-Jun-2020	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR HVDS	3192	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	05:43	6-Jun-2020	06:10	27	0.00044	INTERRUPTION DUE TO FAULTS
60	6-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	1096	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	17:20	6-Jun-2020	18:00	41	0.00007	INTERRUPTION DUE TO FAULTS
61	6-Jun-2020	PARTS OF POOTHKALAN NO.7, 12 HVDS, D-4 SEC-20	1434	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	03:59	6-Jun-2020	04:25	26	0.00017	INTERRUPTION DUE TO FAULTS
62	7-Jun-2020	PARTS OF BUDH VIHAR PH-2 SHYAM COLONY , BRAHM SHAKTI HOSPITAL, MTNL	145	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	21:06	7-Jun-2020	21:35	29	0.00007	INTERRUPTION DUE TO FAULTS
63	7-Jun-2020	PARTS OF WORK CENTRE SULTAN PURI, I & II BOTH PART OF C-3 BLOCK.	1167	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	06:23	7-Jun-2020	07:00	37	0.00014	INTERRUPTION DUE TO FAULTS
64	7-Jun-2020	PARTS OF WORK CENTRE SULTAN PURI, I & II BOTH PART OF C-3 BLOCK.	1167	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	02:29	7-Jun-2020	04:00	91	0.00033	INTERRUPTION DUE TO FAULTS
65	7-Jun-2020	PARTS OF AMAN VIHAR, KIRARI PARK, R.C PLAZA, DJB KIRARI, HARI ENCLAVE-2	517	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	11:45	7-Jun-2020	12:10	25	0.00006	INTERRUPTION DUE TO FAULTS
66	7-Jun-2020	PARTS OF RMU OUTDOOR ,JAL BOARD PUMP HOUSE.	9535	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	22:32	7-Jun-2020	23:00	28	0.00255	INTERRUPTION DUE TO FAULTS
67	7-Jun-2020	PARTS OF RMU OUTDOOR ,JAL BOARD PUMP HOUSE.	8203	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	23:09	7-Jun-2020	23:31	22	0.00102	INTERRUPTION DUE TO FAULTS
68	8-Jun-2020	PARTS OF BUDH VIHAR PH-2 SHYAM COLONY , BRAHM SHAKTI HOSPITAL, MTNL	145	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	12:33	8-Jun-2020	15:16	163	0.00018	FORCE MAJEURE DUE TO SABOTAGE
69	8-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	395	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	18:12	8-Jun-2020	18:30	18	0.00006	INTERRUPTION DUE TO FAULTS
70	8-Jun-2020	PARTS OF RAMESH ENCLAVE AND SHIV CHOWK	1813	OTHER OUTAGE	PLANNED OUTAGE	8-Jun-2020	11:16	8-Jun-2020	16:50	334	0.00176	PLANNED OUTAGE
71	8-Jun-2020	PARTS OF EWS FLATS SULTANPURI MANGOL PURI	559	OTHER OUTAGE	PLANNED OUTAGE	8-Jun-2020	13:04	8-Jun-2020	13:15	11	0.00002	PLANNED OUTAGE
72	9-Jun-2020	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL.	157	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	15:30	9-Jun-2020	16:35	65	0.00009	SYSTEM SCHEDULE OUTAGE
73	9-Jun-2020	PARTS OF PKT-14 SEC-20, PKT-11 SEC-21 RHN, D-2 SEC-20, A-4 SEC-20 RHN, MCD COLONY SEC-20 RHN	2482	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	07:06	9-Jun-2020	07:25	20	0.00009	INTERRUPTION DUE TO FAULTS
74	9-Jun-2020	PARTS OF PKT-14 SEC-20, PKT-11 SEC-21 RHN, D-2 SEC-20, A-4 SEC-20 RHN, MCD COLONY SEC-20 RHN	2482	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	07:34	9-Jun-2020	07:57	23	0.00010	INTERRUPTION DUE TO FAULTS
75	9-Jun-2020	PARTS OF KRISHNA VIHAR NO.1 & 2 HVDS, O & P BLOCK , HARSHDEV PARK	1685	OTHER OUTAGE	PLANNED OUTAGE	9-Jun-2020	10:12	9-Jun-2020	14:35	263	0.00124	PLANNED OUTAGE
76	10-Jun-2020	PART OF B-BLK. PREM NAGAR MANGOLPURI	4	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	13:43	10-Jun-2020	14:06	23	0.00003	INTERRUPTION DUE TO FAULTS
77	10-Jun-2020	PARTS OF AMAN VIHAR, KIRARI PARK, R.C PLAZA, DJB KIRARI, HARI ENCLAVE-2	517	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	11:15	10-Jun-2020	12:34	79	0.00026	INTERRUPTION DUE TO FAULTS
78	10-Jun-2020	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21	2784	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:45	10-Jun-2020	18:20	35	0.00050	INTERRUPTION DUE TO FAULTS
79	10-Jun-2020	PARTS OF POLICE QUARTER NEAR RG-23, PETROL PUMP SEC-23, V. POOTH KALAN, TATA TELE SERVICES, MANGERAM PARK, GARG GOYAL TRADING COMPANY	4361	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:03	10-Jun-2020	18:25	22	0.00027	INTERRUPTION DUE TO FAULTS
80	10-Jun-2020	PARTS OF T-1, T-2 & T-5 MANGOL PURI INDUSTRIAL AREA PH. - 1 (PARTLY)	84	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:35	10-Jun-2020	17:40	5	0.000003	INTERRUPTION DUE TO FAULTS
81	10-Jun-2020	PARTS OF T-1, T-2 & T-5 MANGOL PURI INDUSTRIAL AREA PH. - 1 (PARTLY)	62	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:35	10-Jun-2020	17:43	8	0.000004	INTERRUPTION DUE TO FAULTS
82	10-Jun-2020	PARTS OF BUDH VIHAR PH.1 NO.15, BUDH VIHAR PH.2 NO.4, 5, 6, 3	1144	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	07:22	10-Jun-2020	07:55	33	0.00013	INTERRUPTION DUE TO FAULTS
83	11-Jun-2020	PART OF B-BLK. PREM NAGAR MANGOLPURI	4	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	07:00	11-Jun-2020	07:15	15	0.000004	INTERRUPTION DUE TO FAULTS
84	11-Jun-2020	PARTS OF S. PUR MAZRA PANNI MKT, UT BLK JJC,D-1,2,3,4,5,6,7, BLKS. S. PURI , A-1,2 BLKS. JJC, B-3 BLK JJC.	316	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	13:14	11-Jun-2020	13:55	41	0.00008	INTERRUPTION DUE TO FAULTS
85	11-Jun-2020	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR HVDS	2905	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	17:01	11-Jun-2020	17:24	23	0.00023	INTERRUPTION DUE TO FAULTS
86	11-Jun-2020	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1,	3051	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	18:38	11-Jun-2020	19:15	37	0.00062	INTERRUPTION DUE TO FAULTS
87	11-Jun-2020	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1,	1079	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	19:52	11-Jun-2020	20:20	28	0.00019	INTERRUPTION DUE TO FAULTS
88	11-Jun-2020	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1,	310	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	22:21	11-Jun-2020	22:54	33	0.00009	INTERRUPTION DUE TO FAULTS
89	11-Jun-2020	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1,	310	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	22:38	11-Jun-2020	23:40	62	0.00026	INTERRUPTION DUE TO FAULTS
90	11-Jun-2020	PARTS OF E-1,2,3,4,5 BLKS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK	30	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	23:47	11-Jun-2020	23:56	9	0.00001	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
91	11-Jun-2020	PARTS OF GAURI SHANKER ENCLAVE , TRIPATHI ENCLAVE SHUKHI NAHAR , SARDA ENCLAVE, HIND VIHAR, SUKHI NAHAR MUBARAKPUR	239	OTHER OUTAGE	PLANNED OUTAGE	11-Jun-2020	12:15	11-Jun-2020	17:00	285	0.00024	PLANNED OUTAGE
92	11-Jun-2020	PART OF DHURVA ENCL. MANGOLPURI	2	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	10:59	11-Jun-2020	12:05	66	0.00004	INTERRUPTION DUE TO FAULTS
93	12-Jun-2020	PARTS OF E-1,2,3,4,5 BLKS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY , LOHA MKT. EAST FRIENDS ENCLAVE.	919	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	08:50	12-Jun-2020	10:38	108	0.00045	INTERRUPTION DUE TO FAULTS
94	12-Jun-2020	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 RHN	162	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:20	12-Jun-2020	15:06	166	0.00018	FORCE MAJEURE DUE TO SABOTAGE
95	12-Jun-2020	PARTS OF SOM BAJAR AND ROHINI SEC 20	620	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:42	12-Jun-2020	15:28	106	0.00038	SYSTEM SCHEDULE OUTAGE
96	12-Jun-2020	PARTS OF SOM BAJAR AND ROHINI SEC 20	620	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	15:40	12-Jun-2020	16:04	24	0.00009	SYSTEM SCHEDULE OUTAGE
97	12-Jun-2020	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21	2784	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	05:57	12-Jun-2020	06:35	38	0.00026	INTERRUPTION DUE TO FAULTS
98	12-Jun-2020	PARTS OF VILL. BEGAMPUR NO.1, BEGAMPUR EXTN, RAJEEV NAGAR HVDS	2905	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:26	12-Jun-2020	12:40	14	0.00020	INTERRUPTION DUE TO FAULTS
99	12-Jun-2020	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL PKT-8	3197	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	19:15	12-Jun-2020	19:35	19	0.00019	INTERRUPTION DUE TO FAULTS
100	12-Jun-2020	PART OF DHURVA ENCL. MANGOLPURI	2	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	11:26	12-Jun-2020	11:53	27	0.00002	INTERRUPTION DUE TO FAULTS
101	13-Jun-2020	PARTS OF AMAN VIHAR AND SHIV CHOWK	1723	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:21	13-Jun-2020	14:32	11	0.00010	SYSTEM SCHEDULE OUTAGE
102	13-Jun-2020	PARTS OF POOTHKALAN NO.1 AND POOTHKALAN NO.5 HVDS, MANDIR WALI GALI	428	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:11	13-Jun-2020	16:39	28	0.00007	INTERRUPTION DUE TO FAULTS
103	13-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	148	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	19:40	13-Jun-2020	20:35	54	0.00005	INTERRUPTION DUE TO FAULTS
104	13-Jun-2020	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL.	1045	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	07:39	13-Jun-2020	07:55	16	0.00011	INTERRUPTION DUE TO FAULTS
105	13-Jun-2020	PARTS OF POOTHKALAN NO.1 AND POOTHKALAN NO.5 HVDS, MANDIR WALI GALI	2345	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:45	13-Jun-2020	17:05	21	0.00047	INTERRUPTION DUE TO FAULTS
106	13-Jun-2020	PARTS OF BUDH VIHAR PH-2 SHYAM COLONY , BRAHM SHAKTI HOSPITAL, MTNL	257	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:21	13-Jun-2020	17:38	17	0.00003	INTERRUPTION DUE TO FAULTS
107	13-Jun-2020	PARTS OF BUDH VIHAR PH-2 SHYAM COLONY , BRAHM SHAKTI HOSPITAL, MTNL	2359	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:21	13-Jun-2020	17:50	29	0.00028	INTERRUPTION DUE TO FAULTS
108	14-Jun-2020	PARTS OF AMAN VIHAR, BALBIR VIHAR NO-1, P.V-3 (NALE WALA),PRATAP VIHAR-3 (NALE WALA), RAMESH ENCLAVE	924	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	11:34	14-Jun-2020	11:50	16	0.00011	INTERRUPTION DUE TO FAULTS
109	14-Jun-2020	PARTS OF GAURI SHANKER ENCLAVE , TRIPATHI ENCLAVE SHUKHI NAHAR , SARDA ENCLAVE, HIND VIHAR, SUKHI NAHAR MUBARAKPUR	971	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	12:54	14-Jun-2020	13:52	58	0.00068	INTERRUPTION DUE TO FAULTS
110	14-Jun-2020	PARTS OF AMAN VIHAR, KIRARI PARK, R.C PLAZA, DJB KIRARI, HARI ENCLAVE-2	1958	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	07:15	14-Jun-2020	07:32	17	0.00021	INTERRUPTION DUE TO FAULTS
111	14-Jun-2020	PARTS OF GAURI SHANKER ENCLAVE , TRIPATHI ENCLAVE SHUKHI NAHAR , SARDA ENCLAVE, HIND VIHAR, SUKHI NAHAR MUBARAKPUR	3454	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	12:11	14-Jun-2020	12:35	25	0.00031	INTERRUPTION DUE TO FAULTS
112	14-Jun-2020	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR	4596	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	19:03	14-Jun-2020	19:30	28	0.00050	INTERRUPTION DUE TO FAULTS
113	15-Jun-2020	PART OF B-BLK. PREM NAGAR MANGOLPURI	9	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	06:49	15-Jun-2020	07:05	16	0.00001	INTERRUPTION DUE TO FAULTS
114	15-Jun-2020	PARTS OF WORK CENTRE AND SULTANPURI	1098	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	10:30	15-Jun-2020	11:20	50	0.00014	PLANNED OUTAGE
115	15-Jun-2020	PARTS OF HINDU MUSLIM AMAN VIHAR, RAMESH ENCLAVE, TATA TOWER, BITTOO WALA, KAILASH VIHAR NO-1, RAJ BIR AMAN VIAHR	182	315 kVA	PLANNED OUTAGE	15-Jun-2020	12:07	15-Jun-2020	13:58	111	0.00006	PLANNED OUTAGE
116	15-Jun-2020	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL PKT-8	3197	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	17:20	15-Jun-2020	17:54	35	0.00034	INTERRUPTION DUE TO FAULTS
117	15-Jun-2020	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1,	676	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	08:11	15-Jun-2020	08:35	24	0.00007	INTERRUPTION DUE TO FAULTS
118	16-Jun-2020	PARTS OF AMAN VIHAR AND SHIV CHOWK	21	OTHER OUTAGE	PLANNED OUTAGE	16-Jun-2020	11:27	16-Jun-2020	14:00	153	0.00004	PLANNED OUTAGE
119	30-Jun-20	PARTS OF NITHARI, LAKHI RAM PARK, NITHARI DJB BOOSTER PUMP SUKHI NAHAR TALAB	22	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	15:38	30-Jun-20	17:17	99	0.00003	INTERRUPTION DUE TO FAULTS
120	9-Jun-2020	PARTS OF PKT-14 SEC-20, PKT-11 SEC-21 RHN, D-2 SEC-20	21	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	07:06	9-Jun-2020	07:57	51	0.00003	INTERRUPTION DUE TO FAULTS
121	16-Jun-2020	PARTS OF POOTHKALAN NO.1 AND POOTHKALAN NO.5 HVDS, MANDIR WALI GALI	208	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	22:49	16-Jun-2020	23:10	21	0.00007	INTERRUPTION DUE TO FAULTS
122	16-Jun-2020	PARTS OF F-1,2,3,4,5 BLKS. S. PURI , GH BLK S. PURI ,RATAN VIHAR , KIRARI FURNITURE MKT. BALBEER NAGAR, H-2,3 BLKS. S. PURI	162	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	00:10	16-Jun-2020	00:24	13	0.00001	INTERRUPTION DUE TO FAULTS
123	16-Jun-2020	PARTS OF POOTHKALAN NO.1 AND POOTHKALAN NO.5 HVDS, MANDIR WALI GALI	273	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	00:34	16-Jun-2020	01:30	57	0.00008	INTERRUPTION DUE TO FAULTS
124	16-Jun-2020	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL PKT-8	3197	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	10:42	16-Jun-2020	11:00	18	0.00012	INTERRUPTION DUE TO FAULTS
125	16-Jun-2020	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21	721	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	21:25	16-Jun-2020	21:56	31	0.00012	INTERRUPTION DUE TO FAULTS
126	17-Jun-2020	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21	721	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	08:29	17-Jun-2020	08:50	21	0.00009	SYSTEM SCHEDULE OUTAGE
127	17-Jun-2020	PARTS OF D BLOCK, J BLOCK, Y BLOCK,E BLOCK,	370	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	15:18	17-Jun-2020	16:48	90	0.00050	INTERRUPTION DUE TO FAULTS
128	17-Jun-2020	PARTS OF D BLOCK, J BLOCK, Y BLOCK,E BLOCK,	269	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	15:19	17-Jun-2020	16:48	89	0.00037	INTERRUPTION DUE TO FAULTS
129	17-Jun-2020	PARTS OF SOM BAJAR AND ROHINI SEC 20	50	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	23:11	18-Jun-2020	00:30	78	0.00007	SYSTEM SCHEDULE OUTAGE
130	17-Jun-2020	PARTS OF NITHARI, LAKHI RAM PARK, NITHARI DJB BOOSTER PUMP SUKHI NAHAR TALAB	1297	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	08:45	17-Jun-2020	09:17	32	0.00022	INTERRUPTION DUE TO FAULTS
131	18-Jun-2020	PARTS OF SOM BAJAR AND ROHINI SEC 20	42	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	00:52	18-Jun-2020	01:25	32	0.00004	SYSTEM SCHEDULE OUTAGE
132	18-Jun-2020	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21	190	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	15:33	18-Jun-2020	17:22	109	0.00024	INTERRUPTION DUE TO FAULTS
133	18-Jun-2020	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21	32	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:12	18-Jun-2020	14:10	118	0.00007	INTERRUPTION DUE TO FAULTS
134	18-Jun-2020	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL PKT-8	3587	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	16:52	18-Jun-2020	17:05	13	0.00015	INTERRUPTION DUE TO FAULTS
135	18-Jun-2020	PARTS OF B-BLK.INDER ENCLAVE, PREM NAGAR EXTENSION SPD, GAURAV NAGAR NO-1 SPD, PREM NAGAR EXTENSION	4258	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	09:16	18-Jun-2020	10:08	52	0.00104	INTERRUPTION DUE TO FAULTS
136	18-Jun-2020	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21	995	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	06:25	18-Jun-2020	06:40	14	0.00012	INTERRUPTION DUE TO FAULTS
137	18-Jun-2020	PARTS OF G-BLK RAJIV NAGAR, BEGUMPUR NO-2 & 3, CNG STATION SEC-22,CNG STATION SEC-21	3734	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	06:25	18-Jun-2020	07:06	40	0.00112	INTERRUPTION DUE TO FAULTS
138	18-Jun-2020	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 RHN	1358	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	14:51	18-Jun-2020	15:21	31	0.00045	INTERRUPTION DUE TO FAULTS
139	18-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	2223	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	18:45	18-Jun-2020	19:19	34	0.00046	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
140	19-Jun-2020	PART OF LAKHI RAM PARK MANGOLPURI	17	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	02:18	19-Jun-2020	02:44	26	0.00003	INTERRUPTION DUE TO FAULTS
141	19-Jun-2020	PARTS OF WORK CENTRE SULTAN PURI, I & II BOTH PART OF C-3 BLOCK.	287	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	08:22	19-Jun-2020	09:30	68	0.00023	INTERRUPTION DUE TO FAULTS
142	19-Jun-2020	PARTS OF K BLOCK, X BLOCK, K-2 BLOCK,J BLOCK, P&QBLOCK, R BLOCK, S BLOCK, L BLOCK JUGGI	775	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	16:05	19-Jun-2020	17:44	99	0.00022	INTERRUPTION DUE TO FAULTS
143	19-Jun-2020	PARTS OF SOM BAJAR AND ROHINI SEC 20	935	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	16:19	19-Jun-2020	16:55	36	0.00012	SYSTEM SCHEDULE OUTAGE
144	19-Jun-2020	PARTS OF SOM BAJAR AND ROHINI SEC 20	935	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	18:23	19-Jun-2020	20:32	128	0.00043	FORCE MAJEURE DUE TO SABOTAGE
145	1-Jun-2020	PARTS OF Q, S, BLOCK MANGOL PURI (PARTLY), MANGOL PURI INDUSTRIAL AREA PH.1	25	OTHER OUTAGE	PLANNED OUTAGE	1-Jun-2020	10:58	1-Jun-2020	13:20	142	0.00004	PLANNED OUTAGE
146	20-Jun-2020	PARTS OF AMAN VIHAR, BALBIR VIHAR NO-1, P.V-3 (NALE WALA),PRATAP VIHAR-3 (NALE WALA), RAMESH ENCLAVE	924	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	00:12	20-Jun-2020	00:40	28	0.00020	INTERRUPTION DUE TO FAULTS
147	20-Jun-2020	PART OF LAKHI RAM PARK MANGOLPURI	19	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	16:47	20-Jun-2020	17:07	20	0.00001	SYSTEM SCHEDULE OUTAGE
148	20-Jun-2020	PART OF POOTHKALAN NO.7 MANGOLPURI	15	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	05:15	20-Jun-2020	05:40	25	0.00004	INTERRUPTION DUE TO FAULTS
149	20-Jun-2020	PARTS OF MANGOL PURI INDUSTRIAL AREA PH. - 1 (PARTLY), B LOCK MIA	28	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	11:24	20-Jun-2020	13:21	117	0.00003	PLANNED OUTAGE
150	20-Jun-2020	PARTS OF POOTHKALAN NO.1 AND POOTHKALAN NO.5 HVDS, MANDIR WALI GALI	1083	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	12:30	20-Jun-2020	13:10	40	0.00016	INTERRUPTION DUE TO FAULTS
151	20-Jun-2020	PARTS OF NITHARI, LAKHI RAM PARK, NITHARI DJB BOOSTER PUMP SUKHI NAHAR TALAB	895	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	14:26	20-Jun-2020	14:30	4	0.00001	SYSTEM SCHEDULE OUTAGE
152	20-Jun-2020	PARTS OF P-1,2,3, BLKS.S. PURI & P-1 JJC. (JHANDEWALA PARK, BALMIKI PARK.	1427	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:28	20-Jun-2020	05:20	52	0.00094	INTERRUPTION DUE TO FAULTS
153	20-Jun-2020	PARTS OF P-1,2,3, BLKS.S. PURI & P-1 JJC. (JHANDEWALA PARK, BALMIKI PARK.	1427	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	06:36	20-Jun-2020	07:15	39	0.00046	INTERRUPTION DUE TO FAULTS
154	20-Jun-2020	PARTS OF P-1,2,3, BLKS.S. PURI & P-1 JJC. (JHANDEWALA PARK, BALMIKI PARK.	578	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	06:39	20-Jun-2020	07:15	36	0.00025	INTERRUPTION DUE TO FAULTS
155	24-Jun-2020	PARTS OF Q, S, BLOCK MANGOL PURI (PARTLY), MANGOL PURI INDUSTRIAL AREA PH.1	25	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	15:35	24-Jun-2020	16:00	25	0.00004	INTERRUPTION DUE TO FAULTS
156	20-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	47	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	01:02	20-Jun-2020	01:50	47	0.00013	INTERRUPTION DUE TO FAULTS
157	20-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	512	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	01:02	20-Jun-2020	02:10	67	0.00047	INTERRUPTION DUE TO FAULTS
158	20-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	847	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	01:02	20-Jun-2020	03:32	149	0.00145	FORCE MAJEURE DUE TO SABOTAGE
159	20-Jun-2020	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 RHN	680	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:48	20-Jun-2020	05:50	62	0.00086	INTERRUPTION DUE TO FAULTS
160	20-Jun-2020	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 RHN	680	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	07:50	20-Jun-2020	08:15	25	0.00024	INTERRUPTION DUE TO FAULTS
161	20-Jun-2020	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL.	1045	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:04	20-Jun-2020	08:25	22	0.00031	INTERRUPTION DUE TO FAULTS
162	20-Jun-2020	PARTS OF SOM BAJAR AND ROHINI SEC 20	2250	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:50	20-Jun-2020	09:17	28	0.00033	INTERRUPTION DUE TO FAULTS
163	20-Jun-2020	PARTS OF P-1,2,3, BLKS.S. PURI & P-1 JJC. (JHANDEWALA PARK, BALMIKI PARK.	1076	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	20:22	20-Jun-2020	20:50	28	0.00009	INTERRUPTION DUE TO FAULTS
164	20-Jun-2020	PARTS OF POOTHKALAN NO.7, 12 HVDS, D-4 SEC-20	3215	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:37	20-Jun-2020	05:15	38	0.00069	INTERRUPTION DUE TO FAULTS
165	21-Jun-2020	PARTS OF RMU OUTDOOR ,JAL BOARD PUMP HOUSE.	1087	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	01:12	21-Jun-2020	01:40	29	0.00041	INTERRUPTION DUE TO FAULTS
166	21-Jun-2020	PARTS OF E-1,2,3,4,5 BLKS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY , LOHA MKT. EAST FRIENDS ENCLAVE.	262	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	03:47	21-Jun-2020	04:09	22	0.00003	INTERRUPTION DUE TO FAULTS
167	21-Jun-2020	PARTS OF WORK CENTRE SULTAN PURI, I & II BOTH PART OF C-3 BLOCK.	2783	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	06:28	21-Jun-2020	06:38	10	0.00039	INTERRUPTION DUE TO FAULTS
168	21-Jun-2020	PARTS OF E-1,2,3,4,5 BLKS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY , LOHA MKT. EAST FRIENDS ENCLAVE.	101	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	04:06	21-Jun-2020	04:16	10	0.000003	INTERRUPTION DUE TO FAULTS
169	21-Jun-2020	PARTS OF AMAN VIHAR AND SHIV CHOWK	2365	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	10:47	21-Jun-2020	11:05	18	0.00009	INTERRUPTION DUE TO FAULTS
170	21-Jun-2020	PARTS OF P-1,2,3, BLKS.S. PURI & P-1 JJC. (JHANDEWALA PARK, BALMIKI PARK.	93	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	14:13	21-Jun-2020	15:15	62	0.00003	INTERRUPTION DUE TO FAULTS
171	22-Jun-2020	PART OF B-BLK. PREM NAGAR MANGOLPURI	4	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	14:37	22-Jun-2020	15:34	57	0.00006	INTERRUPTION DUE TO FAULTS
172	22-Jun-2020	PART OF B-BLK. PREM NAGAR MANGOLPURI	4	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	10:24	22-Jun-2020	11:21	57	0.00006	INTERRUPTION DUE TO FAULTS
173	22-Jun-2020	PART OF B-BLK. PREM NAGAR MANGOLPURI	4	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	11:04	22-Jun-2020	11:45	41	0.00005	INTERRUPTION DUE TO FAULTS
174	22-Jun-2020	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL PKT-8	3200	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	13:49	22-Jun-2020	14:01	12	0.00021	INTERRUPTION DUE TO FAULTS
175	22-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	734	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	09:08	22-Jun-2020	09:40	33	0.00014	INTERRUPTION DUE TO FAULTS
176	23-Jun-2020	PART OF EWS FLATS SULTANPURI	6	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	11:38	23-Jun-2020	11:47	9	0.000002	INTERRUPTION DUE TO FAULTS
177	23-Jun-2020	PARTS OF WORK CENTRE AND SULTANPURI	25	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	08:00	23-Jun-2020	08:35	35	0.00010	INTERRUPTION DUE TO FAULTS
178	23-Jun-2020	PARTS OF P-1,2,3, BLKS.S. PURI & P-1 JJC. (JHANDEWALA PARK, BALMIKI PARK.	1427	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	11:27	23-Jun-2020	12:26	59	0.00048	INTERRUPTION DUE TO FAULTS
179	23-Jun-2020	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR	1164	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	12:08	23-Jun-2020	12:45	37	0.00024	INTERRUPTION DUE TO FAULTS
180	23-Jun-2020	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR	331	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	12:08	23-Jun-2020	13:10	62	0.00010	INTERRUPTION DUE TO FAULTS
181	23-Jun-2020	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR	332	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	12:08	23-Jun-2020	17:00	292	0.00049	FORCE MAJEURE DUE TO SABOTAGE
182	23-Jun-2020	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR	331	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	15:52	23-Jun-2020	17:00	68	0.00011	INTERRUPTION DUE TO FAULTS
183	23-Jun-2020	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR	1164	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	16:13	23-Jun-2020	17:00	47	0.00029	INTERRUPTION DUE TO FAULTS
184	23-Jun-2020	PARTS OF WORK CENTRE AND SULTANPURI	5021	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	02:15	23-Jun-2020	02:35	21	0.00093	INTERRUPTION DUE TO FAULTS
185	23-Jun-2020	PARTS OF EWS FLATS SULTANPURI MANGOL PURI	3647	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	11:38	23-Jun-2020	12:00	22	0.00043	INTERRUPTION DUE TO FAULTS
186	23-Jun-2020	PART OF POOTHKALAN NO.1 MANGOLPURI	2	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	14:51	23-Jun-2020	15:18	27	0.00002	INTERRUPTION DUE TO FAULTS
187	23-Jun-2020	PARTS OF PRATAP VIHAR KIRARI MANGOL PURI	2291	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	00:06	23-Jun-2020	00:48	42	0.00047	INTERRUPTION DUE TO FAULTS
188	24-Jun-2020	PARTS OF AMAN VIHAR, KIRARI PARK, R.C PLAZA, DJB KIRARI, HARI ENCLAVE-2	708	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	06:46	24-Jun-2020	08:25	99	0.00055	INTERRUPTION DUE TO FAULTS
189	24-Jun-2020	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL.	1145	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	14:18	24-Jun-2020	14:26	8	0.00002	INTERRUPTION DUE TO FAULTS
190	24-Jun-2020	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1,	677	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	14:20	24-Jun-2020	14:53	33	0.00013	INTERRUPTION DUE TO FAULTS
191	24-Jun-2020	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1,	706	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	19:12	24-Jun-2020	19:45	33	0.00013	INTERRUPTION DUE TO FAULTS
192	24-Jun-2020	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR	1301	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	23:13	25-Jun-2020	00:00	47	0.00013	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
193	23-Jun-2020	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN	1056	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	18:17	23-Jun-2020	18:30	13	0.00008	INTERRUPTION DUE TO FAULTS
194	25-Jun-2020	PART OF T- BLK SULTAN PURI MANGOL PURI	8	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	11:12	25-Jun-2020	13:04	112	0.00003	INTERRUPTION DUE TO FAULTS
195	25-Jun-2020	PART OF GAURI SHANKER ENCLAVE	8	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:48	25-Jun-2020	16:43	115	0.00003	INTERRUPTION DUE TO FAULTS
196	25-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	1715	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	00:21	25-Jun-2020	00:36	15	0.00008	INTERRUPTION DUE TO FAULTS
197	25-Jun-2020	PARTS OF B-BLK.INDER ENCLAVE, PREM NAGAR EXTENSION SPD, GAURAV NAGAR NO-1 SPD, PREM NAGAR EXTENSION	4261	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:05	25-Jun-2020	14:20	15	0.00025	INTERRUPTION DUE TO FAULTS
198	25-Jun-2020	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN	2036	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	16:41	25-Jun-2020	17:24	43	0.00030	INTERRUPTION DUE TO FAULTS
199	25-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	491	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	23:21	25-Jun-2020	23:29	8	0.00003	INTERRUPTION DUE TO FAULTS
200	29-Jun-20	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN	1056	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	19:10	29-Jun-20	19:55	45	0.00031	INTERRUPTION DUE TO FAULTS
201	25-Jun-2020	PARTS OF PRATAP VIHAR KIRARI MANGOL PURI	2291	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:31	25-Jun-2020	15:11	40	0.00033	INTERRUPTION DUE TO FAULTS
202	26-Jun-2020	PARTS OF PKT-14 SEC-20, PKT-11 SEC-21 RHN, D-2 SEC-20, A-4 SEC-20 RHN, MCD COLONY SEC-20 RHN	1942	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	10:50	26-Jun-2020	11:15	25	0.00020	INTERRUPTION DUE TO FAULTS
203	26-Jun-2020	PARTS OF PKT-14 SEC-20, PKT-11 SEC-21 RHN, D-2 SEC-20, A-4 SEC-20 RHN, MCD COLONY SEC-20 RHN	537	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	10:50	26-Jun-2020	13:38	168	0.00042	FORCE MAJEURE DUE TO SABOTAGE
204	26-Jun-2020	PARTS OF PKT-14 SEC-20, PKT-11 SEC-21 RHN, D-2 SEC-20, A-4 SEC-20 RHN, MCD COLONY SEC-20 RHN	1942	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	13:05	26-Jun-2020	13:38	33	0.00039	INTERRUPTION DUE TO FAULTS
205	26-Jun-2020	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1,	706	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	15:49	26-Jun-2020	16:05	16	0.00005	INTERRUPTION DUE TO FAULTS
206	26-Jun-2020	PARTS OF PRIMARY SCHOOL, SEC-20 ROHINI, SHUBHAM PLAZA, CNG STATION SEC-21, PSS NO.-1 PKT-9 SEC-21 RHN	341	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	16:29	26-Jun-2020	16:50	21	0.00002	INTERRUPTION DUE TO FAULTS
207	26-Jun-2020	PARTS OF SULTAN PUR MAZRA VILL. , U- BLK & T- BLK M. PURI	634	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	06:11	26-Jun-2020	06:36	25	0.00008	INTERRUPTION DUE TO FAULTS
208	4-Jun-2020	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN	1041	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	21:05	4-Jun-2020	21:46	41	0.00023	INTERRUPTION DUE TO FAULTS
209	10-Jun-2020	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN	2036	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:36	10-Jun-2020	19:48	71	0.00079	INTERRUPTION DUE TO FAULTS
210	26-Jun-2020	PARTS OF BEGUMPUR NO-3, BEGAMPUR NO.-7, BEGAMPUR NO.-4, NAVIN VIHAR	4600	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	18:18	26-Jun-2020	18:35	17	0.00049	INTERRUPTION DUE TO FAULTS
211	26-Jun-2020	PARTS OF HINDU MUSLIM AMAN VIHAR, RAMESH ENCLAVE, TATA TOWER, BITTOO WALA, KAILASH VIHAR NO-1, RAJ BIR AMAN VIAHR	182	OTHER OUTAGE	PLANNED OUTAGE	26-Jun-2020	07:09	26-Jun-2020	11:44	275	0.00038	PLANNED OUTAGE
212	27-Jun-2020	PART OF PSS NO.-1 PKT-9 SEC-21 RHN	2	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	13:42	27-Jun-2020	14:16	34	0.00001	INTERRUPTION DUE TO FAULTS
213	27-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	175	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	23:50	28-Jun-2020	04:18	267	0.00089	FORCE MAJEURE DUE TO SABOTAGE
214	27-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	1503	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	18:30	27-Jun-2020	18:40	10	0.00005	INTERRUPTION DUE TO FAULTS
215	27-Jun-2020	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL.	6707	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	06:16	27-Jun-2020	06:50	34	0.00043	INTERRUPTION DUE TO FAULTS
216	27-Jun-2020	PARTS OF K1-BLOCK, MUBARAK PUR ROAD BEHIND DJB, NAG MANDIR, IJ-BLOCK, DJB KIRARI, DHURVA ENCL.	335	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	06:16	27-Jun-2020	06:50	34	0.00007	INTERRUPTION DUE TO FAULTS
217	10-Jun-2020	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN	2036	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:09	10-Jun-2020	17:45	36	0.00028	INTERRUPTION DUE TO FAULTS
218	27-Jun-2020	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1,	677	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	19:14	27-Jun-2020	19:40	27	0.00006	INTERRUPTION DUE TO FAULTS
219	27-Jun-2020	PARTS OF E-1,2,3,4,5 BLKS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY , LOHA MKT. EAST FRIENDS ENCLAVE.	3123	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	19:41	27-Jun-2020	19:50	9	0.00009	INTERRUPTION DUE TO FAULTS
220	27-Jun-2020	PARTS OF E-1,2,3,4,5 BLKS S. PURI , DSIDC SHED SHANI BAZAR ROAD, RAJ PARK , BANK OF BARODA, ZONAL OFFICE, D-1,2,3,4, BLK S. PURI PARTIALLY , LOHA MKT. EAST FRIENDS ENCLAVE.	63	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	19:41	27-Jun-2020	20:55	74	0.00016	INTERRUPTION DUE TO FAULTS
221	27-Jun-2020	PARTS OF D BLOCK, J BLOCK, Y BLOCK,E BLOCK,	827	630 kVA	PLANNED OUTAGE	27-Jun-2020	10:55	27-Jun-2020	12:50	115	0.00026	PLANNED OUTAGE
222	28-Jun-2020	PARTS OF G. D. GOENKA, PKT-17 SEC-22, PKT-12 SEC-22, RAJEEV NAGAR PH.2 NO.1 & 2	631	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	21:10	28-Jun-2020	21:35	25	0.00010	INTERRUPTION DUE TO FAULTS
223	28-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	175	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	17:47	28-Jun-2020	18:50	63	0.00032	SYSTEM SCHEDULE OUTAGE
224	28-Jun-2020	PART OF SOM BAJAR AND ROHINI SEC 20	14	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	15:00	28-Jun-2020	15:25	25	0.00001	INTERRUPTION DUE TO FAULTS
225	28-Jun-2020	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	1503	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	07:24	28-Jun-2020	08:04	40	0.00020	INTERRUPTION DUE TO FAULTS
226	12-Jun-2020	PART OF SS-7 BUDHVIHAR PH-1 MANGOLPURI	12	250 kVA	PLANNED OUTAGE	12-Jun-2020	10:54	12-Jun-2020	17:56	422	0.00012	PLANNED OUTAGE
227	28-Jun-2020	PARTS OF T-2 & T-4 MANGOL PURI INDUSTRIAL AREA PH. -1	130	OTHER OUTAGE	PLANNED OUTAGE	28-Jun-2020	11:32	28-Jun-2020	13:28	116	0.00026	PLANNED OUTAGE
228	29-Jun-20	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	175	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	14:50	29-Jun-20	16:10	80	0.00022	SYSTEM SCHEDULE OUTAGE
229	16-Jun-2020	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN	2036	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	15:52	16-Jun-2020	16:10	18	0.00023	INTERRUPTION DUE TO FAULTS
230	29-Jun-20	PARTS OF MASTER FACTORY,B-BLK. PREM NAGAR, WEST CABIN BLOCK, D BLOCK PREM NAGAR-2	33	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	13:08	29-Jun-20	14:26	78	0.00011	INTERRUPTION DUE TO FAULTS
231	29-Jun-20	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN	23	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	20:10	29-Jun-20	20:54	44	0.00001	INTERRUPTION DUE TO FAULTS
232	29-Jun-20	PARTS OF BUDH VIHAR PH-2 SHYAM COLONY , BRAHM SHAKTI HOSPITAL, MTNL	4108	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:35	29-Jun-20	17:55	20	0.00014	INTERRUPTION DUE TO FAULTS
233	29-Jun-20	PARTS OF SULTANPURI P2 BLOCK POOTHKALAN	1032	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	20:20	29-Jun-20	20:53	33	0.00023	INTERRUPTION DUE TO FAULTS
234	22-Jun-2020	PARTS OF SULTANPURI P4 BLOCK MANGOL PURI	1145	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	07:44	22-Jun-2020	08:15	31	0.00030	INTERRUPTION DUE TO FAULTS
235	22-Jun-2020	PARTS OF SULTANPURI P4 BLOCK MANGOL PURI	356	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	16:05	22-Jun-2020	16:40	35	0.00008	INTERRUPTION DUE TO FAULTS
236	8-Jun-2020	PARTS OF SULTANPURI P4 BLOCK MANGOL PURI	105	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	10:55	8-Jun-2020	12:00	65	0.00009	INTERRUPTION DUE TO FAULTS
237	16-Jun-2020	PARTS OF SULTANPURI P4 BLOCK MANGOL PURI	465	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	15:26	16-Jun-2020	16:25	59	0.00041	INTERRUPTION DUE TO FAULTS
238	29-Jun-20	PARTS OF SS-7 BUDHVIHAR PH-1, BUDH VIHAR PH-1,	677	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	03:01	29-Jun-20	03:26	26	0.00011	INTERRUPTION DUE TO FAULTS
239	18-Jun-2020	PARTS OF SULTANPURI P4 BLOCK MANGOL PURI	174	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	03:58	18-Jun-2020	04:20	21	0.00004	INTERRUPTION DUE TO FAULTS
240	29-Jun-20	PARTS OF BEGUM PUR POLICE STN SEC 22 RHN, CNG STATION SEC-22 (OPP. PKT-11A), D.T.C BUS DEPOT, WOMEN & CHILD WELFARE , MAHARAJA AGARSEN INSTITUTE, DDA STREET LIGHT, MCD SCHOOL PKT-8	2864	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:39	29-Jun-20	18:20	41	0.00040	INTERRUPTION DUE TO FAULTS
241	29-Jun-20	PARTS OF SANJAY GANDHI HOSPITAL MANGOL PURI	49	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	10:57	29-Jun-20	13:06	129	0.00004	PLANNED OUTAGE
242	30-Jun-20	PARTS OF SOM BAJAR AND ROHINI SEC 20	165	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	11:20	30-Jun-20	13:48	148	0.00021	FORCE MAJEURE DUE TO SABOTAGE
243	30-Jun-20	PARTS OF SOM BAJAR AND ROHINI SEC 20	635	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	12:09	30-Jun-20	12:45	36	0.00045	INTERRUPTION DUE TO FAULTS
244	30-Jun-20	PARTS OF SOM BAJAR AND ROHINI SEC 20	31	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	17:53	30-Jun-20	19:25	91	0.00005	INTERRUPTION DUE TO FAULTS
245	30-Jun-20	PARTS OF T-4 MANGOL PURI INDUSTRIAL AREA PH.-1	1468	OTHER OUTAGE	PLANNED OUTAGE	30-Jun-20	10:42	30-Jun-20	12:00	78	0.00030	PLANNED OUTAGE
246	30-Jun-20	PARTS OF C BLOCK, DDA SLUM , G BLOCK H BLOCK, Y BLOCK	37	OTHER OUTAGE	PLANNED OUTAGE	30-Jun-20	10:24	30-Jun-20	12:02	98	0.00003	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
247	30-Jun-20	PARTS OF GAURI SHANKER ENCLAVE , TRIPATHI ENCLAVE SHUKHI NAHAR , SARDA ENCLAVE, HIND VIHAR, SUKHI NAHAR MUBARAKPUR	7856	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	08:24	30-Jun-20	08:32	8	0.00023	INTERRUPTION DUE TO FAULTS
248	30-Jun-20	PARTS OF GAURI SHANKER ENCLAVE , TRIPATHI ENCLAVE SHUKHI NAHAR , SARDA ENCLAVE, HIND VIHAR, SUKHI NAHAR MUBARAKPUR	2623	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	08:34	30-Jun-20	09:25	51	0.00050	INTERRUPTION DUE TO FAULTS
					MODEL TOWN							
1	1-Jun-2020	PARTS OF AIR STAFF QUARTER,DHAKA KIOSK,PRIMARI SCHOOL,NARULA,RBTB HOSPITAL DT-2,TAGOR PARK EX.	600	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	23:54	2-Jun-2020	00:21	26	0.00011	INTERRUPTION DUE TO FAULTS
2	1-Jun-2020	PARTS OF AIR STAFF QUARTER,DHAKA KIOSK,PRIMARI SCHOOL,NARULA,RBTB HOSPITAL DT-2,TAGOR PARK EX.	1437	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	23:54	2-Jun-2020	00:21	26	0.00033	INTERRUPTION DUE TO FAULTS
3	1-Jun-2020	PARTS OF SHIV MANDIR, SEWAGE PUMP, GALI NO. 10 , GALI NO. 11 , GALI NO 12 , GALI NO. 13 MAJLIS PARK, ARYA SAMAJ ROAD , DAIRY ROAD , SIWAJI ROAD , RANA PARTAP ROAD , SUSHEEL ROAD , LORD KRISHNA ROAD ADARSH NAGAR , POLICE STORE , ROAD NO. 51, CHAUDHARY PETROL PUMP.	898	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	16:59	1-Jun-2020	17:35	36	0.00010	INTERRUPTION DUE TO FAULTS
4	1-Jun-2020	PARTS OF SHIV MANDIR, SEWAGE PUMP, GALI NO. 10 , GALI NO. 11 , GALI NO 12 , GALI NO. 13 MAJLIS PARK, ARYA SAMAJ ROAD , DAIRY ROAD , SIWAJI ROAD , RANA PARTAP ROAD , SUSHEEL ROAD , LORD KRISHNA ROAD ADARSH NAGAR , POLICE STORE , ROAD NO. 51, CHAUDHARY PETROL PUMP.	1368	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	16:59	1-Jun-2020	17:50	51	0.00025	INTERRUPTION DUE TO FAULTS
5	1-Jun-2020	PARTS OF AIR STAFF QUARTER,DHAKA KIOSK,PRIMARI SCHOOL,NARULA,RBTB HOSPITAL DT-2,TAGOR PARK EX.	2037	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	22:39	1-Jun-2020	23:05	25	0.00066	INTERRUPTION DUE TO FAULTS
6	2-Jun-2020	PARTS OF BUDH MANDIR AZADPUR, TRANSPORT CENTRE, BHAROLLA VILLAGE, DARGAH WALA, ADARSH NAGAR POLICE STATION	374	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	14:50	2-Jun-2020	15:04	14	0.00006	INTERRUPTION DUE TO FAULTS
7	2-Jun-2020	PARTS OF BUDH MANDIR AZADPUR, TRANSPORT CENTRE, BHAROLLA VILLAGE, DARGAH WALA, ADARSH NAGAR POLICE STATION	4122	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	15:04	2-Jun-2020	15:13	8	0.00010	SYSTEM SCHEDULE OUTAGE
8	3-Jun-2020	PART OF A-BLOCK MAHENDRU ENCLAVE GUJRAWALAN TOWN	3	OTHER OUTAGE	PLANNED OUTAGE	3-Jun-2020	11:12	3-Jun-2020	13:38	146	0.00004	PLANNED OUTAGE
9	3-Jun-2020	PARTS OF A - BLOCK INDUSTRIAL AREA, GTK, A-BLOCK MAHENDRU ENCLAVE(RESIDENTIAL)	152	OTHER OUTAGE	PLANNED OUTAGE	3-Jun-2020	11:11	3-Jun-2020	13:37	146	0.00008	PLANNED OUTAGE
10	4-Jun-2020	PARTS OF DILKUSH BAGH INDUSTRIAL AREA, PART OF A AREAL AREA GTK	52	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	06:57	4-Jun-2020	08:37	99	0.00008	PLANNED OUTAGE
11	4-Jun-2020	PARTS OF 336 SFS FLAT NO-2,336 SFS FLAT NO-1,336 SFS FLAT NO-3 TO MUKHERJEE NGE-2	1660	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	06:49	4-Jun-2020	07:20	32	0.00011	INTERRUPTION DUE TO FAULTS
12	5-Jun-2020	PARTS OF DMRC STAFF FLAT MODEL TOWN	1452	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	06:20	5-Jun-2020	07:40	79	0.00033	INTERRUPTION DUE TO FAULTS
13	5-Jun-2020	PARTS OF DMRC STAFF FLAT MODEL TOWN	402	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	06:20	5-Jun-2020	07:45	84	0.00028	INTERRUPTION DUE TO FAULTS
14	5-Jun-2020	PART OF DMRC STAFF FLAT ADARSH NAGAR	9	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	06:20	5-Jun-2020	07:50	89	0.00005	INTERRUPTION DUE TO FAULTS
15	6-Jun-2020	PARTS OF SHIV MANDIR, SEWAGE PUMP, GALI NO. 10 , GALI NO. 11 , GALI NO 12 , GALI NO. 13 MAJLIS PARK, ARYA SAMAJ ROAD , DAIRY ROAD , SIWAJI ROAD , RANA PARTAP ROAD , SUSHEEL ROAD , LORD KRISHNA ROAD ADARSH NAGAR , POLICE STORE , ROAD NO. 51, CHAUDHARY PETROL PUMP.	2364	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	18:14	6-Jun-2020	18:58	44	0.00049	INTERRUPTION DUE TO FAULTS
16	6-Jun-2020	PARTS OF 336 SFS FLAT NO-2,336 SFS FLAT NO-1,336 SFS FLAT NO-3 TO MUKHERJEE NGE-2	1387	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	00:00	6-Jun-2020	01:20	79	0.00029	INTERRUPTION DUE TO FAULTS
17	7-Jun-2020	PARTS OF SHIV MANDIR, SEWAGE PUMP, GALI NO. 10 , GALI NO. 11 , GALI NO 12 , GALI NO. 13 MAJLIS PARK, ARYA SAMAJ ROAD , DAIRY ROAD , SIWAJI ROAD , RANA PARTAP ROAD , SUSHEEL ROAD , LORD KRISHNA ROAD ADARSH NAGAR , POLICE STORE , ROAD NO. 51, CHAUDHARY PETROL PUMP.	1204	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	06:17	7-Jun-2020	07:00	43	0.00014	INTERRUPTION DUE TO FAULTS
18	7-Jun-2020	PART OF SHIV MANDIR KEWAL PARK ADARSH NAGAR	2	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	06:17	7-Jun-2020	08:30	133	0.00004	FORCE MAJEURE DUE TO SABOTAGE
19	7-Jun-2020	PARTS OF FCI GODOWN, PART OF B - BLOCK INDUSTRIAL AREA, SANGAM PARK, PART OF R. P. BAGH	39	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	15:27	7-Jun-2020	16:20	53	0.00004	INTERRUPTION DUE TO FAULTS
20	7-Jun-2020	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER	490	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	19:39	7-Jun-2020	20:15	36	0.00015	INTERRUPTION DUE TO FAULTS
21	7-Jun-2020	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER	43	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	19:39	7-Jun-2020	20:20	41	0.00006	INTERRUPTION DUE TO FAULTS
22	8-Jun-2020	PARTS OF 336 SFS FLAT NO-2,336 SFS FLAT NO-1,336 SFS FLAT NO-3 TO MUKHERJEE NGE-2	1387	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	19:40	8-Jun-2020	19:55	15	0.00004	INTERRUPTION DUE TO FAULTS
23	10-Jun-2020	PARTS OF FCI GODOWN, PART OF B - BLOCK INDUSTRIAL AREA, SANGAM PARK, PART OF R. P. BAGH	39	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	10:38	10-Jun-2020	16:56	378	0.00011	PLANNED OUTAGE
24	11-Jun-2020	PARTS OF B BLK SHAKTI NAGAR	57	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	10:28	11-Jun-2020	11:05	37	0.00012	INTERRUPTION DUE TO FAULTS
25	11-Jun-2020	PART OF SBI COLONY GUJRAWALAN TOWN	2	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	09:34	11-Jun-2020	10:00	26	0.00001	INTERRUPTION DUE TO FAULTS
26	12-Jun-2020	PARTS OF KEWAL PARK, A,B & C-BLOCK MAJLISH PARK, TIMBER MARKET, SOME PART OF KEWAL PARK EXTN.,GOPAL NAGAR, SHANTI MARG KEWAL PARK	479	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	16:14	12-Jun-2020	17:09	55	0.00023	INTERRUPTION DUE TO FAULTS
27	12-Jun-2020	PARTS OF POLICE COLONY MODEL TOWN	1527	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:03	12-Jun-2020	12:25	22	0.00047	INTERRUPTION DUE TO FAULTS
28	12-Jun-2020	PARTS OF GALI NO-3 MAJLIS PARK ADARSH NAGAR MODEL TOWN	375	990 kVA	PLANNED OUTAGE	12-Jun-2020	11:21	12-Jun-2020	14:57	216	0.00018	PLANNED OUTAGE
29	12-Jun-2020	PARTS OF MUKERJEE NAGAR, INDRA VIKAS COLONY, PART OF NIRANKARI COLONY. MUNSI RAM COLONY ,NIRANKARI MANDAL	399	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	11:25	12-Jun-2020	12:20	55	0.00006	PLANNED OUTAGE
30	13-Jun-2020	PARTS OF OLD AZADPUR VILLAGE & DDA MKT GUJRAWALAN TOWN	703	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	23:11	13-Jun-2020	23:26	15	0.00004	INTERRUPTION DUE TO FAULTS
31	13-Jun-2020	PART OF SHIV MANDIR KEWAL PARK ADARSH NAGAR	14	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	11:27	13-Jun-2020	15:35	248	0.00007	PLANNED OUTAGE
32	15-Jun-2020	PARTS OF A - BLOCK. GUJRAWALA, B - BLOCK GUJRAWALA, LSC GUJRAWALA B - BLOCK.	118	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	12:27	15-Jun-2020	13:10	43	0.00010	INTERRUPTION DUE TO FAULTS
33	15-Jun-2020	PARTS OF A - BLOCK. GUJRAWALA, B - BLOCK GUJRAWALA, LSC GUJRAWALA B - BLOCK.	572	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	12:30	15-Jun-2020	12:38	8	0.00002	INTERRUPTION DUE TO FAULTS
34	16-Jun-2020	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER	1901	OTHER OUTAGE	PLANNED OUTAGE	16-Jun-2020	08:20	16-Jun-2020	10:00	100	0.00053	PLANNED OUTAGE
35	16-Jun-2020	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER	43	OTHER OUTAGE	PLANNED OUTAGE	16-Jun-2020	09:00	16-Jun-2020	09:53	53	0.00001	PLANNED OUTAGE
36	17-Jun-2020	PARTS OF FCI GODOWN, PART OF B - BLOCK INDUSTRIAL AREA, SANGAM PARK, PART OF R. P. BAGH	39	OTHER OUTAGE	PLANNED OUTAGE	17-Jun-2020	10:21	17-Jun-2020	16:30	369	0.0001	PLANNED OUTAGE
37	17-Jun-2020	PARTS OF OLD AZADPUR VILLAGE & DDA MKT GUJRAWALAN TOWN	458	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	01:32	17-Jun-2020	01:54	22	0.00007	INTERRUPTION DUE TO FAULTS
38	17-Jun-2020	PARTS OF DHAKA STORM WATER HTC,POLICE CHOWKI YOGRAJ,DHEERPUR-1,2,3,4,5, STREET LIGHT DHEERPUR,BHARAT BATTERY,DHEERPUR DDA PARK,PRADHAN MARKET,TIKONA PARK,AVTAR PARK	1333	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	20:16	17-Jun-2020	20:37	21	0.00008	INTERRUPTION DUE TO FAULTS
39	18-Jun-2020	PART OF SHIV MANDIR KEWAL PARK ADARSH NAGAR	7	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:11	18-Jun-2020	14:58	167	0.00009	FORCE MAJEURE DUE TO SABOTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
40	18-Jun-2020	PARTS OF SHIV MANDIR, SEWAGE PUMP, GALI NO. 10 , GALI NO. 11 , GALI NO 12 , GALI NO. 13 MAJLIS PARK, ARYA SAMAJ ROAD , DAIRY ROAD , SIWAJI ROAD , RANA PARTAP ROAD , SUSHEEL ROAD , LORD KRISHNA ROAD ADARSH NAGAR , POLICE STORE , ROAD NO. 51, CHAUDHARY PETROL PUMP.	2369	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	05:52	18-Jun-2020	06:50	58	0.00042	INTERRUPTION DUE TO FAULTS
41	19-Jun-2020	PARTS OF 336 SFS FLAT NO-2,336 SFS FLAT NO-1,336 SFS FLAT NO-3 TO MUKHERJEE NGE-2	1387	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	16:50	19-Jun-2020	17:45	55	0.00063	INTERRUPTION DUE TO FAULTS
42	19-Jun-2020	PARTS OF SHIV MANDIR, SEWAGE PUMP, GALI NO. 10 , GALI NO. 11 , GALI NO 12 , GALI NO. 13 MAJLIS PARK, ARYA SAMAJ ROAD , DAIRY ROAD , SIWAJI ROAD , RANA PARTAP ROAD , SUSHEEL ROAD , LORD KRISHNA ROAD ADARSH NAGAR , POLICE STORE , ROAD NO. 51, CHAUDHARY PETROL PUMP.	371	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	02:19	19-Jun-2020	03:00	41	0.00014	INTERRUPTION DUE TO FAULTS
43	19-Jun-2020	PARTS OF A - BLOCK INDUSTRIAL AREA, GTK, A-BLOCK MAHENDRU ENCLAVE(RESIDENTIAL)	615	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	21:01	19-Jun-2020	21:13	13	0.00014	INTERRUPTION DUE TO FAULTS
44	19-Jun-2020	PARTS OF A - BLOCK INDUSTRIAL AREA, GTK, A-BLOCK MAHENDRU ENCLAVE(RESIDENTIAL)	306	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	21:01	19-Jun-2020	21:30	29	0.00024	INTERRUPTION DUE TO FAULTS
45	19-Jun-2020	PARTS OF C BLOCK MODEL TOWN, COMMERCIAL COMPLEX, SURAJ NAGAR, RAMESHWER NAGAR, KEWAL PARK, GOPAL PARK,MCD JHEEL MODEL TOWN	572	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	20:41	19-Jun-2020	21:10	29	0.00008	INTERRUPTION DUE TO FAULTS
46	19-Jun-2020	PARTS OF C BLOCK MODEL TOWN, COMMERCIAL COMPLEX, SURAJ NAGAR, RAMESHWER NAGAR, KEWAL PARK, GOPAL PARK,MCD JHEEL MODEL TOWN	736	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	20:41	19-Jun-2020	21:40	59	0.00025	INTERRUPTION DUE TO FAULTS
47	19-Jun-2020	PARTS OF C BLOCK MODEL TOWN, COMMERCIAL COMPLEX, SURAJ NAGAR, RAMESHWER NAGAR, KEWAL PARK, GOPAL PARK,MCD JHEEL MODEL TOWN	426	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	20:41	19-Jun-2020	21:45	64	0.00018	INTERRUPTION DUE TO FAULTS
48	19-Jun-2020	PARTS OF C BLOCK MODEL TOWN, COMMERCIAL COMPLEX, SURAJ NAGAR, RAMESHWER NAGAR, KEWAL PARK, GOPAL PARK,MCD JHEEL MODEL TOWN	442	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	20:41	19-Jun-2020	21:55	74	0.00016	INTERRUPTION DUE TO FAULTS
49	19-Jun-2020	PARTS OF C BLOCK MODEL TOWN, COMMERCIAL COMPLEX, SURAJ NAGAR, RAMESHWER NAGAR, KEWAL PARK, GOPAL PARK,MCD JHEEL MODEL TOWN	539	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	20:41	20-Jun-2020	04:00	439	0.00122	FORCE MAJEURE DUE TO SABOTAGE
50	20-Jun-2020	PARTS OF DHAKA STORM WATER HTC,POLICE CHOWKI YOGRAJ,DHEERPUR-1,2,3,4,5, STREET LIGHT DHEERPUR,BHARAT BATTERY,DHEERPUR DDA PARK,PRADHAN MARKET,TIKONA PARK,AVTAR PARK	1345	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	06:09	20-Jun-2020	07:00	51	0.00021	INTERRUPTION DUE TO FAULTS
51	20-Jun-2020	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER	533	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	09:37	20-Jun-2020	10:20	42	0.00014	INTERRUPTION DUE TO FAULTS
52	21-Jun-2020	PART OF G-1 G.T.K GUJRAWALAN TOWN	4	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	07:34	21-Jun-2020	08:05	31	0.00002	SYSTEM SCHEDULE OUTAGE
53	21-Jun-2020	PARTS OF G - I, G - II INDUSTRIAL AREA, GTK, PART OF A BLOCK INDUSTRIAL AREA GTK, LAL BAGH J.J. CLUSTER	533	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	17:12	21-Jun-2020	18:20	69	0.00010	INTERRUPTION DUE TO FAULTS
54	21-Jun-2020	PARTS OF TO CORONATION PILLAR -1,CORONATION PILLAR -2,SAMAGAM GROUND	22	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	07:55	21-Jun-2020	08:25	30	0.00004	INTERRUPTION DUE TO FAULTS
55	21-Jun-2020	PARTS OF TO CORONATION PILLAR -1,CORONATION PILLAR -2,SAMAGAM GROUND	2219	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	07:55	21-Jun-2020	08:45	50	0.00048	INTERRUPTION DUE TO FAULTS
56	22-Jun-2020	PARTS OF MAHENDRU ENCLAVE, C, D BLOCK GUJRAWALA TOWN. .	1054	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	15:28	22-Jun-2020	16:10	42	0.00012	INTERRUPTION DUE TO FAULTS
57	24-Jun-2020	PARTS OF MAHENDRU ENCLAVE, C, D BLOCK GUJRAWALA TOWN. .	212	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	14:39	24-Jun-2020	15:27	48	0.00016	INTERRUPTION DUE TO FAULTS
58	24-Jun-2020	PARTS OF TO CORONATION PILLAR -1,CORONATION PILLAR -2,SAMAGAM GROUND	2099	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	17:20	24-Jun-2020	17:31	11	0.00014	INTERRUPTION DUE TO FAULTS
59	24-Jun-2020	PARTS OF TO CORONATION PILLAR -1,CORONATION PILLAR -2,SAMAGAM GROUND	131	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	17:20	24-Jun-2020	18:10	50	0.00021	INTERRUPTION DUE TO FAULTS
60	29-Jun-20	PART OF RADIO COLONY NO-6 MUKHERJEE NAGAR	2	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:00	29-Jun-20	18:45	45	0.00001	INTERRUPTION DUE TO FAULTS
61	24-Jun-2020	PART OF RADIO COLONY NO-6 MUKHERJEE NAGAR	9	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	17:20	24-Jun-2020	20:00	160	0.00009	FORCE MAJEURE DUE TO SABOTAGE
62	26-Jun-2020	PART OF RAMESHWAR NAGAR MODEL TOWN	1	OTHER OUTAGE	PLANNED OUTAGE	26-Jun-2020	11:28	26-Jun-2020	15:51	263	0.00007	PLANNED OUTAGE
63	26-Jun-2020	PARTS OF SHIV MANDIR, SEWAGE PUMP, GALI NO. 10 , GALI NO. 11 , GALI NO 12 , GALI NO. 13 MAJLIS PARK, ARYA SAMAJ ROAD , DAIRY ROAD , SIWAJI ROAD , RANA PARTAP ROAD , SUSHEEL ROAD , LORD KRISHNA ROAD ADARSH NAGAR , POLICE STORE , ROAD NO. 51, CHAUDHARY PETROL PUMP.	2279	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	21:46	26-Jun-2020	22:16	30	0.00017	INTERRUPTION DUE TO FAULTS
64	26-Jun-2020	PARTS OF OLD AZADPUR VILLAGE & DDA MKT GUJRAWALAN TOWN	624	630 kVA	PLANNED OUTAGE	26-Jun-2020	11:06	26-Jun-2020	14:53	227	0.00025	PLANNED OUTAGE
65	26-Jun-2020	PARTS OF OLD AZADPUR VILLAGE & DDA MKT GUJRAWALAN TOWN	899	990 kVA	PLANNED OUTAGE	26-Jun-2020	11:04	26-Jun-2020	15:40	276	0.00069	PLANNED OUTAGE
66	27-Jun-2020	PARTS OF ARYABHATT.POLYTECHNIC, PART OF B - BLOCK INDUSTRIAL AREA GTK	671	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	09:16	27-Jun-2020	09:51	34	0.00038	INTERRUPTION DUE TO FAULTS
67	27-Jun-2020	PARTS OF OLD & NEW TAGORE PARK, MALIKPUR VILLAGE, WEST PARMANAD COLONY.	718	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	16:05	27-Jun-2020	16:30	25	0.00025	INTERRUPTION DUE TO FAULTS
68	27-Jun-2020	PARTS OF B BLOCK GUJRAWALAN TOWN	2757	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	18:35	27-Jun-2020	19:10	35	0.00039	INTERRUPTION DUE TO FAULTS
69	27-Jun-2020	PARTS OF SHIV MANDIR, SEWAGE PUMP, GALI NO. 10 , GALI NO. 11 , GALI NO 12 , GALI NO. 13 MAJLIS PARK, ARYA SAMAJ ROAD , DAIRY ROAD , SIWAJI ROAD , RANA PARTAP ROAD , SUSHEEL ROAD , LORD KRISHNA ROAD ADARSH NAGAR , POLICE STORE , ROAD NO. 51, CHAUDHARY PETROL PUMP.	263	630 kVA	PLANNED OUTAGE	27-Jun-2020	11:32	27-Jun-2020	13:02	90	0.00005	PLANNED OUTAGE
70	27-Jun-2020	PARTS OF SHIV MANDIR, SEWAGE PUMP, GALI NO. 10 , GALI NO. 11 , GALI NO 12 , GALI NO. 13 MAJLIS PARK, ARYA SAMAJ ROAD , DAIRY ROAD , SIWAJI ROAD , RANA PARTAP ROAD , SUSHEEL ROAD , LORD KRISHNA ROAD ADARSH NAGAR , POLICE STORE , ROAD NO. 51, CHAUDHARY PETROL PUMP.	371	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	12:09	27-Jun-2020	15:24	195	0.00016	PLANNED OUTAGE
71	28-Jun-2020	PART OF MAJLISH PARK ADARSH NAGAR	20	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	05:54	28-Jun-2020	07:00	66	0.00004	INTERRUPTION DUE TO FAULTS
72	28-Jun-2020	PARTS OF SHIV MANDIR, SEWAGE PUMP, GALI NO. 10 , GALI NO. 11 , GALI NO 12 , GALI NO. 13 MAJLIS PARK, ARYA SAMAJ ROAD , DAIRY ROAD , SIWAJI ROAD , RANA PARTAP ROAD , SUSHEEL ROAD , LORD KRISHNA ROAD ADARSH NAGAR , POLICE STORE , ROAD NO. 51, CHAUDHARY PETROL PUMP.	2279	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	01:42	28-Jun-2020	02:38	57	0.00268	INTERRUPTION DUE TO FAULTS
73	28-Jun-2020	PARTS OF DILKUSH BAGH INDUSTRIAL AREA, PART OF A AREAL AREA GTK	22	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	10:43	28-Jun-2020	11:26	43	0.00047	INTERRUPTION DUE TO FAULTS
74	29-Jun-20	PARTS OF TO CORONATION PILLAR S/S-1,CORONATION PILLAR S/S-2,SAMAGAM GROUND	123	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	00:47	29-Jun-20	01:25	38	0.00016	INTERRUPTION DUE TO FAULTS
75	29-Jun-20	PARTS OF ADARSH NAGAR,C-BLOCK MAJLISH PARK,RAJAN BABU ROAD , PART OF ADARSH NAGAR EXTN ,	2170	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	04:14	29-Jun-20	04:50	36	0.00035	INTERRUPTION DUE TO FAULTS
76	29-Jun-20	PARTS OF ARYABHATT.POLYTECHNIC, PART OF B - BLOCK INDUSTRIAL AREA GTK	671	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:37	29-Jun-20	18:44	66	0.00138	INTERRUPTION DUE TO FAULTS
77	29-Jun-20	PARTS OF TO CORONATION PILLAR S/S-1,CORONATION PILLAR S/S-2,SAMAGAM GROUND	121	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:00	29-Jun-20	18:45	45	0.00004	INTERRUPTION DUE TO FAULTS
					MOTI NAGAR							
1	1-Jun-2020	PARTS OF METALLIC IMPRESSONS, A-58 ASITIC ELECTRICALS, A-46, APEX SHOES	73	OTHER OUTAGE	PLANNED OUTAGE	1-Jun-2020	06:45	1-Jun-2020	11:10	265	0.00015	PLANNED OUTAGE
2	12-Jun-2020	PART OF A-58 ASITIC ELECTRICALS MOTI NAGAR	2	100 kVA	UNPLANNED OUTAGE	12-Jun-2020	07:49	12-Jun-2020	08:15	26	0.00001	SYSTEM SCHEDULE OUTAGE
3	1-Jun-2020	PARTS OF GOPINATH BAZAR, SADAR BAZAR, PRAHLADPUR VILLAGE, SURVEY OF INDIA.	140	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	21:31	1-Jun-2020	22:35	64	0.00021	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
4	1-Jun-2020	PARTS OF GOPINATH BAZAR, SADAR BAZAR, PRAHLADPUR VILLAGE, SURVEY OF INDIA.	127	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	07:19	1-Jun-2020	08:00	41	0.00003	INTERRUPTION DUE TO FAULTS
5	1-Jun-2020	PARTS OF BARAR SQUARE RED LIGHT, DJB BARAR SQUARE	196	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	02:56	1-Jun-2020	03:15	20	0.00003	INTERRUPTION DUE TO FAULTS
6	1-Jun-2020	PARTS OF BARAR SQUARE RED LIGHT, DJB BARAR SQUARE	1364	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	02:56	1-Jun-2020	03:40	44	0.00032	INTERRUPTION DUE TO FAULTS
7	1-Jun-2020	PARTS OF WHS NO. 1, B-1 BLOCK WHS, A BLOCK WHS, A-1, A-2 WHS & JAWAR CAMP JJ CLUSTER	719	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	09:15	1-Jun-2020	10:01	47	0.00013	INTERRUPTION DUE TO FAULTS
8	1-Jun-2020	PARTS OF WHS NO. 1, B-1 BLOCK WHS, A BLOCK WHS, A-1, A-2 WHS & JAWAR CAMP JJ CLUSTER	1459	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	09:15	1-Jun-2020	10:14	59	0.00034	INTERRUPTION DUE TO FAULTS
9	16-Jun-2020	PART OF A-58 ASITIC ELECTRICALS MOTI NAGAR	2	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	14:22	16-Jun-2020	16:00	98	0.00003	INTERRUPTION DUE TO FAULTS
10	1-Jun-2020	PARTS OF B, C BLOCK NARAINA INDUSTRIAL AREA PH. - 1	191	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	17:19	1-Jun-2020	17:45	26	0.00003	INTERRUPTION DUE TO FAULTS
11	6-Jun-2020	PART OF B BLOCK NARAINA VIHAR MOTI NAGAR	11	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	10:46	6-Jun-2020	17:07	381	0.00011	PLANNED OUTAGE
12	2-Jun-2020	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK, TYAGI MARKET BASAI DARAPUR, SOME PORTION OF BASAI DARAPUR	1083	OTHER OUTAGE	PLANNED OUTAGE	2-Jun-2020	12:54	2-Jun-2020	15:20	146	0.00041	PLANNED OUTAGE
13	2-Jun-2020	PARTS OF HARIZAN BASTI LAKKAD MANDI MOTINAGAR	1867	OTHER OUTAGE	PLANNED OUTAGE	2-Jun-2020	11:01	2-Jun-2020	13:50	169	0.00085	PLANNED OUTAGE
14	2-Jun-2020	PARTS OF A & B BLOCK LOHA MANDI PH. - 2, Y-BLK, A-15 PH-1, COMMUNITY CENTER.	101	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	14:42	2-Jun-2020	15:53	71	0.00016	INTERRUPTION DUE TO FAULTS
15	2-Jun-2020	PARTS OF BARAR SQUARE RED LIGHT, DJB BARAR SQUARE	196	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	03:12	2-Jun-2020	03:40	28	0.00004	INTERRUPTION DUE TO FAULTS
16	2-Jun-2020	PARTS OF BARAR SQUARE RED LIGHT, DJB BARAR SQUARE	1364	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	03:12	2-Jun-2020	04:45	92	0.00026	INTERRUPTION DUE TO FAULTS
17	2-Jun-2020	PARTS OF A BLOCK NARAINA INDUSTRIAL AREA PH. - 1	50	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	04:30	2-Jun-2020	04:40	9	0.00003	INTERRUPTION DUE TO FAULTS
18	2-Jun-2020	PARTS OF 62,63, RAMA HVDS ROAD BISLERI HTC	553	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:14	2-Jun-2020	06:40	26	0.00009	INTERRUPTION DUE TO FAULTS
19	2-Jun-2020	PARTS OF MAIN INDERPURI (WZ, RA , A , EA-BLK, C, B, EC-BLK),PARTS OF IARI PUSA,	433	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	08:41	2-Jun-2020	10:40	118	0.00033	INTERRUPTION DUE TO FAULTS
20	11-Jun-2020	PARTS OF 26, 25, 15 N G ROAD & ZAKHIRA MOTINAGAR	1113	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	00:35	11-Jun-2020	01:25	50	0.00111	INTERRUPTION DUE TO FAULTS
21	3-Jun-2020	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK	1812	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	13:50	3-Jun-2020	14:11	21	0.00017	INTERRUPTION DUE TO FAULTS
22	24-Jun-2020	PARTS OF 26, 25, 15 N G ROAD & ZAKHIRA	37	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	11:09	24-Jun-2020	13:14	125	0.00003	PLANNED OUTAGE
23	29-Jun-20	PARTS OF 26, 25, 15 N G ROAD & ZAKHIRA MOTINAGAR	37	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:41	29-Jun-20	18:30	49	0.00003	INTERRUPTION DUE TO FAULTS
24	3-Jun-2020	PARTS OF SHARDA PURI, FA BLOCK M S GARDEN, DOUBLE STORY RAMESH NAGAR, BANDER WALI KUI, S D MANDIE, 34 TO 37 BLOCK	1531	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	08:18	3-Jun-2020	09:00	42	0.00030	INTERRUPTION DUE TO FAULTS
25	29-Jun-20	PARTS OF 26, 25, 15 N G ROAD & ZAKHIRA MOTINAGAR	1076	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:41	29-Jun-20	18:48	67	0.00019	INTERRUPTION DUE TO FAULTS
26	3-Jun-2020	PART OF GOPINATH BAZAR OTINAGAR	2	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	06:13	3-Jun-2020	07:00	47	0.00001	INTERRUPTION DUE TO FAULTS
27	4-Jun-2020	PARTS OF WHS NO. 1, B-1 BLOCK WHS, A BLOCK WHS, A-1, A-2 WHS & JAWAR CAMP JJ CLUSTER	2178	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	09:50	4-Jun-2020	10:35	44	0.00031	INTERRUPTION DUE TO FAULTS
28	4-Jun-2020	PARTS OF F BLOCK BALI NAGAR, WZ AREA BASAI DARA PUR	1206	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:26	4-Jun-2020	17:50	24	0.00021	INTERRUPTION DUE TO FAULTS
29	4-Jun-2020	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK	1568	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	18:22	4-Jun-2020	18:56	33	0.00014	INTERRUPTION DUE TO FAULTS
30	4-Jun-2020	PARTS OF C-BLK JJ COLONY INDER PURI MOTINAGAR	578	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	20:50	4-Jun-2020	22:45	115	0.00080	INTERRUPTION DUE TO FAULTS
31	5-Jun-2020	PARTS OF A & B BLOCK LOHA MANDI PH. - 2, Y-BLK, A-15 PH-1, COMMUNITY CENTER.	101	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	06:45	5-Jun-2020	07:20	35	0.00010	INTERRUPTION DUE TO FAULTS
32	5-Jun-2020	PARTS OF C-BLK JJ COLONY INDER PURI MOTINAGAR	193	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	00:00	5-Jun-2020	01:10	70	0.00020	INTERRUPTION DUE TO FAULTS
33	5-Jun-2020	PARTS OF A BLOCK NARAINA INDUSTRIAL AREA PH. - 1	50	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	09:13	5-Jun-2020	09:35	22	0.00001	INTERRUPTION DUE TO FAULTS
34	5-Jun-2020	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK	574	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	15:48	5-Jun-2020	17:45	117	0.00013	INTERRUPTION DUE TO FAULTS
35	6-Jun-2020	PARTS OF 6-BLK MOTHER DAIRY, 6/5A,OLD RANJIT NAGAR, SHIV CHOWK, GALI NO-10 (OLD)	3120	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	22:58	6-Jun-2020	23:30	33	0.00075	INTERRUPTION DUE TO FAULTS
36	6-Jun-2020	PART OF PUSA ITI FLATS MOTINAGAR	2	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	10:19	6-Jun-2020	14:57	278	0.00008	PLANNED OUTAGE
37	6-Jun-2020	PART OF PUSA ITI FLATS MOTINAGAR	8	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	06:48	6-Jun-2020	11:30	282	0.00008	PLANNED OUTAGE
38	7-Jun-2020	PARTS OF DSIDC,F-BLK J J COLONY, PARTS OF EG BLK INDERPURI,POLICE STATION INDERPURI,E-BLK J J COLONY	2991	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	06:29	7-Jun-2020	07:00	32	0.00036	INTERRUPTION DUE TO FAULTS
39	7-Jun-2020	PARTS OF F BLOCK BALI NAGAR, WZ AREA BASAI DARA PUR	899	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:35	7-Jun-2020	09:55	20	0.00004	INTERRUPTION DUE TO FAULTS
40	8-Jun-2020	PARTS OF 54 TO 59 RAMA ROAD, SAW PIPE MOTI NAGAR	1397	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	11:07	8-Jun-2020	11:32	25	0.00054	INTERRUPTION DUE TO FAULTS
41	8-Jun-2020	PARTS OF B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1	103	OTHER OUTAGE	PLANNED OUTAGE	8-Jun-2020	07:05	8-Jun-2020	11:30	265	0.00015	PLANNED OUTAGE
42	9-Jun-2020	PARTS OF DSIDC,F-BLK J J COLONY, PARTS OF EG BLK INDERPURI,POLICE STATION INDERPURI,E-BLK J J COLONY	205	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	17:22	9-Jun-2020	19:00	98	0.00014	SYSTEM SCHEDULE OUTAGE
43	9-Jun-2020	PARTS OF BARAR SQUARE RED LIGHT, DJB BARAR SQUARE	196	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	06:20	9-Jun-2020	06:35	15	0.00009	INTERRUPTION DUE TO FAULTS
44	9-Jun-2020	PARTS OF BARAR SQUARE RED LIGHT, DJB BARAR SQUARE	1364	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	06:20	9-Jun-2020	07:41	81	0.00079	INTERRUPTION DUE TO FAULTS
45	9-Jun-2020	PARTS OF A BLOCK NARAINA INDUSTRIAL AREA PH - 1 & COMMERCIAL CENTER NARAINA INDUSTRIAL AREA - PH - 1	371	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	14:18	9-Jun-2020	15:00	42	0.00007	INTERRUPTION DUE TO FAULTS
46	10-Jun-2020	PARTS OF GOPINATH BAZAR, SADAR BAZAR, PRAHLADPUR VILLAGE, SURVEY OF INDIA.	470	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	06:04	10-Jun-2020	06:20	16	0.00007	INTERRUPTION DUE TO FAULTS
47	10-Jun-2020	PARTS OF GOPINATH BAZAR, SADAR BAZAR, PRAHLADPUR VILLAGE, SURVEY OF INDIA.	140	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	06:04	10-Jun-2020	06:30	26	0.00007	INTERRUPTION DUE TO FAULTS
48	10-Jun-2020	PARTS OF MAIN INDERPURI (EA, EG, ER, EF, EB BLOCK INDERPURI)	796	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	10:58	10-Jun-2020	13:24	146	0.00032	PLANNED OUTAGE
49	10-Jun-2020	PARTS OF F BLOCK M S GARDEN, F BLOCK SHOPPING CENTRE, FA BLOCK M S GARDEN & DG CABLE HT CONSUMER	145	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	11:09	10-Jun-2020	12:20	71	0.00004	PLANNED OUTAGE
50	11-Jun-2020	PARTS OF 62,63, RAMA HVDS ROAD BISLERI HTC	553	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	03:33	11-Jun-2020	04:00	27	0.00023	INTERRUPTION DUE TO FAULTS
51	11-Jun-2020	PARTS OF 53 TO 14 RAMA ROAD MOTI NAGAR	321	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	14:37	11-Jun-2020	14:55	18	0.00002	INTERRUPTION DUE TO FAULTS
52	11-Jun-2020	PARTS OF 5/31 ,5/35 JJ CLUSTER,WZ HVDS, 3,4 BLOCK KIRTINAGAR INDUSTRIAL AREA.	240	OTHER OUTAGE	PLANNED OUTAGE	11-Jun-2020	07:12	11-Jun-2020	12:04	292	0.00016	PLANNED OUTAGE
53	12-Jun-2020	PART OF C BLOCK NARAINA INDUSTRIAL AREA PH.-1	5	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:55	12-Jun-2020	14:19	84	0.00002	INTERRUPTION DUE TO FAULTS
54	12-Jun-2020	PARTS OF 69/1 TO 69/6 NAJAF GARH ROAD & HARPREET FORD & INDIA EXPORT	186	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	15:26	12-Jun-2020	16:00	34	0.00033	INTERRUPTION DUE TO FAULTS
55	12-Jun-2020	PARTS OF 62,63, RAMA HVDS ROAD BISLERI HTC	553	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	23:55	13-Jun-2020	00:40	45	0.00019	INTERRUPTION DUE TO FAULTS
56	12-Jun-2020	PARTS OF 62,63, RAMA HVDS ROAD BISLERI HTC	553	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	06:56	12-Jun-2020	07:30	34	0.00024	INTERRUPTION DUE TO FAULTS
57	12-Jun-2020	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK, TYAGI MARKET BASAI DARAPUR, SOME PORTION OF BASAI DARAPUR	1083	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	15:11	12-Jun-2020	15:50	39	0.00013	INTERRUPTION DUE TO FAULTS
58	12-Jun-2020	PARTS OF KRISHI KUNJ NO.-1, KRISHI KUNJ NO.-2	1685	630 kVA	PLANNED OUTAGE	12-Jun-2020	10:41	12-Jun-2020	13:10	149	0.00074	PLANNED OUTAGE
59	13-Jun-2020	PART OF PRAHLADPUR VILLAGE MOTINAGAR	1	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	07:15	13-Jun-2020	15:05	469	0.00013	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
60	14-Jun-2020	PARTS OF DLF NO 3 KIRTI NAGAR MKT MOTINAGAR	191	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	16:46	14-Jun-2020	17:05	18	0.00026	INTERRUPTION DUE TO FAULTS
61	14-Jun-2020	PARTS OF DLF NO 3 KIRTI NAGAR MKT MOTINAGAR	100	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	16:46	14-Jun-2020	17:40	53	0.00015	INTERRUPTION DUE TO FAULTS
62	15-Jun-2020	PARTS OF METALLIC IMPRESSONS, A-58 ASITIC ELECTRICALS, A-46, APEX SHOES	99	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	07:08	15-Jun-2020	11:40	272	0.00008	PLANNED OUTAGE
63	16-Jun-2020	PARTS OF B-BLOCK SUDARSHAN PARK MOTINAGAR	1467	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	04:58	16-Jun-2020	05:32	34	0.00024	INTERRUPTION DUE TO FAULTS
64	16-Jun-2020	PART OF PUSA ITI FLATS MOTINAGAR	8	OTHER OUTAGE	PLANNED OUTAGE	16-Jun-2020	11:24	16-Jun-2020	15:30	246	0.00007	PLANNED OUTAGE
65	17-Jun-2020	PART OF NASC, INDO ISRAEL, MELA GATE, BEEJ BHAWAN, CTO, DATA CENTER	7	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	19:25	17-Jun-2020	20:30	65	0.00002	INTERRUPTION DUE TO FAULTS
66	17-Jun-2020	PART OF NASC, INDO ISRAEL, MELA GATE, BEEJ BHAWAN, CTO, DATA CENTER	7	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	23:50	18-Jun-2020	00:20	30	0.00002	INTERRUPTION DUE TO FAULTS
67	17-Jun-2020	PARTS OF J,L ,K, BLOCK KIRTI NAGAR INDUSTRIAL AREA.	739	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	00:13	17-Jun-2020	01:05	52	0.00014	INTERRUPTION DUE TO FAULTS
68	17-Jun-2020	PART OF K BLOCK KIRTI NAGAR INDUSTRIAL AREA.	3	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	00:13	17-Jun-2020	01:05	52	0.00001	INTERRUPTION DUE TO FAULTS
69	17-Jun-2020	PARTS OF WHS FURNITURE BLOCK AND SHOPPING CENTRE MOTINAGAR	1575	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	08:27	17-Jun-2020	09:00	33	0.00018	INTERRUPTION DUE TO FAULTS
70	17-Jun-2020	PARTS OF 54 TO 59 RAMA ROAD, SAW PIPE MOTI NAGAR	1397	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	18:00	17-Jun-2020	18:30	30	0.00007	INTERRUPTION DUE TO FAULTS
71	18-Jun-2020	PARTS OF 62,63, RAMA HVDS ROAD BISLERI HTC	552	OTHER OUTAGE	PLANNED OUTAGE	18-Jun-2020	07:22	18-Jun-2020	13:10	348	0.00058	PLANNED OUTAGE
72	18-Jun-2020	PARTS OF A, B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1	47	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	18:00	18-Jun-2020	18:30	30	0.00004	INTERRUPTION DUE TO FAULTS
73	19-Jun-2020	PARTS OF LAKKAD MANDI AND BALI NAGAR	751	990 kVA	PLANNED OUTAGE	19-Jun-2020	10:46	19-Jun-2020	11:26	40	0.00008	PLANNED OUTAGE
74	19-Jun-2020	PARTS OF 53 TO 14 RAMA ROAD MOTI NAGAR	321	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	16:54	19-Jun-2020	17:20	26	0.00066	INTERRUPTION DUE TO FAULTS
75	20-Jun-2020	PARTS OF A, B & C BLOCK NARAINA INDUSTRIAL AREA PH. - 1	47	400 kVA	UNPLANNED OUTAGE	20-Jun-2020	10:16	20-Jun-2020	10:36	20	0.00001	SYSTEM SCHEDULE OUTAGE
76	20-Jun-2020	PART OF MELA GATE MOTI NAGAR	7	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	00:25	20-Jun-2020	01:40	75	0.00004	INTERRUPTION DUE TO FAULTS
77	20-Jun-2020	PARTS OF F BLOCK M S GARDEN, E BLOCK M S GARDEN FA - 357 M S GARDEN & SHARDA PURI	1089	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:10	20-Jun-2020	08:32	22	0.00010	INTERRUPTION DUE TO FAULTS
78	20-Jun-2020	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK	1568	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	11:26	20-Jun-2020	11:45	18	0.00014	INTERRUPTION DUE TO FAULTS
79	20-Jun-2020	PARTS OF BARAR SQUARE RED LIGHT, DJB BARAR SQUARE	196	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	23:39	20-Jun-2020	23:45	6	0.00001	INTERRUPTION DUE TO FAULTS
80	20-Jun-2020	PARTS OF BARAR SQUARE RED LIGHT, DJB BARAR SQUARE	797	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	23:39	20-Jun-2020	23:50	11	0.00003	INTERRUPTION DUE TO FAULTS
81	21-Jun-2020	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK, TYAGI MARKET BASAI DARAPUR, SOME PORTION OF BASAI DARAPUR	543	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	09:35	21-Jun-2020	10:00	25	0.00008	INTERRUPTION DUE TO FAULTS
82	22-Jun-2020	PARTS OF ESI COLONY, E & F BLOCK SUDERSHAN PARK, TYAGI MARKET, RAJDHANI COLLEGE, BALI NAGAR	1244	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	06:35	22-Jun-2020	07:15	40	0.00017	INTERRUPTION DUE TO FAULTS
83	22-Jun-2020	PARTS OF L &T MANJEET, 27, 28, 29, 71/1 TO 71/5 NAJAF GARH ROAD	240	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	07:58	22-Jun-2020	08:25	27	0.00006	INTERRUPTION DUE TO FAULTS
84	23-Jun-2020	PARTS OF BARAR SQUARE RED LIGHT, DJB BARAR SQUARE	449	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	06:53	23-Jun-2020	07:10	18	0.00002	INTERRUPTION DUE TO FAULTS
85	23-Jun-2020	PARTS OF BARAR SQUARE RED LIGHT, DJB BARAR SQUARE	405	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	06:53	23-Jun-2020	07:15	23	0.00003	INTERRUPTION DUE TO FAULTS
86	23-Jun-2020	PARTS OF BARAR SQUARE RED LIGHT, DJB BARAR SQUARE	510	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	06:53	23-Jun-2020	09:15	142	0.00020	FORCE MAJEURE DUE TO SABOTAGE
87	24-Jun-2020	PART OF NEERI PH-1 NARAINA MOTI NAGAR	9	400 kVA	UNPLANNED OUTAGE	24-Jun-2020	13:16	24-Jun-2020	14:06	50	0.00001	SYSTEM SCHEDULE OUTAGE
88	24-Jun-2020	PART OF DLF NO 3 KIRTI NAGAR	12	100 kVA	UNPLANNED OUTAGE	24-Jun-2020	13:40	24-Jun-2020	14:49	69	0.00002	SYSTEM SCHEDULE OUTAGE
89	24-Jun-2020	PARTS OF GOPINATH BAZAR, SADAR BAZAR, PRAHLADPUR VILLAGE, SURVEY OF INDIA.	983	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	07:22	24-Jun-2020	07:30	8	0.00002	INTERRUPTION DUE TO FAULTS
90	24-Jun-2020	PARTS OF GOPINATH BAZAR, SADAR BAZAR, PRAHLADPUR VILLAGE, SURVEY OF INDIA.	140	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	07:22	24-Jun-2020	07:38	16	0.00001	INTERRUPTION DUE TO FAULTS
91	25-Jun-2020	PARTS OF MOTI NAGAR, NATRAJ, KAILESH PARK, MEDICAL DIRECTOR KALRA	682	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	12:03	25-Jun-2020	12:35	31	0.00013	INTERRUPTION DUE TO FAULTS
92	25-Jun-2020	PARTS OF MOTI NAGAR, NATRAJ, KAILESH PARK, MEDICAL DIRECTOR KALRA	357	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	12:03	25-Jun-2020	12:50	46	0.00019	INTERRUPTION DUE TO FAULTS
93	25-Jun-2020	PARTS OF MOTI NAGAR, NATRAJ, KAILESH PARK, MEDICAL DIRECTOR KALRA	114	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	12:03	25-Jun-2020	15:30	206	0.00006	FORCE MAJEURE DUE TO SABOTAGE
94	25-Jun-2020	PARTS OF B, C, E, H BLOCK NARAINA VIHAR & PART OF NARAINA VILLAGE	484	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	22:32	25-Jun-2020	22:55	23	0.00005	INTERRUPTION DUE TO FAULTS
95	25-Jun-2020	PARTS OF B, C, E, H BLOCK NARAINA VIHAR & PART OF NARAINA VILLAGE	847	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	22:32	25-Jun-2020	23:05	33	0.00015	INTERRUPTION DUE TO FAULTS
96	26-Jun-2020	PART OF NASC RESIDENTIAL MOTINAGAR	3	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	08:43	26-Jun-2020	21:24	761	0.00021	FORCE MAJEURE DUE TO SABOTAGE
97	27-Jun-2020	PARTS OF MOTI NAGAR, NATRAJ, KAILESH PARK, MEDICAL DIRECTOR KALRA	114	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	01:54	27-Jun-2020	02:36	42	0.00004	INTERRUPTION DUE TO FAULTS
98	27-Jun-2020	PARTS OF MAIN INDERPURI (WZ, RA , A , EA-BLK, C, B, EC-BLK),PARTS OF IARI PUSA,	1505	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	12:54	27-Jun-2020	13:28	35	0.00050	INTERRUPTION DUE TO FAULTS
99	27-Jun-2020	PARTS OF MAIN INDERPURI (WZ, RA , A , EA-BLK, C, B, EC-BLK),PARTS OF IARI PUSA,	265	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	12:54	27-Jun-2020	13:32	38	0.00013	INTERRUPTION DUE TO FAULTS
100	27-Jun-2020	PARTS OF GOPINATH BAZAR, SADAR BAZAR, PRAHLADPUR VILLAGE, SURVEY OF INDIA.	140	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	10:49	27-Jun-2020	15:30	281	0.00016	PLANNED OUTAGE
101	28-Jun-2020	PARTS OF MAIN INDERPURI (EA, EG, ER, EF, EB BLOCK INDERPURI)	270	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	15:56	28-Jun-2020	16:30	33	0.00076	INTERRUPTION DUE TO FAULTS
102	28-Jun-2020	PARTS OF 53 TO 14 RAMA ROAD MOTI NAGAR	321	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	16:13	28-Jun-2020	16:35	22	0.00046	INTERRUPTION DUE TO FAULTS
103	28-Jun-2020	PARTS OF MAIN INDERPURI (WZ, RA , A , EA-BLK, C, B, EC-BLK),PARTS OF IARI PUSA,	2280	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	16:41	28-Jun-2020	17:10	29	0.00020	INTERRUPTION DUE TO FAULTS
104	29-Jun-20	PARTS OF 24, 17, BLOCK MEDICAL SUPRITENDENT MOTI NAGAR	1170	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:49	29-Jun-20	18:05	16	0.00007	INTERRUPTION DUE TO FAULTS
105	29-Jun-20	PARTS OF METALLIC IMPRESSONS, A-58 ASITIC ELECTRICALS, A-46, APEX SHOES	99	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:48	29-Jun-20	18:15	26	0.00009	INTERRUPTION DUE TO FAULTS
106	30-Jun-20	PART OF PUSA ITI FLATS MOTINAGAR	8	OTHER OUTAGE	PLANNED OUTAGE	30-Jun-20	11:44	30-Jun-20	17:34	350	0.00010	PLANNED OUTAGE
107	30-Jun-20	PARTS OF B - BLOCK SUDERSHAN PARK, A BLOCK SUDERSHAN PARK, D BLOCK SUDERSHAN PARK, TYAGI MARKET BASAI DARAPUR, SOME PORTION OF BASAI DARAPUR	543	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	00:01	30-Jun-20	00:19	18	0.00004	INTERRUPTION DUE TO FAULTS
108	30-Jun-20	PARTS OF A,B BLK NARAINA IND AREA PH-2	153	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	13:50	30-Jun-20	14:20	29	0.00021	INTERRUPTION DUE TO FAULTS
109	30-Jun-20	PARTS OF A,B BLK NARAINA IND AREA PH-2	95	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	13:50	30-Jun-20	14:35	44	0.00006	INTERRUPTION DUE TO FAULTS
					NARELA							
1	1-Jun-2020	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA	74	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	09:30	1-Jun-2020	10:15	45	0.00006	INTERRUPTION DUE TO FAULTS
2	1-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	3000	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	05:31	1-Jun-2020	05:58	27	0.00049	INTERRUPTION DUE TO FAULTS
3	1-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	85	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	06:31	1-Jun-2020	07:20	49	0.00006	INTERRUPTION DUE TO FAULTS
4	1-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	90	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	08:48	1-Jun-2020	10:10	82	0.00011	INTERRUPTION DUE TO FAULTS
5	1-Jun-2020	PARTS OF D BLOCK DSIDC NARELA, POLICE STATION OFFICE & BHORGARH SCHOOL(HT) NARELA.	41	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	09:40	1-Jun-2020	10:20	39	0.00001	INTERRUPTION DUE TO FAULTS
6	1-Jun-2020	PARTS OF D BLOCK DSIDC NARELA, POLICE STATION OFFICE & BHORGARH SCHOOL(HT) NARELA.	36	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	09:40	1-Jun-2020	15:55	375	0.00010	FORCE MAJEURE DUE TO SABOTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
7	1-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	58	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	09:54	1-Jun-2020	10:15	21	0.00001	INTERRUPTION DUE TO FAULTS
8	1-Jun-2020	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION	34	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	11:21	1-Jun-2020	18:30	429	0.00012	FORCE MAJEURE DUE TO SABOTAGE
9	1-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	189	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	11:20	1-Jun-2020	12:10	50	0.00007	INTERRUPTION DUE TO FAULTS
10	1-Jun-2020	PART OF BLOCK-B DSIDC NARELA INDUSTRIAL AREA.	3	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	11:43	1-Jun-2020	12:35	52	0.00001	SYSTEM SCHEDULE OUTAGE
11	1-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	1999	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	11:54	1-Jun-2020	13:01	66	0.00035	INTERRUPTION DUE TO FAULTS
12	1-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	85	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	14:42	1-Jun-2020	16:27	105	0.00003	INTERRUPTION DUE TO FAULTS
13	1-Jun-2020	PART OF E BLOCK (DSIDC NARELA)	3	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	15:41	1-Jun-2020	16:30	49	0.00001	SYSTEM SCHEDULE OUTAGE
14	1-Jun-2020	PARTS OF DSIDC L BLOCK BHORGARH	511	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	17:06	1-Jun-2020	17:36	30	0.00004	INTERRUPTION DUE TO FAULTS
15	1-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	50	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	17:12	1-Jun-2020	18:15	63	0.00002	INTERRUPTION DUE TO FAULTS
16	1-Jun-2020	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	408	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	19:06	1-Jun-2020	19:46	40	0.00013	INTERRUPTION DUE TO FAULTS
17	1-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	63	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	20:06	1-Jun-2020	20:21	15	0.000004	INTERRUPTION DUE TO FAULTS
18	2-Jun-2020	PARTS OF NANGLI KIOSK ALIPUR NARELA	110	OTHER OUTAGE	PLANNED OUTAGE	2-Jun-2020	10:47	2-Jun-2020	14:33	226	0.00013	PLANNED OUTAGE
19	12-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR	22	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	10:11	12-Jun-2020	12:00	109	0.00045	INTERRUPTION DUE TO FAULTS
20	2-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3256	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	17:55	2-Jun-2020	19:00	65	0.00072	INTERRUPTION DUE TO FAULTS
21	2-Jun-2020	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL.	194	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	09:42	2-Jun-2020	10:42	60	0.00002	INTERRUPTION DUE TO FAULTS
22	2-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	1744	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:41	2-Jun-2020	08:30	109	0.00061	INTERRUPTION DUE TO FAULTS
23	2-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	256	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:41	2-Jun-2020	11:55	314	0.00026	FORCE MAJEURE DUE TO SABOTAGE
24	2-Jun-2020	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL.	906	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:43	2-Jun-2020	08:45	122	0.00075	FORCE MAJEURE DUE TO RAIN/STORM
25	2-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	362	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:50	2-Jun-2020	08:18	88	0.00012	INTERRUPTION DUE TO FAULTS
26	2-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	395	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:50	2-Jun-2020	09:35	165	0.00018	FORCE MAJEURE DUE TO RAIN/STORM
27	2-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	281	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:50	2-Jun-2020	09:35	165	0.00018	FORCE MAJEURE DUE TO RAIN/STORM
28	2-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	1962	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:50	2-Jun-2020	14:00	430	0.00239	FORCE MAJEURE DUE TO RAIN/STORM
29	2-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	281	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	10:05	2-Jun-2020	14:00	235	0.00020	FORCE MAJEURE DUE TO RAIN/STORM
30	2-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3878	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	06:45	2-Jun-2020	08:00	75	0.00194	INTERRUPTION DUE TO FAULTS
31	2-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	2722	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	09:00	2-Jun-2020	10:45	105	0.00088	INTERRUPTION DUE TO FAULTS
32	2-Jun-2020	PARTS OF NANGLI KIOSK ALIPUR NARELA	89	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	11:28	2-Jun-2020	17:25	357	0.00020	FORCE MAJEURE DUE TO SABOTAGE
33	2-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	85	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	18:09	2-Jun-2020	18:40	31	0.00002	INTERRUPTION DUE TO FAULTS
34	2-Jun-2020	PARTS OF C BLK DSIDC BHORGARH BAWANA	65	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	20:51	2-Jun-2020	22:00	69	0.00010	INTERRUPTION DUE TO FAULTS
35	2-Jun-2020	PART OF NO - 7 B-BLOCK DSIDC NARELA	6	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	16:42	2-Jun-2020	17:00	18	0.00001	INTERRUPTION DUE TO FAULTS
36	2-Jun-2020	PART OF 58 H-BLOCK DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	11:25	2-Jun-2020	14:00	155	0.00004	FORCE MAJEURE DUE TO SABOTAGE
37	2-Jun-2020	PART OF 58 H-BLOCK DSIDC NARELA	2	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	16:03	2-Jun-2020	17:04	61	0.00002	INTERRUPTION DUE TO FAULTS
38	2-Jun-2020	PART OF HARIZAN BASTI NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	15:47	2-Jun-2020	17:00	73	0.00002	SYSTEM SCHEDULE OUTAGE
39	3-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	74	OTHER OUTAGE	PLANNED OUTAGE	3-Jun-2020	11:34	3-Jun-2020	15:35	241	0.00007	PLANNED OUTAGE
40	3-Jun-2020	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I	307	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	22:20	3-Jun-2020	22:39	19	0.00004	INTERRUPTION DUE TO FAULTS
41	3-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	566	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	11:56	3-Jun-2020	16:29	273	0.00038	FORCE MAJEURE DUE TO SABOTAGE
42	3-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	676	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	10:35	3-Jun-2020	11:15	40	0.00017	INTERRUPTION DUE TO FAULTS
43	3-Jun-2020	PART OF H BLOCK (DSIDC NARELA)	4	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	15:15	3-Jun-2020	16:45	90	0.00003	INTERRUPTION DUE TO FAULTS
44	3-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	676	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	06:20	3-Jun-2020	06:38	18	0.00004	INTERRUPTION DUE TO FAULTS
45	3-Jun-2020	PART OF NANGLI KIOSK ALIPUR NARELA	13	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	09:18	3-Jun-2020	11:03	104	0.00003	INTERRUPTION DUE TO FAULTS
46	3-Jun-2020	PART OF D-1543 DSIDC NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	10:49	3-Jun-2020	13:38	169	0.00005	FORCE MAJEURE DUE TO SABOTAGE
47	3-Jun-2020	PART OF D-1543 DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	11:14	3-Jun-2020	14:01	167	0.00005	FORCE MAJEURE DUE TO SABOTAGE
48	3-Jun-2020	PARTS OF RICHPAL WALA , NATIONAL PUBLIC SCHOOL, SHIV MANDIR COLONY WALA, HAZARI-BIHARI, NPS SAFIYABAD ROAD	1684	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	12:45	3-Jun-2020	13:20	35	0.00016	INTERRUPTION DUE TO FAULTS
49	3-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3878	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	14:01	3-Jun-2020	14:50	49	0.00055	INTERRUPTION DUE TO FAULTS
50	3-Jun-2020	PART OF C BLOCK 1272 NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	15:35	4-Jun-2020	09:30	1075	0.00030	FORCE MAJEURE DUE TO SABOTAGE
51	3-Jun-2020	PARTS OF DSIDC SECTOR B-2562 NARELA	54	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	16:00	3-Jun-2020	16:12	12	0.000003	INTERRUPTION DUE TO FAULTS
52	3-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	1594	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	15:48	3-Jun-2020	16:10	22	0.00009	INTERRUPTION DUE TO FAULTS
53	3-Jun-2020	PARTS OF BLOCK - G DSIDC NARELA INDUSTRIAL AREA.	65	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	18:14	3-Jun-2020	18:35	21	0.00001	INTERRUPTION DUE TO FAULTS
54	3-Jun-2020	PARTS OF DDA B-2, POCKET A, D, H NARELA	634	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	21:09	3-Jun-2020	21:30	22	0.00005	INTERRUPTION DUE TO FAULTS
55	3-Jun-2020	PART OF DSIIDC FACTORY NO:D-1501 NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	15:43	3-Jun-2020	17:48	125	0.00004	FORCE MAJEURE DUE TO SABOTAGE
56	4-Jun-2020	PART OF BHORGARH VILLAGE NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	12:54	4-Jun-2020	14:00	66	0.00002	INTERRUPTION DUE TO FAULTS
57	4-Jun-2020	PART OF J-3368 DSIDC NARELA	7	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	09:14	4-Jun-2020	11:25	131	0.00004	FORCE MAJEURE DUE TO SABOTAGE
58	4-Jun-2020	PART OF BLOCK-G DSIDC NARELA INDUSTRIAL AREA.	4	250 kVA	UNPLANNED OUTAGE	4-Jun-2020	12:26	4-Jun-2020	13:05	39	0.00001	SYSTEM SCHEDULE OUTAGE
59	4-Jun-2020	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING	1623	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	08:31	4-Jun-2020	11:10	159	0.00071	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
60	4-Jun-2020	PARTS OF SHASTRIPARK, KAUSHIK ENCLAVE B-BLOCK, JMP SCHOOL	4902	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	15:10	4-Jun-2020	15:31	21	0.00029	SYSTEM SCHEDULE OUTAGE
61	4-Jun-2020	PART OF H BLOCK (DSIDC NARELA)	3	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	15:46	4-Jun-2020	16:28	42	0.00001	INTERRUPTION DUE TO FAULTS
62	4-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2621	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	19:58	4-Jun-2020	20:41	43	0.00048	INTERRUPTION DUE TO FAULTS
63	4-Jun-2020	PART OF F BLOCK (DSIDC NARELA)	3	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	20:16	4-Jun-2020	21:13	57	0.00002	SYSTEM SCHEDULE OUTAGE
64	4-Jun-2020	PART OF D-1543 DSIDC NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	10:51	4-Jun-2020	11:58	67	0.00002	SYSTEM SCHEDULE OUTAGE
65	29-Jun-20	PART OF C BLK NARELA	2	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	22:44	30-Jun-20	00:55	131	0.00004	FORCE MAJEURE DUE TO SABOTAGE
66	30-Jun-20	PART OF C BLK NARELA	1	OTHER OUTAGE	PLANNED OUTAGE	30-Jun-20	12:36	30-Jun-20	17:15	279	0.00008	PLANNED OUTAGE
67	4-Jun-2020	PARTS OF DJB-1 KHERA KHURD NARELA	538	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	21:37	4-Jun-2020	22:00	23	0.00004	SYSTEM SCHEDULE OUTAGE
68	4-Jun-2020	PART OF D-1543 DSIDC NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	10:39	4-Jun-2020	11:56	77	0.00002	INTERRUPTION DUE TO FAULTS
69	4-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	5233	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	05:29	4-Jun-2020	06:10	41	0.00034	INTERRUPTION DUE TO FAULTS
70	4-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	5233	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	06:25	4-Jun-2020	06:53	28	0.00043	INTERRUPTION DUE TO FAULTS
71	4-Jun-2020	PARTS OF A-10 GAS GODOWN NARELA	2338	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	09:22	4-Jun-2020	09:53	31	0.00026	INTERRUPTION DUE TO FAULTS
72	4-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	82	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	09:34	4-Jun-2020	10:15	41	0.00034	INTERRUPTION DUE TO FAULTS
73	4-Jun-2020	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY,PREEM NAGAR.	214	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	20:01	4-Jun-2020	21:02	60	0.00005	INTERRUPTION DUE TO FAULTS
74	4-Jun-2020	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIPUR NARELA	3250	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	22:07	4-Jun-2020	22:57	50	0.00055	INTERRUPTION DUE TO FAULTS
75	4-Jun-2020	PART OF C BLOCK 1272 NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	14:40	4-Jun-2020	18:30	231	0.00006	FORCE MAJEURE DUE TO SABOTAGE
76	4-Jun-2020	PART OF H BLOCK (DSIDC NARELA)	3	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	16:09	4-Jun-2020	17:05	56	0.00002	INTERRUPTION DUE TO FAULTS
77	4-Jun-2020	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI	82	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:07	4-Jun-2020	18:40	93	0.00065	INTERRUPTION DUE TO FAULTS
78	5-Jun-2020	PART OF J-3368 DSIDC NARELA	5	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	12:49	5-Jun-2020	14:20	91	0.00003	INTERRUPTION DUE TO FAULTS
79	8-Jun-2020	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	10:52	8-Jun-2020	11:17	25	0.00001	SYSTEM SCHEDULE OUTAGE
80	5-Jun-2020	PART OF HOLAMBI KALAN NARELA	9	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	10:00	5-Jun-2020	10:50	50	0.00001	INTERRUPTION DUE TO FAULTS
81	8-Jun-2020	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	11:18	8-Jun-2020	11:40	22	0.00001	INTERRUPTION DUE TO FAULTS
82	5-Jun-2020	PARTS OF F-1884 DSIDC NARELA	59	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	11:17	5-Jun-2020	12:00	43	0.00038	INTERRUPTION DUE TO FAULTS
83	5-Jun-2020	PART OF E BLOCK (DSIDC NARELA)	2	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	12:19	5-Jun-2020	13:32	73	0.00002	INTERRUPTION DUE TO FAULTS
84	5-Jun-2020	PART OF A BLOCK DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	14:45	5-Jun-2020	16:00	75	0.00002	INTERRUPTION DUE TO FAULTS
85	5-Jun-2020	PART OF F BLOCK (DSIDC ,NARELA)	4	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	18:37	5-Jun-2020	19:00	23	0.00001	INTERRUPTION DUE TO FAULTS
86	5-Jun-2020	PART OF B BLOCK (DSIDC ,NARELA)	3	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	19:58	5-Jun-2020	20:38	40	0.00001	INTERRUPTION DUE TO FAULTS
87	9-Jun-2020	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	11:43	9-Jun-2020	12:33	50	0.00003	INTERRUPTION DUE TO FAULTS
88	5-Jun-2020	PARTS OF A-10 GAS GODOWN NARELA	3264	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	06:21	5-Jun-2020	07:04	42	0.00047	INTERRUPTION DUE TO FAULTS
89	5-Jun-2020	PARTS OF A-10 GAS GODOWN NARELA	483	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	06:21	5-Jun-2020	07:10	48	0.00004	INTERRUPTION DUE TO FAULTS
90	5-Jun-2020	PARTS OF A-10 GAS GODOWN NARELA	474	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	06:21	5-Jun-2020	07:48	86	0.00007	INTERRUPTION DUE TO FAULTS
91	5-Jun-2020	PARTS OF NAYA BANS VILLAGE, KHERA KHURD VILLAGE, METRO VIHAR HOLAMBI KHURD.	216	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	07:12	5-Jun-2020	08:05	53	0.00029	INTERRUPTION DUE TO FAULTS
92	5-Jun-2020	PARTS OF NAYA BANS VILLAGE, KHERA KHURD VILLAGE, METRO VIHAR HOLAMBI KHURD.	1611	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	07:12	5-Jun-2020	08:10	57	0.00064	INTERRUPTION DUE TO FAULTS
93	5-Jun-2020	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA	73	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	07:00	5-Jun-2020	07:40	40	0.00002	INTERRUPTION DUE TO FAULTS
94	5-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	837	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	09:43	5-Jun-2020	11:00	77	0.00075	INTERRUPTION DUE TO FAULTS
95	5-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	97	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	09:43	5-Jun-2020	12:20	157	0.00022	FORCE MAJEURE DUE TO SABOTAGE
96	5-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	123	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	09:43	5-Jun-2020	12:30	167	0.00037	FORCE MAJEURE DUE TO SABOTAGE
97	5-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	798	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	09:43	5-Jun-2020	13:21	218	0.00127	FORCE MAJEURE DUE TO SABOTAGE
98	5-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	372	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	09:43	5-Jun-2020	16:09	386	0.00086	FORCE MAJEURE DUE TO SABOTAGE
99	5-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	495	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	09:43	5-Jun-2020	19:25	582	0.00178	FORCE MAJEURE DUE TO SABOTAGE
100	5-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	837	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	12:19	5-Jun-2020	12:30	11	0.00011	INTERRUPTION DUE TO FAULTS
101	5-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	867	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	13:21	5-Jun-2020	15:06	105	0.00102	INTERRUPTION DUE TO FAULTS
102	5-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	1855	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	15:06	5-Jun-2020	15:35	29	0.00044	INTERRUPTION DUE TO FAULTS
103	5-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	372	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	18:53	5-Jun-2020	19:25	32	0.00007	INTERRUPTION DUE TO FAULTS
104	5-Jun-2020	PARTS OF A-10 GAS GODOWN NARELA	2338	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	09:41	5-Jun-2020	10:10	30	0.00025	INTERRUPTION DUE TO FAULTS
105	5-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	1595	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	10:16	5-Jun-2020	13:50	213	0.00249	FORCE MAJEURE DUE TO SABOTAGE
106	5-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	437	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	10:16	5-Jun-2020	15:15	298	0.00099	FORCE MAJEURE DUE TO SABOTAGE
107	5-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	1474	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	10:49	5-Jun-2020	10:57	7	0.00007	INTERRUPTION DUE TO FAULTS
108	5-Jun-2020	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI	82	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	13:11	5-Jun-2020	15:07	116	0.00029	INTERRUPTION DUE TO FAULTS
109	5-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	696	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	13:24	5-Jun-2020	14:00	36	0.00016	INTERRUPTION DUE TO FAULTS
110	5-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	659	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	13:24	5-Jun-2020	15:00	96	0.00120	INTERRUPTION DUE TO FAULTS
111	5-Jun-2020	PARTS OF NDPL COLONY, SOS BAWANA RAJEEV COLONY)	22	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	14:25	5-Jun-2020	15:20	55	0.00003	INTERRUPTION DUE TO FAULTS
112	5-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	2032	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	16:19	5-Jun-2020	16:40	21	0.00030	INTERRUPTION DUE TO FAULTS
113	5-Jun-2020	PARTS OF C BLK DSIDC BHORGARH BAWANA	2632	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	18:09	5-Jun-2020	18:25	16	0.00013	INTERRUPTION DUE TO FAULTS
114	9-Jun-2020	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	5	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	12:39	9-Jun-2020	13:08	29	0.00001	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
115	6-Jun-2020	PART OF H-1331 DSIDC INDUSTRIAL AREA	3	250 kVA	UNPLANNED OUTAGE	6-Jun-2020	11:16	6-Jun-2020	12:26	70	0.00002	SYSTEM SCHEDULE OUTAGE
116	6-Jun-2020	PART OF BLOCK-B DSIDC NARELA INDUSTRIAL AREA.	3	315 kVA	UNPLANNED OUTAGE	6-Jun-2020	13:17	6-Jun-2020	14:14	57	0.00002	SYSTEM SCHEDULE OUTAGE
117	9-Jun-2020	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	14:35	9-Jun-2020	14:48	13	0.000004	INTERRUPTION DUE TO FAULTS
118	6-Jun-2020	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY	611	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	10:46	6-Jun-2020	13:15	149	0.00025	PLANNED OUTAGE
119	6-Jun-2020	PARTS OF HVDS ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	106	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	11:20	6-Jun-2020	15:21	241	0.00007	PLANNED OUTAGE
120	6-Jun-2020	PARTS OF B BLOCK (DSIDC ,NARELA)	105	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	10:39	6-Jun-2020	17:00	381	0.00021	PLANNED OUTAGE
121	6-Jun-2020	PARTS OF HVDS ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	878	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	10:33	6-Jun-2020	16:45	372	0.00155	PLANNED OUTAGE
122	6-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	2722	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	10:05	6-Jun-2020	12:35	150	0.00213	PLANNED OUTAGE
123	6-Jun-2020	PART OF E BLOCK (DSIDC NARELA)	3	315 kVA	PLANNED OUTAGE	6-Jun-2020	11:18	6-Jun-2020	15:45	267	0.00007	PLANNED OUTAGE
124	6-Jun-2020	PART OF F BLOCK (DSIDC ,NARELA)	3	100 kVA	PLANNED OUTAGE	6-Jun-2020	12:17	6-Jun-2020	16:20	243	0.00007	PLANNED OUTAGE
125	6-Jun-2020	PART OF F BLOCK (DSIDC ,NARELA)	5	315 kVA	PLANNED OUTAGE	6-Jun-2020	12:09	6-Jun-2020	16:35	266	0.00007	PLANNED OUTAGE
126	6-Jun-2020	PART OF E BLOCK (DSIDC NARELA)	3	400 kVA	PLANNED OUTAGE	6-Jun-2020	11:31	6-Jun-2020	15:50	259	0.00007	PLANNED OUTAGE
127	6-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	48	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	05:47	6-Jun-2020	06:10	23	0.00001	INTERRUPTION DUE TO FAULTS
128	6-Jun-2020	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING	83	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	09:22	6-Jun-2020	16:02	400	0.00056	FORCE MAJEURE DUE TO SABOTAGE
129	6-Jun-2020	PARTS OF C & E BLOCK DSIDC NARELA	52	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	14:49	6-Jun-2020	15:20	31	0.00004	INTERRUPTION DUE TO FAULTS
130	6-Jun-2020	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION	429	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	14:56	6-Jun-2020	16:01	65	0.00014	INTERRUPTION DUE TO FAULTS
131	9-Jun-2020	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	14:57	9-Jun-2020	16:00	63	0.00004	INTERRUPTION DUE TO FAULTS
132	6-Jun-2020	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL.	906	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	16:04	6-Jun-2020	16:32	28	0.00016	SYSTEM SCHEDULE OUTAGE
133	6-Jun-2020	PART OF D BLOCK (DSIDC NARELA)	2	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	16:12	6-Jun-2020	17:05	53	0.00002	INTERRUPTION DUE TO FAULTS
134	6-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	85	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	09:10	6-Jun-2020	09:40	30	0.00007	INTERRUPTION DUE TO FAULTS
135	9-Jun-2020	PART OF DEDICATED EXPRESS CONSUMER - IAMR NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	16:41	9-Jun-2020	16:59	18	0.00001	SYSTEM SCHEDULE OUTAGE
136	6-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	2940	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	13:06	6-Jun-2020	15:02	115	0.00080	INTERRUPTION DUE TO FAULTS
137	6-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	1190	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	14:10	6-Jun-2020	15:02	51	0.00021	INTERRUPTION DUE TO FAULTS
138	6-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	172	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	13:16	6-Jun-2020	14:00	45	0.00010	INTERRUPTION DUE TO FAULTS
139	6-Jun-2020	PARTS OF F-1712 DSIDC NARELA	36	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	22:34	6-Jun-2020	23:04	30	0.00002	INTERRUPTION DUE TO FAULTS
140	6-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	1355	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	23:30	6-Jun-2020	23:55	25	0.00035	INTERRUPTION DUE TO FAULTS
141	7-Jun-2020	PART OF J-3057 DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	15:19	7-Jun-2020	20:27	308	0.00017	FORCE MAJEURE DUE TO SABOTAGE
142	7-Jun-2020	PARTS OF H BLOCK (DSIDC NARELA)	53	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	07:26	7-Jun-2020	07:57	31	0.00002	INTERRUPTION DUE TO FAULTS
143	7-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	38	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	07:50	7-Jun-2020	08:00	10	0.00002	INTERRUPTION DUE TO FAULTS
144	7-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	981	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	07:50	7-Jun-2020	10:15	145	0.00073	FORCE MAJEURE DUE TO SABOTAGE
145	7-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	1473	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:25	7-Jun-2020	10:00	35	0.00025	INTERRUPTION DUE TO FAULTS
146	7-Jun-2020	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING	2006	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:50	7-Jun-2020	10:10	20	0.00034	INTERRUPTION DUE TO FAULTS
147	7-Jun-2020	PARTS OF TEJSINGH KHERAKALAN , JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN	689	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:50	7-Jun-2020	10:15	25	0.00017	INTERRUPTION DUE TO FAULTS
148	7-Jun-2020	PART OF ALIPUR - 2 NARELA	8	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	11:31	7-Jun-2020	11:55	24	0.00001	INTERRUPTION DUE TO FAULTS
149	7-Jun-2020	PART OF AGRICULTURE LAND OF PALLA	16	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	14:00	7-Jun-2020	14:59	59	0.00003	INTERRUPTION DUE TO FAULTS
150	7-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	1019	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	14:40	7-Jun-2020	15:45	65	0.00056	INTERRUPTION DUE TO FAULTS
151	7-Jun-2020	PARTS OF J-3057 DSIDC NARELA	39	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	14:48	7-Jun-2020	16:55	127	0.00039	FORCE MAJEURE DUE TO SABOTAGE
152	7-Jun-2020	PART OF D-1543 DSIDC NARELA	2	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	18:15	7-Jun-2020	19:07	52	0.00003	INTERRUPTION DUE TO FAULTS
153	7-Jun-2020	PARTS OF DSIDC SECTOR B-2562 NARELA	50	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	19:40	7-Jun-2020	20:15	35	0.00003	INTERRUPTION DUE TO FAULTS
154	7-Jun-2020	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI	82	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	21:32	7-Jun-2020	22:10	38	0.00016	INTERRUPTION DUE TO FAULTS
155	7-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	4667	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	04:50	7-Jun-2020	06:20	90	0.00125	INTERRUPTION DUE TO FAULTS
156	7-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	117	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	04:50	7-Jun-2020	07:00	130	0.00011	FORCE MAJEURE DUE TO SABOTAGE
157	7-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	981	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	07:20	7-Jun-2020	07:44	24	0.00007	INTERRUPTION DUE TO FAULTS
158	7-Jun-2020	PARTS OF H BLOCK (DSIDC NARELA)	72	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	06:04	7-Jun-2020	06:35	31	0.00003	INTERRUPTION DUE TO FAULTS
159	7-Jun-2020	PART OF BAKHTAWAR PUR NARELA	5	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	06:45	7-Jun-2020	07:40	55	0.00002	INTERRUPTION DUE TO FAULTS
160	7-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	654	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	07:03	7-Jun-2020	07:40	37	0.00007	INTERRUPTION DUE TO FAULTS
161	10-Jun-2020	PARTS OF J BLOCK (DSIDC) & NDDB NARELA	103	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:20	10-Jun-2020	17:38	17	0.00028	INTERRUPTION DUE TO FAULTS
162	7-Jun-2020	PARTS OF TEJSINGH KHERAKALAN , JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN	380	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	12:29	7-Jun-2020	12:55	26	0.00010	INTERRUPTION DUE TO FAULTS
163	7-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	1038	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	14:42	7-Jun-2020	15:12	30	0.00010	INTERRUPTION DUE TO FAULTS
164	7-Jun-2020	PARTS OF DDA B-2, POCKET A, D, H NARELA	634	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	21:49	7-Jun-2020	22:03	14	0.00006	INTERRUPTION DUE TO FAULTS
165	7-Jun-2020	PART OF 58 H-BLOCK DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	19:00	7-Jun-2020	20:43	103	0.00006	INTERRUPTION DUE TO FAULTS
166	27-Jun-2020	PARTS OF J BLOCK (DSIDC) & NDDB NARELA	99	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	16:14	27-Jun-2020	17:15	61	0.00002	INTERRUPTION DUE TO FAULTS
167	8-Jun-2020	PARTS OF NO 25 E-BLK DSIDC NARELA	23	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	12:20	8-Jun-2020	13:00	40	0.00006	INTERRUPTION DUE TO FAULTS
168	8-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	981	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	15:14	8-Jun-2020	17:30	136	0.00038	FORCE MAJEURE DUE TO SABOTAGE
169	8-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY, SWARAN JAYANTI VIHAR, TIKARI SEAWAGE PLANT, TUBE WELL NETWORK, TRANSIT CAMP	1473	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	11:45	8-Jun-2020	12:23	38	0.00037	SYSTEM SCHEDULE OUTAGE
170	8-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	2340	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	08:00	8-Jun-2020	08:39	38	0.00096	INTERRUPTION DUE TO FAULTS
171	8-Jun-2020	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION	144	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	11:08	8-Jun-2020	17:30	382	0.00053	FORCE MAJEURE DUE TO SABOTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
172	8-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	85	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	17:16	8-Jun-2020	17:50	34	0.00008	INTERRUPTION DUE TO FAULTS
173	8-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	2117	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	22:57	8-Jun-2020	23:35	37	0.00104	INTERRUPTION DUE TO FAULTS
174	8-Jun-2020	PARTS OF SANNOTH VILLAGE NARELA	1294	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	23:51	9-Jun-2020	00:40	49	0.00020	INTERRUPTION DUE TO FAULTS
175	8-Jun-2020	PARTS OF METRO VIHAR PH - 2, J. J. SLUM COLONY (HOLAMBI KALAN)	2445	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	00:46	8-Jun-2020	01:25	39	0.00043	INTERRUPTION DUE TO FAULTS
176	8-Jun-2020	PARTS OF METRO VIHAR PH - 2, J. J. SLUM COLONY (HOLAMBI KALAN)	931	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	00:46	8-Jun-2020	02:50	124	0.00052	FORCE MAJEURE DUE TO SABOTAGE
177	8-Jun-2020	PARTS OF METRO VIHAR PH - 2, J. J. SLUM COLONY (HOLAMBI KALAN)	2445	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	01:51	8-Jun-2020	02:57	66	0.00073	INTERRUPTION DUE TO FAULTS
178	8-Jun-2020	PARTS OF F BLOCK (DSIDC ,NARELA)	40	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	07:40	8-Jun-2020	07:55	15	0.00004	INTERRUPTION DUE TO FAULTS
179	8-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	124	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	09:12	8-Jun-2020	09:39	27	0.00004	INTERRUPTION DUE TO FAULTS
180	8-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	167	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	13:21	8-Jun-2020	14:05	44	0.00004	INTERRUPTION DUE TO FAULTS
181	8-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	233	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	19:58	8-Jun-2020	20:40	42	0.00012	INTERRUPTION DUE TO FAULTS
182	29-Jun-20	PART OF DSIDC B-2562 DSIDC NARELA	4	250 kVA	UNPLANNED OUTAGE	29-Jun-20	12:20	29-Jun-20	13:49	89	0.00002	SYSTEM SCHEDULE OUTAGE
183	8-Jun-2020	PART OF 58 H-BLOCK DSIDC NARELA	2	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	15:24	8-Jun-2020	15:56	32	0.00001	INTERRUPTION DUE TO FAULTS
184	7-Jun-2020	PART OF DSIDC B-2562 DSIDC NARELA	2	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	19:14	7-Jun-2020	20:15	61	0.00002	INTERRUPTION DUE TO FAULTS
185	8-Jun-2020	PART OF DSIIDC FACTORY NO: F-1829 NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	14:58	8-Jun-2020	16:02	64	0.00004	INTERRUPTION DUE TO FAULTS
186	8-Jun-2020	PART OF I BLOCK,DSIDC NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	11:27	8-Jun-2020	12:05	38	0.00002	INTERRUPTION DUE TO FAULTS
187	9-Jun-2020	PART OF DSIDC B-2562 DSIDC NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	18:21	9-Jun-2020	18:56	35	0.00002	INTERRUPTION DUE TO FAULTS
188	9-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	2117	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	11:53	9-Jun-2020	12:25	32	0.00027	INTERRUPTION DUE TO FAULTS
189	20-Jun-2020	PART OF DSIDC B-2562 DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	14:35	20-Jun-2020	15:14	39	0.00002	INTERRUPTION DUE TO FAULTS
190	9-Jun-2020	PART OF A BLOCK DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	12:29	9-Jun-2020	13:30	61	0.00002	INTERRUPTION DUE TO FAULTS
191	9-Jun-2020	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI	103	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	06:35	9-Jun-2020	07:15	40	0.00001	INTERRUPTION DUE TO FAULTS
192	9-Jun-2020	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY,PREEM NAGAR.	214	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	14:08	9-Jun-2020	14:38	31	0.00004	INTERRUPTION DUE TO FAULTS
193	9-Jun-2020	PARTS OF METRO VIHAR PH - 2, J. J. SLUM COLONY (HOLAMBI KALAN)	3377	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	19:44	9-Jun-2020	20:25	41	0.00059	INTERRUPTION DUE TO FAULTS
194	9-Jun-2020	PARTS OF A BLOCK, DSIDC NARELA	127	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	19:46	9-Jun-2020	21:39	113	0.00003	INTERRUPTION DUE TO FAULTS
195	9-Jun-2020	PARTS OF A-10 GAS GODOWN NARELA	1712	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	23:18	10-Jun-2020	00:12	54	0.00015	INTERRUPTION DUE TO FAULTS
196	9-Jun-2020	PARTS OF A BLOCK DSIDC NARELA	121	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	09:09	9-Jun-2020	09:32	23	0.00026	INTERRUPTION DUE TO FAULTS
197	9-Jun-2020	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	2408	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	11:54	9-Jun-2020	12:20	26	0.00025	INTERRUPTION DUE TO FAULTS
198	9-Jun-2020	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	227	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	11:54	9-Jun-2020	17:07	313	0.00035	FORCE MAJEURE DUE TO SABOTAGE
199	9-Jun-2020	PART OF A BLOCK (DSIDC NARELA)	5	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	12:03	9-Jun-2020	12:36	33	0.00002	INTERRUPTION DUE TO FAULTS
200	9-Jun-2020	PARTS OF SANNOTH VILLAGE NARELA	1294	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	13:50	9-Jun-2020	15:36	106	0.00147	INTERRUPTION DUE TO FAULTS
201	9-Jun-2020	PART OF A BLOCK DSIDC NARELA	5	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	23:42	9-Jun-2020	23:57	15	0.000004	SYSTEM SCHEDULE OUTAGE
202	9-Jun-2020	PART OF A BLOCK DSIDC NARELA	3	400 kVA	UNPLANNED OUTAGE	9-Jun-2020	12:19	9-Jun-2020	13:46	87	0.00002	SYSTEM SCHEDULE OUTAGE
203	1-Jun-2020	PART OF DSIIDC FACTORY NO:J-2293 NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	18:19	1-Jun-2020	19:11	52	0.00001	SYSTEM SCHEDULE OUTAGE
204	9-Jun-2020	PARTS OF GAUTAM COLONY AND SANJAY COLONY	453	630 kVA	PLANNED OUTAGE	9-Jun-2020	10:29	9-Jun-2020	15:40	311	0.00043	PLANNED OUTAGE
205	9-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	437	OTHER OUTAGE	PLANNED OUTAGE	9-Jun-2020	08:18	9-Jun-2020	13:43	325	0.00036	PLANNED OUTAGE
206	9-Jun-2020	PART OF I BLOCK,DSIDC NARELA	7	400 kVA	UNPLANNED OUTAGE	9-Jun-2020	11:28	9-Jun-2020	11:45	17	0.000005	SYSTEM SCHEDULE OUTAGE
207	23-Jun-2020	PART OF DSIIDC FACTORY NO:J-2293 NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	18:50	23-Jun-2020	19:24	34	0.00001	INTERRUPTION DUE TO FAULTS
208	30-Jun-20	PART OF DSIIDC FACTORY NO:J-2293 NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	11:28	30-Jun-20	12:00	32	0.00001	INTERRUPTION DUE TO FAULTS
209	10-Jun-2020	PART OF NO - 7 B-BLOCK DSIDC NARELA	1	160 kVA	PLANNED OUTAGE	10-Jun-2020	10:52	10-Jun-2020	14:05	193	0.00005	PLANNED OUTAGE
210	10-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	1473	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	07:14	10-Jun-2020	07:55	41	0.00010	INTERRUPTION DUE TO FAULTS
211	10-Jun-2020	PART OF A BLOCK (DSIDC NARELA)	2	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	14:39	10-Jun-2020	15:36	57	0.00002	INTERRUPTION DUE TO FAULTS
212	10-Jun-2020	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING	2006	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:45	10-Jun-2020	17:30	45	0.00131	INTERRUPTION DUE TO FAULTS
213	10-Jun-2020	PART OF D-BLOCK DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	11:29	10-Jun-2020	13:00	91	0.00003	SYSTEM SCHEDULE OUTAGE
214	10-Jun-2020	PART OF F BLOCK (DSIDC ,NARELA)	2	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	12:10	10-Jun-2020	12:55	45	0.00001	SYSTEM SCHEDULE OUTAGE
215	10-Jun-2020	PART OF STAND WALA KUSHAK HIRANKI	9	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	12:17	10-Jun-2020	16:39	262	0.00007	FORCE MAJEURE DUE TO SABOTAGE
216	10-Jun-2020	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI	224	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	15:22	10-Jun-2020	17:00	98	0.00008	INTERRUPTION DUE TO FAULTS
217	10-Jun-2020	PARTS OF GAUTAM COLONY AND SANJAY COLONY	2660	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:32	10-Jun-2020	17:00	28	0.00031	INTERRUPTION DUE TO FAULTS
218	10-Jun-2020	PARTS OF BLOCK - G DSIDC NARELA INDUSTRIAL AREA.	65	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:58	10-Jun-2020	17:35	37	0.00067	INTERRUPTION DUE TO FAULTS
219	10-Jun-2020	PARTS OF E BLOCK (DSIDC NARELA)	113	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:57	10-Jun-2020	17:30	33	0.00087	INTERRUPTION DUE TO FAULTS
220	10-Jun-2020	PARTS OF F-1884 DSIDC NARELA	59	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:57	10-Jun-2020	17:15	18	0.00020	INTERRUPTION DUE TO FAULTS
221	10-Jun-2020	PARTS OF C BLOCK (DSIDC NARELA)	54	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:58	10-Jun-2020	17:40	42	0.00056	INTERRUPTION DUE TO FAULTS
222	10-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3878	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:51	10-Jun-2020	19:30	159	0.00186	FORCE MAJEURE DUE TO RAIN/STORM
223	10-Jun-2020	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	357	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:56	11-Jun-2020	00:05	429	0.00072	FORCE MAJEURE DUE TO RAIN/STORM
224	10-Jun-2020	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	473	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:56	11-Jun-2020	00:05	429	0.00072	FORCE MAJEURE DUE TO RAIN/STORM
225	10-Jun-2020	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	45	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:56	11-Jun-2020	00:05	429	0.00024	FORCE MAJEURE DUE TO RAIN/STORM
226	10-Jun-2020	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	37	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:56	11-Jun-2020	14:00	1264	0.00105	FORCE MAJEURE DUE TO RAIN/STORM

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
227	10-Jun-2020	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA	245	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:00	10-Jun-2020	21:30	270	0.00188	FORCE MAJEURE DUE TO RAIN/STORM
228	10-Jun-2020	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL.	906	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:56	10-Jun-2020	21:00	244	0.00170	FORCE MAJEURE DUE TO RAIN/STORM
229	10-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	1019	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:57	10-Jun-2020	17:40	43	0.00030	INTERRUPTION DUE TO FAULTS
230	10-Jun-2020	PARTS OF DDA B-2, POCKET A, D, H NARELA	636	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:54	10-Jun-2020	17:15	21	0.00007	INTERRUPTION DUE TO FAULTS
231	10-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	387	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	19:00	12-Jun-2020	04:05	1985	0.00827	FORCE MAJEURE DUE TO RAIN/STORM
232	10-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	67	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	01:31	10-Jun-2020	02:14	44	0.00001	INTERRUPTION DUE TO FAULTS
233	10-Jun-2020	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	62	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	11:21	10-Jun-2020	13:13	112	0.00006	INTERRUPTION DUE TO FAULTS
234	10-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	4027	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:54	10-Jun-2020	19:33	159	0.00221	FORCE MAJEURE DUE TO RAIN/STORM
235	10-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	807	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	19:31	11-Jun-2020	14:00	1109	0.00401	FORCE MAJEURE DUE TO RAIN/STORM
236	10-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2636	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:56	10-Jun-2020	18:10	74	0.00205	INTERRUPTION DUE TO FAULTS
237	10-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	659	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:56	10-Jun-2020	19:45	168	0.00117	FORCE MAJEURE DUE TO RAIN/STORM
238	10-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	696	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:56	11-Jun-2020	05:50	773	0.00537	FORCE MAJEURE DUE TO RAIN/STORM
239	10-Jun-2020	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	2609	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:56	10-Jun-2020	17:15	18	0.00051	INTERRUPTION DUE TO FAULTS
240	10-Jun-2020	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	38	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:56	10-Jun-2020	20:50	233	0.00032	FORCE MAJEURE DUE TO RAIN/STORM
241	10-Jun-2020	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI	84	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:56	10-Jun-2020	23:59	422	0.00293	FORCE MAJEURE DUE TO RAIN/STORM
242	10-Jun-2020	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	88	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:58	10-Jun-2020	18:00	62	0.00003	INTERRUPTION DUE TO FAULTS
243	10-Jun-2020	PARTS OF E BLOCK (DSIDC NARELA)	33	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:55	10-Jun-2020	20:10	194	0.00011	FORCE MAJEURE DUE TO RAIN/STORM
244	10-Jun-2020	PARTS OF A5 POLICE COLONY, A5 PKT 6 FLATS	2562	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:54	10-Jun-2020	17:20	27	0.00034	INTERRUPTION DUE TO FAULTS
245	10-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	1364	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:01	10-Jun-2020	19:40	159	0.00221	FORCE MAJEURE DUE TO RAIN/STORM
246	10-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	2117	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:01	10-Jun-2020	17:35	34	0.00057	INTERRUPTION DUE TO FAULTS
247	10-Jun-2020	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION	4611	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:58	10-Jun-2020	17:15	17	0.00093	INTERRUPTION DUE TO FAULTS
248	10-Jun-2020	PARTS OF DSIIDC E-860 TO E-871 AND E-776 TO E-797	42	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:03	10-Jun-2020	17:45	42	0.00014	INTERRUPTION DUE TO FAULTS
249	10-Jun-2020	PARTS OF DSIDC-1 VILLAGE NARELA	2595	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:05	10-Jun-2020	17:20	15	0.00035	INTERRUPTION DUE TO FAULTS
250	10-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	2722	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:54	10-Jun-2020	18:35	101	0.00169	INTERRUPTION DUE TO FAULTS
251	10-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	1645	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:22	11-Jun-2020	11:53	1110	0.00617	FORCE MAJEURE DUE TO RAIN/STORM
252	10-Jun-2020	PARTS OF HVDS ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	1559	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:02	10-Jun-2020	17:28	26	0.00036	INTERRUPTION DUE TO FAULTS
253	10-Jun-2020	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	552	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:14	10-Jun-2020	17:45	31	0.00009	INTERRUPTION DUE TO FAULTS
254	10-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	1594	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:18	10-Jun-2020	17:50	31	0.00069	INTERRUPTION DUE TO FAULTS
255	10-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	1473	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:16	11-Jun-2020	08:50	934	0.01038	FORCE MAJEURE DUE TO RAIN/STORM
256	10-Jun-2020	PARTS OF KURAINI MODE, KURAINI BASTI, ICICI BANK NARELA, EID GAH	1422	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:04	10-Jun-2020	17:50	47	0.00013	INTERRUPTION DUE TO FAULTS
257	10-Jun-2020	PARTS OF DSIIDC FACTORY NO:E-664 TO E-679	79	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:24	10-Jun-2020	17:55	32	0.00013	INTERRUPTION DUE TO FAULTS
258	10-Jun-2020	PARTS OF E BLOCK (DSIDC NARELA)	33	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:06	10-Jun-2020	18:30	24	0.00010	INTERRUPTION DUE TO FAULTS
259	10-Jun-2020	PARTS OF TEJSINGH KHERAKALAN , JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN	404	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:30	10-Jun-2020	18:50	20	0.00008	INTERRUPTION DUE TO FAULTS
260	10-Jun-2020	PARTS OF DJB MW CONSUMER, PART OF HOLAMBI KALAN.	1219	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:16	10-Jun-2020	18:45	29	0.00008	INTERRUPTION DUE TO FAULTS
261	10-Jun-2020	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	637	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:39	10-Jun-2020	19:20	41	0.00017	INTERRUPTION DUE TO FAULTS
262	10-Jun-2020	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY,PREEM NAGAR.	126	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	19:28	10-Jun-2020	19:40	12	0.00003	INTERRUPTION DUE TO FAULTS
263	10-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	186	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	19:24	10-Jun-2020	20:15	51	0.00014	INTERRUPTION DUE TO FAULTS
264	10-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	60	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	21:37	10-Jun-2020	22:05	27	0.00004	INTERRUPTION DUE TO FAULTS
265	10-Jun-2020	PART OF POCKET - H NARELA	13	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	00:40	10-Jun-2020	01:50	70	0.00002	INTERRUPTION DUE TO FAULTS
266	10-Jun-2020	PARTS OF DDA B-2, POCKET A, D, H NARELA	88	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	01:05	10-Jun-2020	01:50	45	0.00001	INTERRUPTION DUE TO FAULTS
267	10-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	1019	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	01:16	10-Jun-2020	01:23	7	0.00010	INTERRUPTION DUE TO FAULTS
268	10-Jun-2020	PART OF KHERAKALAN ALIPUR NARELA	10	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	01:29	10-Jun-2020	02:29	60	0.00002	INTERRUPTION DUE TO FAULTS
269	10-Jun-2020	PARTS OF STAND WALA KUSHAK HIRANKI, RAGHUBEER WALA RAMJANPUR, HIRANKI BUS STAND NO-1	1955	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	22:05	10-Jun-2020	22:20	15	0.00046	INTERRUPTION DUE TO FAULTS
270	10-Jun-2020	PART OF F BLOCK (DSIDC ,NARELA)	2	315 kVA	UNPLANNED OUTAGE	10-Jun-2020	11:33	10-Jun-2020	12:29	56	0.00002	SYSTEM SCHEDULE OUTAGE
271	10-Jun-2020	PART OF E-695 DSIDC NARELA	3	250 kVA	UNPLANNED OUTAGE	10-Jun-2020	13:39	10-Jun-2020	14:50	71	0.00002	SYSTEM SCHEDULE OUTAGE
272	10-Jun-2020	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER	183	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	11:49	10-Jun-2020	16:42	293	0.00016	PLANNED OUTAGE
273	10-Jun-2020	PART OF SUNGER PUR VILLAGE NARELA	8	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	14:33	10-Jun-2020	15:07	34	0.00001	SYSTEM SCHEDULE OUTAGE
274	11-Jun-2020	PARTS OF GAUTAM COLONY AND SANJAY COLONY	2651	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	09:14	11-Jun-2020	09:20	6	0.00011	INTERRUPTION DUE TO FAULTS
275	11-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	1559	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	10:09	11-Jun-2020	10:35	26	0.00013	INTERRUPTION DUE TO FAULTS
276	11-Jun-2020	PART OF E BLOCK (DSIDC NARELA)	4	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	00:01	11-Jun-2020	01:20	79	0.00002	INTERRUPTION DUE TO FAULTS
277	11-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	99	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	10:19	11-Jun-2020	14:30	251	0.00014	FORCE MAJEURE DUE TO SABOTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
278	11-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	1355	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	21:35	11-Jun-2020	23:50	135	0.00113	FORCE MAJEURE DUE TO SABOTAGE
279	11-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3878	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	21:35	11-Jun-2020	23:55	140	0.00933	FORCE MAJEURE DUE TO SABOTAGE
280	11-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3256	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	16:00	11-Jun-2020	17:30	90	0.00100	INTERRUPTION DUE TO FAULTS
281	11-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	415	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	12:59	11-Jun-2020	13:17	18	0.00004	INTERRUPTION DUE TO FAULTS
282	28-Jun-2020	PARTS OF DSIIDC FACTORY NO:J-2293 TO J-3116 AND J-2824 NARELA	26	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	21:35	28-Jun-2020	22:30	55	0.00008	INTERRUPTION DUE TO FAULTS
283	11-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	41	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	16:17	12-Jun-2020	17:50	1533	0.00426	FORCE MAJEURE DUE TO RAIN/STORM
284	11-Jun-2020	PARTS OF RICHPAL WALA , NATIONAL PUBLIC SCHOOL, SHIV MANDIR COLONY WALA, HAZARI-BIHARI, NPS SAFIYABAD ROAD	503	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	01:25	11-Jun-2020	02:30	65	0.00027	INTERRUPTION DUE TO FAULTS
285	11-Jun-2020	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY	1278	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	08:19	11-Jun-2020	09:44	85	0.00035	INTERRUPTION DUE TO FAULTS
286	11-Jun-2020	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY	611	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	08:19	11-Jun-2020	12:00	221	0.00049	FORCE MAJEURE DUE TO SABOTAGE
287	11-Jun-2020	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY	2660	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	11:11	11-Jun-2020	12:00	49	0.00041	INTERRUPTION DUE TO FAULTS
288	11-Jun-2020	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY	2711	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	11:30	11-Jun-2020	11:56	26	0.00022	INTERRUPTION DUE TO FAULTS
289	11-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	287	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	08:39	11-Jun-2020	09:00	21	0.00006	INTERRUPTION DUE TO FAULTS
290	11-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	4611	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	08:58	11-Jun-2020	10:57	119	0.00231	INTERRUPTION DUE TO FAULTS
291	11-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	1725	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	09:13	11-Jun-2020	12:20	187	0.00104	FORCE MAJEURE DUE TO SABOTAGE
292	11-Jun-2020	PARTS OF TEJSINGH KHERAKALAN , JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN	404	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	11:10	11-Jun-2020	11:35	24	0.00005	INTERRUPTION DUE TO FAULTS
293	11-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	1885	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	11:51	11-Jun-2020	14:00	129	0.00108	FORCE MAJEURE DUE TO SABOTAGE
294	11-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2514	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	12:27	11-Jun-2020	13:15	48	0.00040	INTERRUPTION DUE TO FAULTS
295	11-Jun-2020	PARTS OF C-611 DSIDC NARELA	44	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	13:11	11-Jun-2020	14:17	66	0.00002	INTERRUPTION DUE TO FAULTS
296	11-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	99	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	14:51	11-Jun-2020	15:39	49	0.00003	INTERRUPTION DUE TO FAULTS
297	11-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	3243	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	16:58	11-Jun-2020	17:25	27	0.00015	INTERRUPTION DUE TO FAULTS
298	11-Jun-2020	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION	4961	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	18:10	11-Jun-2020	18:21	10	0.00034	INTERRUPTION DUE TO FAULTS
299	11-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	82	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	19:24	11-Jun-2020	20:30	66	0.00018	INTERRUPTION DUE TO FAULTS
300	11-Jun-2020	PARTS OF RICHPAL WALA , NATIONAL PUBLIC SCHOOL, SHIV MANDIR COLONY WALA, HAZARI-BIHARI, NPS SAFIYABAD ROAD	2962	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	21:16	11-Jun-2020	22:11	55	0.00092	INTERRUPTION DUE TO FAULTS
301	11-Jun-2020	PART OF E BLOCK (DSIDC NARELA)	5	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	11:03	11-Jun-2020	11:45	42	0.00001	INTERRUPTION DUE TO FAULTS
302	30-Jun-20	PART OF DSIIDC FACTORY NO:J-2293 NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	16:17	30-Jun-20	16:54	37	0.00001	INTERRUPTION DUE TO FAULTS
303	12-Jun-2020	PARTS OF GHOGHA VILLAGE NARELA	1182	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	10:31	12-Jun-2020	11:00	29	0.00012	INTERRUPTION DUE TO FAULTS
304	11-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA	22	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	12:59	12-Jun-2020	10:45	1306	0.00181	FORCE MAJEURE DUE TO RAIN/STORM
305	12-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	910	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	01:20	12-Jun-2020	02:01	41	0.00040	INTERRUPTION DUE TO FAULTS
306	12-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	910	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	03:49	12-Jun-2020	04:05	16	0.00011	INTERRUPTION DUE TO FAULTS
307	12-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	1298	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	04:15	12-Jun-2020	04:21	6	0.00005	INTERRUPTION DUE TO FAULTS
308	12-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	3243	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	04:29	12-Jun-2020	05:15	46	0.00179	INTERRUPTION DUE TO FAULTS
309	12-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	1298	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	04:39	12-Jun-2020	04:45	6	0.00009	INTERRUPTION DUE TO FAULTS
310	12-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	910	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	05:12	12-Jun-2020	06:30	78	0.00054	INTERRUPTION DUE TO FAULTS
311	12-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	388	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	05:12	12-Jun-2020	17:59	767	0.00256	FORCE MAJEURE DUE TO SABOTAGE
312	12-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	415	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	09:54	12-Jun-2020	10:45	51	0.00014	INTERRUPTION DUE TO FAULTS
313	12-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	542	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	06:40	12-Jun-2020	08:15	95	0.00029	INTERRUPTION DUE TO FAULTS
314	12-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	1922	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	07:00	12-Jun-2020	08:15	75	0.00067	INTERRUPTION DUE TO FAULTS
315	12-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	84	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	08:30	12-Jun-2020	09:15	45	0.00021	INTERRUPTION DUE TO FAULTS
316	12-Jun-2020	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION	4907	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:10	12-Jun-2020	13:25	15	0.00051	INTERRUPTION DUE TO FAULTS
317	12-Jun-2020	PARTS OF KURAINI MODE, KURAINI BASTI, ICICI BANK NARELA, EID GAH	1422	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:39	12-Jun-2020	14:00	21	0.00018	INTERRUPTION DUE TO FAULTS
318	12-Jun-2020	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA	1719	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:50	12-Jun-2020	17:10	200	0.00167	FORCE MAJEURE DUE TO RAIN/STORM
319	12-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	1347	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	16:49	12-Jun-2020	17:50	61	0.00017	INTERRUPTION DUE TO FAULTS
320	12-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	2530	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	10:43	12-Jun-2020	11:25	42	0.00111	INTERRUPTION DUE TO FAULTS
321	12-Jun-2020	PARTS OF GHOGHA VILLAGE NARELA	1205	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:30	12-Jun-2020	12:45	15	0.00021	INTERRUPTION DUE TO FAULTS
322	12-Jun-2020	PARTS OF DSIDC BHORGARH VILLAGE NARELA	46	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:00	12-Jun-2020	13:51	51	0.00021	INTERRUPTION DUE TO FAULTS
323	12-Jun-2020	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY,PREEM NAGAR.	97	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	14:14	12-Jun-2020	15:15	62	0.00003	INTERRUPTION DUE TO FAULTS
324	12-Jun-2020	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I	169	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	15:27	12-Jun-2020	16:30	64	0.00018	INTERRUPTION DUE TO FAULTS
325	12-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	87	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	19:24	12-Jun-2020	19:36	12	0.00003	INTERRUPTION DUE TO FAULTS
326	12-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	3176	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	19:50	12-Jun-2020	20:55	65	0.00122	INTERRUPTION DUE TO FAULTS
327	12-Jun-2020	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I	169	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	20:00	12-Jun-2020	20:37	37	0.00010	INTERRUPTION DUE TO FAULTS
328	12-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3501	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	16:22	12-Jun-2020	17:10	48	0.00184	INTERRUPTION DUE TO FAULTS
329	12-Jun-2020	PART OF BLOCK-B DSIDC NARELA INDUSTRIAL AREA.	5	315 kVA	UNPLANNED OUTAGE	12-Jun-2020	11:01	12-Jun-2020	12:04	63	0.00002	SYSTEM SCHEDULE OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
330	12-Jun-2020	PART OF G BLOCK DSIDC NRL	5	400 kVA	UNPLANNED OUTAGE	12-Jun-2020	11:45	12-Jun-2020	13:02	77	0.00002	SYSTEM SCHEDULE OUTAGE
331	12-Jun-2020	PART OF DEDICATED HT CONSUMER - RAJA HARISHCHAND GOVT. HOSPITAL	6	250 kVA	UNPLANNED OUTAGE	12-Jun-2020	14:19	12-Jun-2020	17:04	165	0.00005	FORCE MAJEURE DUE TO SABOTAGE
332	12-Jun-2020	PARTS OF SHASTRIPARK, KAUSHIK ENCLAVE B-BLOCK, JMP SCHOOL	810	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	10:11	12-Jun-2020	11:00	49	0.00011	PLANNED OUTAGE
333	12-Jun-2020	PARTS OF SHASTRIPARK, KAUSHIK ENCLAVE B-BLOCK, JMP SCHOOL	798	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	13:24	12-Jun-2020	14:15	51	0.00011	PLANNED OUTAGE
334	12-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	53	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	12:00	12-Jun-2020	14:55	175	0.00005	PLANNED OUTAGE
335	12-Jun-2020	PART OF SINGHOLA VILLAGE NARELA	15	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	18:26	12-Jun-2020	18:50	24	0.00007	SYSTEM SCHEDULE OUTAGE
336	13-Jun-2020	PART OF APPOLO CONVENT SCHOOL NARELA	1	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	09:53	13-Jun-2020	15:50	357	0.0001	PLANNED OUTAGE
337	13-Jun-2020	PARTS OF DSIDC BHORGARH VILLAGE NARELA	519	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	02:49	13-Jun-2020	03:17	28	0.00023	INTERRUPTION DUE TO FAULTS
338	13-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	1473	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	20:46	13-Jun-2020	21:35	49	0.00079	SYSTEM SCHEDULE OUTAGE
339	13-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	608	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	19:19	13-Jun-2020	19:55	36	0.00010	INTERRUPTION DUE TO FAULTS
340	13-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2445	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	20:26	13-Jun-2020	20:51	25	0.00073	INTERRUPTION DUE TO FAULTS
341	13-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	58	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	07:50	13-Jun-2020	08:20	30	0.00004	INTERRUPTION DUE TO FAULTS
342	13-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	264	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	13:09	13-Jun-2020	14:00	51	0.00007	INTERRUPTION DUE TO FAULTS
343	13-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	1085	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:36	13-Jun-2020	14:50	14	0.00004	INTERRUPTION DUE TO FAULTS
344	13-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	2777	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:36	13-Jun-2020	15:20	44	0.00061	INTERRUPTION DUE TO FAULTS
345	13-Jun-2020	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	679	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:54	13-Jun-2020	15:20	26	0.00004	INTERRUPTION DUE TO FAULTS
346	13-Jun-2020	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA	1446	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:57	13-Jun-2020	15:10	13	0.00005	INTERRUPTION DUE TO FAULTS
347	13-Jun-2020	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	3092	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:02	13-Jun-2020	15:20	18	0.00015	INTERRUPTION DUE TO FAULTS
348	13-Jun-2020	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING	2000	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:05	13-Jun-2020	15:20	15	0.00013	INTERRUPTION DUE TO FAULTS
349	13-Jun-2020	PARTS OF NANGLI KIOSK ALIPUR NARELA	267	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:54	13-Jun-2020	16:10	75	0.00011	INTERRUPTION DUE TO FAULTS
350	13-Jun-2020	PART OF A BLOCK DSIDC NARELA	5	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:59	13-Jun-2020	17:12	73	0.00002	SYSTEM SCHEDULE OUTAGE
351	13-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3501	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:19	13-Jun-2020	17:00	41	0.00034	INTERRUPTION DUE TO FAULTS
352	13-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	84	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:38	13-Jun-2020	18:05	87	0.00002	INTERRUPTION DUE TO FAULTS
353	13-Jun-2020	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING	2000	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:34	13-Jun-2020	17:50	16	0.00023	INTERRUPTION DUE TO FAULTS
354	13-Jun-2020	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	3054	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:46	13-Jun-2020	18:00	14	0.00020	INTERRUPTION DUE TO FAULTS
355	13-Jun-2020	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	38	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:50	13-Jun-2020	19:41	111	0.00015	INTERRUPTION DUE TO FAULTS
356	13-Jun-2020	PART OF SANNOTH VILLAGE NARELA	6	400 kVA	PLANNED OUTAGE	13-Jun-2020	13:11	13-Jun-2020	14:26	75	0.00002	PLANNED OUTAGE
357	13-Jun-2020	PARTS OF NANGLI KIOSK ALIPUR NARELA	910	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	08:58	13-Jun-2020	09:30	32	0.00014	INTERRUPTION DUE TO FAULTS
358	13-Jun-2020	PARTS OF NANGLI KIOSK ALIPUR NARELA	89	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	08:58	13-Jun-2020	12:30	212	0.00006	FORCE MAJEURE DUE TO SABOTAGE
359	13-Jun-2020	PARTS OF GAUTAM COLONY AND SANJAY COLONY	2592	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	11:15	13-Jun-2020	12:15	60	0.00212	INTERRUPTION DUE TO FAULTS
360	13-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	2135	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:24	13-Jun-2020	14:45	20	0.00028	INTERRUPTION DUE TO FAULTS
361	13-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	147	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:39	13-Jun-2020	16:30	51	0.00001	INTERRUPTION DUE TO FAULTS
362	13-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2621	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	18:36	13-Jun-2020	18:56	21	0.00057	INTERRUPTION DUE TO FAULTS
363	13-Jun-2020	PARTS OF GHOGHA VILLAGE NARELA	1205	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	18:45	13-Jun-2020	19:27	42	0.00018	INTERRUPTION DUE TO FAULTS
364	13-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3501	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	09:33	13-Jun-2020	10:16	43	0.00119	INTERRUPTION DUE TO FAULTS
365	13-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	2162	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	09:49	13-Jun-2020	11:23	94	0.00084	INTERRUPTION DUE TO FAULTS
366	13-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	483	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	09:49	13-Jun-2020	11:23	94	0.00031	INTERRUPTION DUE TO FAULTS
367	13-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	125	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	09:49	13-Jun-2020	11:46	117	0.00016	INTERRUPTION DUE TO FAULTS
368	13-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	40	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	09:49	13-Jun-2020	19:50	601	0.00033	FORCE MAJEURE DUE TO SABOTAGE
369	13-Jun-2020	PART OF KHERAKALAN NARELA	2	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	21:45	13-Jun-2020	22:31	46	0.00001	INTERRUPTION DUE TO FAULTS
370	13-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	1083	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	22:09	13-Jun-2020	22:31	22	0.00021	INTERRUPTION DUE TO FAULTS
371	13-Jun-2020	PARTS OF DJB MW CONSUMER, PART OF HOLAMBI KALAN.	332	630 kVA	PLANNED OUTAGE	13-Jun-2020	10:42	13-Jun-2020	12:38	116	0.00013	PLANNED OUTAGE
372	13-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	73	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	13:51	13-Jun-2020	16:36	165	0.00005	PLANNED OUTAGE
373	13-Jun-2020	PARTS OF DJB MW CONSUMER, PART OF HOLAMBI KALAN.	182	315 kVA	PLANNED OUTAGE	13-Jun-2020	10:43	13-Jun-2020	12:35	112	0.00006	PLANNED OUTAGE
374	13-Jun-2020	PART OF F BLOCK (DSIDC ,NARELA)	5	400 kVA	PLANNED OUTAGE	13-Jun-2020	11:20	13-Jun-2020	14:45	205	0.00006	PLANNED OUTAGE
375	13-Jun-2020	PART OF E BLOCK (DSIDC NARELA)	3	315 kVA	PLANNED OUTAGE	13-Jun-2020	10:48	13-Jun-2020	14:10	202	0.00006	PLANNED OUTAGE
376	13-Jun-2020	PART OF F BLOCK (DSIDC ,NARELA)	4	315 kVA	PLANNED OUTAGE	13-Jun-2020	11:16	13-Jun-2020	14:45	209	0.00006	PLANNED OUTAGE
377	13-Jun-2020	PARTS OF H BLOCK (DSIDC NARELA)	45	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	12:02	13-Jun-2020	14:37	155	0.00004	PLANNED OUTAGE
378	13-Jun-2020	PARTS OF J-3057 DSIDC NARELA	42	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	11:02	13-Jun-2020	17:18	376	0.0001	PLANNED OUTAGE
379	13-Jun-2020	PARTS OF D BLOCK DSIDC NARELA, POLICE STATION OFFICE & BHORGARH SCHOOL(HT) NARELA.	36	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	12:53	13-Jun-2020	16:18	205	0.00006	PLANNED OUTAGE
380	13-Jun-2020	PART OF TIKRI SEWAGE PLANT NARELA	11	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	09:49	13-Jun-2020	19:50	601	0.00017	FORCE MAJEURE DUE TO SABOTAGE
381	14-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2621	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	01:04	14-Jun-2020	01:23	19	0.00056	INTERRUPTION DUE TO FAULTS
382	14-Jun-2020	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	2930	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	07:51	14-Jun-2020	08:16	25	0.00015	INTERRUPTION DUE TO FAULTS
383	14-Jun-2020	PARTS OF HVDS ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	1393	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	03:18	14-Jun-2020	03:40	22	0.00019	INTERRUPTION DUE TO FAULTS
384	14-Jun-2020	PARTS OF HVDS ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	1408	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	05:47	14-Jun-2020	06:05	19	0.00017	INTERRUPTION DUE TO FAULTS
385	14-Jun-2020	PARTS OF DSIDC-1 VILLAGE NARELA	918	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	13:41	14-Jun-2020	14:00	18	0.00013	INTERRUPTION DUE TO FAULTS
386	14-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2636	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	16:16	14-Jun-2020	16:35	18	0.00057	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
387	14-Jun-2020	PARTS OF NAYA BANS VILLAGE, KHERA KHURD VILLAGE, METRO VIHAR HOLAMBI KHURD.	1827	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	20:52	14-Jun-2020	21:18	26	0.00102	INTERRUPTION DUE TO FAULTS
388	14-Jun-2020	PARTS OF KURAINI MODE, KURAINI BASTI, ICICI BANK NARELA, EID GAH	1422	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	22:22	14-Jun-2020	22:57	35	0.00048	INTERRUPTION DUE TO FAULTS
389	14-Jun-2020	PART OF KURAINI BASTI NARELA	11	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	22:22	15-Jun-2020	02:31	249	0.00014	FORCE MAJEURE DUE TO SABOTAGE
390	14-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2621	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	00:10	14-Jun-2020	00:35	25	0.00077	INTERRUPTION DUE TO FAULTS
391	14-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	56	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	06:40	14-Jun-2020	08:10	90	0.00008	INTERRUPTION DUE TO FAULTS
392	14-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	1355	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	06:49	14-Jun-2020	07:30	41	0.00059	INTERRUPTION DUE TO FAULTS
393	14-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	2532	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	06:57	14-Jun-2020	07:43	46	0.00123	INTERRUPTION DUE TO FAULTS
394	14-Jun-2020	PART OF E BLOCK DSIDC DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	11:56	14-Jun-2020	13:10	73	0.00002	INTERRUPTION DUE TO FAULTS
395	14-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	1776	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	13:25	14-Jun-2020	14:40	75	0.00170	INTERRUPTION DUE TO FAULTS
396	14-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	372	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	13:25	14-Jun-2020	15:37	132	0.00044	FORCE MAJEURE DUE TO SABOTAGE
397	14-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	495	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	13:25	14-Jun-2020	21:25	480	0.00067	FORCE MAJEURE DUE TO SABOTAGE
398	14-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	372	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	20:49	14-Jun-2020	21:25	36	0.00011	INTERRUPTION DUE TO FAULTS
399	14-Jun-2020	PARTS OF KURENI VILLAGE, MANDI EXTN, PANJABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT.	622	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	22:57	14-Jun-2020	23:03	6	0.00004	INTERRUPTION DUE TO FAULTS
400	14-Jun-2020	PARTS OF KURENI VILLAGE, MANDI EXTN, PANJABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT.	4658	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	22:57	14-Jun-2020	23:15	18	0.00110	INTERRUPTION DUE TO FAULTS
401	15-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	65	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	13:57	15-Jun-2020	15:00	63	0.00014	FORCE MAJEURE DUE TO RAIN/STORM
402	15-Jun-2020	PARTS OF F BLOCK (DSIDC ,NARELA)	45	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	12:39	15-Jun-2020	13:10	31	0.00004	INTERRUPTION DUE TO FAULTS
403	15-Jun-2020	PARTS OF A BLOCK DSIDC NARELA	1495	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	17:55	15-Jun-2020	18:15	20	0.00033	INTERRUPTION DUE TO FAULTS
404	15-Jun-2020	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING	46	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	18:44	15-Jun-2020	19:53	69	0.00004	SYSTEM SCHEDULE OUTAGE
405	15-Jun-2020	PARTS OF C BLK DSIDC BHORGARH BAWANA	2650	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	20:44	15-Jun-2020	21:02	18	0.00023	INTERRUPTION DUE TO FAULTS
406	15-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	3266	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	22:17	15-Jun-2020	22:52	35	0.00170	INTERRUPTION DUE TO FAULTS
407	15-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	1633	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	22:17	15-Jun-2020	23:49	92	0.00192	INTERRUPTION DUE TO FAULTS
408	15-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	3266	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	23:14	15-Jun-2020	23:49	35	0.00170	INTERRUPTION DUE TO FAULTS
409	15-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	4027	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	16:03	15-Jun-2020	16:30	27	0.00019	INTERRUPTION DUE TO FAULTS
410	15-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	872	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	16:03	15-Jun-2020	17:30	87	0.00019	INTERRUPTION DUE TO FAULTS
411	15-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	807	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	13:57	15-Jun-2020	15:00	63	0.00021	INTERRUPTION DUE TO FAULTS
412	15-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	175	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	13:56	15-Jun-2020	14:34	38	0.00005	INTERRUPTION DUE TO FAULTS
413	15-Jun-2020	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	443	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	14:37	15-Jun-2020	15:10	33	0.00011	INTERRUPTION DUE TO FAULTS
414	15-Jun-2020	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	2206	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	14:37	15-Jun-2020	16:25	107	0.00054	INTERRUPTION DUE TO FAULTS
415	15-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	155	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	15:38	15-Jun-2020	16:05	26	0.00003	INTERRUPTION DUE TO FAULTS
416	15-Jun-2020	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	679	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	03:44	15-Jun-2020	04:00	16	0.00005	INTERRUPTION DUE TO FAULTS
417	15-Jun-2020	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	679	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	06:52	15-Jun-2020	07:15	23	0.00005	INTERRUPTION DUE TO FAULTS
418	16-Jun-2020	PART OF PARSHURAM CHOWK DSIDC NARELA	2	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	08:42	16-Jun-2020	09:19	37	0.00001	INTERRUPTION DUE TO FAULTS
419	16-Jun-2020	PART OF G BLOCK (DSIDC NARELA)	4	250 kVA	UNPLANNED OUTAGE	16-Jun-2020	12:46	16-Jun-2020	14:26	100	0.00003	SYSTEM SCHEDULE OUTAGE
420	16-Jun-2020	PARTS OF KURENI VILLAGE, MANDI EXTN, PANJABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT.	199	400 kVA	PLANNED OUTAGE	16-Jun-2020	13:07	16-Jun-2020	14:59	112	0.00006	PLANNED OUTAGE
421	16-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	116	315 kVA	PLANNED OUTAGE	16-Jun-2020	10:47	16-Jun-2020	13:00	133	0.00007	PLANNED OUTAGE
422	16-Jun-2020	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	679	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	07:44	16-Jun-2020	08:10	26	0.00006	INTERRUPTION DUE TO FAULTS
423	16-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	390	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	14:36	16-Jun-2020	15:08	32	0.00013	INTERRUPTION DUE TO FAULTS
424	16-Jun-2020	PART OF C BLOCK, DSIDC NRL	3	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	11:07	16-Jun-2020	12:54	107	0.00003	INTERRUPTION DUE TO FAULTS
425	16-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	39	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	21:50	16-Jun-2020	22:20	30	0.00002	INTERRUPTION DUE TO FAULTS
426	16-Jun-2020	PARTS OF ALL BLOCK OF DSIDC INDUSTRIAL AREA	89	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	13:20	16-Jun-2020	14:15	55	0.00115	INTERRUPTION DUE TO FAULTS
427	16-Jun-2020	PART OF BAKHTAWAR PUR NARELA	5	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	14:45	16-Jun-2020	17:10	145	0.00008	FORCE MAJEURE DUE TO SABOTAGE
428	16-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	149	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	05:22	16-Jun-2020	06:20	58	0.00032	INTERRUPTION DUE TO FAULTS
429	16-Jun-2020	PART OF C BLOCK 1272 NARELA	11	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	05:43	16-Jun-2020	07:00	77	0.00009	INTERRUPTION DUE TO FAULTS
430	16-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	73	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	05:43	16-Jun-2020	09:10	207	0.00115	FORCE MAJEURE DUE TO SABOTAGE
431	16-Jun-2020	PARTS OF A-10 GAS GODOWN NARELA	2338	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	06:24	16-Jun-2020	07:50	86	0.00191	INTERRUPTION DUE TO FAULTS
432	16-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	149	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	17:09	16-Jun-2020	17:28	19	0.00005	INTERRUPTION DUE TO FAULTS
433	16-Jun-2020	PARTS OF NEW KAUSHIK ENCLAVE ALI PUR NARELA	271	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	21:46	16-Jun-2020	22:20	34	0.00010	INTERRUPTION DUE TO FAULTS
434	16-Jun-2020	PART OF SUNGER PUR VILLAGE NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	19:26	16-Jun-2020	19:58	32	0.00001	INTERRUPTION DUE TO FAULTS
435	17-Jun-2020	PARTS OF APPOLO CONVENT SCHOOL, SHIV MANDIR , NURSERY WALA NO-2, MAAN PUBLIC SCHOOL NO-2	1217	400 kVA	PLANNED OUTAGE	17-Jun-2020	13:29	17-Jun-2020	14:28	59	0.0002	PLANNED OUTAGE
436	17-Jun-2020	PARTS OF APPOLO CONVENT SCHOOL, SHIV MANDIR , NURSERY WALA NO-2, MAAN PUBLIC SCHOOL NO-2	918	400 kVA	PLANNED OUTAGE	17-Jun-2020	12:13	17-Jun-2020	13:26	73	0.00018	PLANNED OUTAGE
437	17-Jun-2020	PART OF E BLOCK (DSIDC NARELA)	2	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	14:55	17-Jun-2020	16:06	71	0.00002	INTERRUPTION DUE TO FAULTS
438	17-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	73	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	15:36	17-Jun-2020	17:49	133	0.00019	FORCE MAJEURE DUE TO SABOTAGE
439	17-Jun-2020	PARTS OF A BLOCK, DSIDC NARELA	53	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	16:26	17-Jun-2020	17:03	37	0.00005	INTERRUPTION DUE TO FAULTS
440	17-Jun-2020	PARTS OF RICHPAL WALA , NATIONAL PUBLIC SCHOOL, SHIV MANDIR COLONY WALA, HAZARI-BIHARI, NPS SAFIYABAD ROAD	241	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	03:43	17-Jun-2020	04:20	37	0.00003	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
441	17-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	1735	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	07:33	17-Jun-2020	08:33	60	0.00033	INTERRUPTION DUE TO FAULTS
442	17-Jun-2020	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI	63	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	11:40	17-Jun-2020	15:00	200	0.00028	FORCE MAJEURE DUE TO SABOTAGE
443	17-Jun-2020	PART OPF HIRANKI ALIPUR NARELA	13	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	14:07	17-Jun-2020	14:59	52	0.00003	INTERRUPTION DUE TO FAULTS
444	17-Jun-2020	PARTS OF E BLOCK (DSIDC NARELA)	33	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	16:43	17-Jun-2020	17:51	68	0.00009	INTERRUPTION DUE TO FAULTS
445	17-Jun-2020	PARTS OF DJB MW CONSUMER, PART OF HOLAMBI KALAN.	2754	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	21:55	17-Jun-2020	23:01	66	0.00055	INTERRUPTION DUE TO FAULTS
446	18-Jun-2020	PART OF 58 H-BLOCK DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	15:30	18-Jun-2020	17:30	120	0.00003	INTERRUPTION DUE TO FAULTS
447	18-Jun-2020	PART OF I BLOCK,DSIDC NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	10:58	18-Jun-2020	11:30	32	0.00001	INTERRUPTION DUE TO FAULTS
448	18-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	381	400 kVA	PLANNED OUTAGE	18-Jun-2020	11:17	18-Jun-2020	13:08	111	0.00012	PLANNED OUTAGE
449	18-Jun-2020	PART OF G BLOCK DSIDC NRL	4	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	11:38	18-Jun-2020	12:10	32	0.00001	INTERRUPTION DUE TO FAULTS
450	18-Jun-2020	PARTS OF I BLOCK, DSIDC & SHAHPUR VILLAGE(RESIDENTAIL) NARELA	93	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	23:19	18-Jun-2020	23:59	40	0.00002	INTERRUPTION DUE TO FAULTS
451	18-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3323	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	23:45	19-Jun-2020	00:10	25	0.00021	INTERRUPTION DUE TO FAULTS
452	18-Jun-2020	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY	611	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	15:44	18-Jun-2020	16:36	52	0.00036	INTERRUPTION DUE TO FAULTS
453	18-Jun-2020	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I	3223	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	06:11	18-Jun-2020	06:42	32	0.00035	INTERRUPTION DUE TO FAULTS
454	18-Jun-2020	PARTS OF E BLOCK (DSIDC NARELA)	113	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	05:55	18-Jun-2020	06:15	20	0.00011	INTERRUPTION DUE TO FAULTS
455	18-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	138	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	09:46	18-Jun-2020	09:56	10	0.00001	INTERRUPTION DUE TO FAULTS
456	18-Jun-2020	PARTS OF C BLOCK (DSIDC NARELA)	43	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:26	18-Jun-2020	12:40	14	0.00012	INTERRUPTION DUE TO FAULTS
457	18-Jun-2020	PARTS OF C BLOCK (DSIDC NARELA)	51	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:26	18-Jun-2020	14:45	139	0.00116	FORCE MAJEURE DUE TO SABOTAGE
458	18-Jun-2020	PARTS OF H BLOCK (DSIDC NARELA)	72	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:35	18-Jun-2020	12:55	20	0.00044	INTERRUPTION DUE TO FAULTS
459	18-Jun-2020	PARTS OF NDPL COLONY, SOS BAWANA RAJEEV COLONY)	1460	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	15:38	18-Jun-2020	15:50	12	0.00007	INTERRUPTION DUE TO FAULTS
460	18-Jun-2020	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI	3110	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	21:41	18-Jun-2020	21:55	14	0.00012	INTERRUPTION DUE TO FAULTS
461	18-Jun-2020	PARTS OF DDA B-2, POCKET - C, F, G NARELA	46	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	22:25	18-Jun-2020	22:50	25	0.00002	INTERRUPTION DUE TO FAULTS
462	30-Jun-20	PART OF GANGA RAM COLONY NARELA	5	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	11:08	30-Jun-20	11:39	31	0.00001	INTERRUPTION DUE TO FAULTS
463	16-Jun-2020	PART OF GANGA RAM COLONY NARELA	9	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	21:00	16-Jun-2020	22:20	80	0.00002	INTERRUPTION DUE TO FAULTS
464	19-Jun-2020	PARTS OF DJB MW CONSUMER, PART OF HOLAMBI KALAN.	263	630 kVA	PLANNED OUTAGE	19-Jun-2020	14:25	19-Jun-2020	15:50	85	0.00007	PLANNED OUTAGE
465	19-Jun-2020	PARTS OF DJB MW CONSUMER, PART OF HOLAMBI KALAN.	310	400 kVA	PLANNED OUTAGE	19-Jun-2020	11:45	19-Jun-2020	13:24	99	0.00008	PLANNED OUTAGE
466	19-Jun-2020	PARTS OF DJB MW CONSUMER, PART OF HOLAMBI KALAN.	26	315 kVA	PLANNED OUTAGE	19-Jun-2020	11:43	19-Jun-2020	13:24	101	0.00003	PLANNED OUTAGE
467	19-Jun-2020	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI	83	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	09:33	19-Jun-2020	12:44	191	0.00011	FORCE MAJEURE DUE TO SABOTAGE
468	19-Jun-2020	PART OF DEDICATED HT CONSUMER - RAJA HARISHCHAND GOVT. HOSPITAL	4	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	12:03	19-Jun-2020	12:32	29	0.00001	INTERRUPTION DUE TO FAULTS
469	19-Jun-2020	PARTS OF NDPL COLONY, SOS BAWANA RAJEEV COLONY)	2711	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	14:37	19-Jun-2020	15:30	52	0.00029	INTERRUPTION DUE TO FAULTS
470	19-Jun-2020	PARTS OF NDPL COLONY, SOS BAWANA RAJEEV COLONY)	22	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	14:37	19-Jun-2020	15:40	62	0.00002	INTERRUPTION DUE TO FAULTS
471	19-Jun-2020	PARTS OF NDPL COLONY, SOS BAWANA RAJEEV COLONY)	44	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	14:37	19-Jun-2020	17:42	184	0.00005	FORCE MAJEURE DUE TO SABOTAGE
472	19-Jun-2020	PART OF BAKHTAWAR PUR NARELA	2	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	09:29	19-Jun-2020	11:00	91	0.00003	INTERRUPTION DUE TO FAULTS
473	19-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	406	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	05:38	19-Jun-2020	07:35	116	0.00013	INTERRUPTION DUE TO FAULTS
474	19-Jun-2020	PARTS OF TIKRI, SWARN JAYANTI,GANGA RAM COLONY,TAJPUR	3621	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	05:38	19-Jun-2020	09:10	211	0.00147	FORCE MAJEURE DUE TO RAIN/STORM
475	25-Jun-2020	PART OF GANGA RAM COLONY NARELA	14	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	18:34	25-Jun-2020	19:40	66	0.00004	INTERRUPTION DUE TO FAULTS
476	19-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	107	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	01:13	19-Jun-2020	02:00	48	0.00003	INTERRUPTION DUE TO FAULTS
477	19-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	158	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	07:59	19-Jun-2020	10:46	167	0.00014	FORCE MAJEURE DUE TO SABOTAGE
478	19-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	175	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	19:00	19-Jun-2020	19:36	36	0.00008	INTERRUPTION DUE TO FAULTS
479	19-Jun-2020	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI	3110	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	23:50	20-Jun-2020	00:07	18	0.00079	INTERRUPTION DUE TO FAULTS
480	19-Jun-2020	PARTS OF NANGLI KIOSK ALIPUR NARELA	999	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	02:58	19-Jun-2020	03:30	32	0.00018	INTERRUPTION DUE TO FAULTS
481	19-Jun-2020	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	909	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	03:25	19-Jun-2020	04:00	35	0.00123	INTERRUPTION DUE TO FAULTS
482	19-Jun-2020	PARTS OF A-10 GAS GODOWN NARELA	493	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	04:35	19-Jun-2020	05:25	50	0.00007	INTERRUPTION DUE TO FAULTS
483	19-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	759	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	05:53	19-Jun-2020	06:30	37	0.00010	INTERRUPTION DUE TO FAULTS
484	19-Jun-2020	PART OF SINGHOLA VILLAGE NARELA	6	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	09:14	19-Jun-2020	10:30	77	0.00002	INTERRUPTION DUE TO FAULTS
485	19-Jun-2020	PART OF SUNGER PUR VILLAGE NARELA	6	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	18:46	19-Jun-2020	19:02	16	0.000004	INTERRUPTION DUE TO FAULTS
486	20-Jun-2020	PART OF NO - 7 B-BLOCK DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	12:17	20-Jun-2020	12:48	31	0.00002	INTERRUPTION DUE TO FAULTS
487	20-Jun-2020	PART OF G BLOCK (DSIDC NARELA)	1	250 kVA	UNPLANNED OUTAGE	20-Jun-2020	11:38	20-Jun-2020	12:16	38	0.00001	SYSTEM SCHEDULE OUTAGE
488	20-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	84	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	12:03	20-Jun-2020	13:19	76	0.00002	PLANNED OUTAGE
489	20-Jun-2020	PARTS OF F-1884 DSIDC NARELA	59	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	10:39	20-Jun-2020	17:21	402	0.00011	PLANNED OUTAGE
490	20-Jun-2020	PARTS OF DSIIDC FACTORY NO: F-1829 TO F-1863 AND A-1 TO A-34	64	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	11:33	20-Jun-2020	14:58	205	0.00006	PLANNED OUTAGE
491	20-Jun-2020	PARTS OF GHOGHA VILLAGE NARELA	23	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	13:35	20-Jun-2020	14:14	39	0.00001	PLANNED OUTAGE
492	20-Jun-2020	PART OF E-695 DSIDC NARELA	5	400 kVA	PLANNED OUTAGE	20-Jun-2020	11:03	20-Jun-2020	15:20	257	0.00007	PLANNED OUTAGE
493	20-Jun-2020	PARTS OF E BLOCK (DSIDC NARELA)	32	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	18:11	20-Jun-2020	20:50	159	0.00022	FORCE MAJEURE DUE TO SABOTAGE
494	20-Jun-2020	PARTS OF TEJSINGH KHERAKALAN , JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN	284	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	16:55	20-Jun-2020	17:23	28	0.00006	INTERRUPTION DUE TO FAULTS
495	20-Jun-2020	PART OF G BLOCK (DSIDC NARELA)	2	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	19:07	20-Jun-2020	19:59	52	0.00003	INTERRUPTION DUE TO FAULTS
496	20-Jun-2020	PART OF BLOCK-B DSIDC NARELA INDUSTRIAL AREA.	3	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	20:55	20-Jun-2020	21:55	60	0.00002	INTERRUPTION DUE TO FAULTS
497	20-Jun-2020	PARTS OF DDA B-2, POCKET A, D, H NARELA	22	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	13:08	20-Jun-2020	13:43	35	0.00002	INTERRUPTION DUE TO FAULTS
498	20-Jun-2020	PARTS OF DDA B-2, POCKET A, D, H NARELA	26	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	13:18	20-Jun-2020	13:43	25	0.00003	INTERRUPTION DUE TO FAULTS
499	20-Jun-2020	PARTS OF A-10 GAS GODOWN NARELA	2338	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	00:45	20-Jun-2020	01:03	18	0.00079	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
500	20-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2621	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:17	20-Jun-2020	04:23	6	0.00003	INTERRUPTION DUE TO FAULTS
501	20-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	3443	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:16	20-Jun-2020	04:29	13	0.00054	INTERRUPTION DUE TO FAULTS
502	20-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	653	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:16	20-Jun-2020	04:30	14	0.00020	INTERRUPTION DUE TO FAULTS
503	20-Jun-2020	PARTS OF KURAINI MODE, KURAINI BASTI, ICICI BANK NARELA, EID GAH	1422	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:12	20-Jun-2020	04:28	15	0.00007	INTERRUPTION DUE TO FAULTS
504	20-Jun-2020	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION	1627	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:25	20-Jun-2020	04:40	15	0.00013	INTERRUPTION DUE TO FAULTS
505	20-Jun-2020	PARTS OF C BLK DSIDC BHORGARH BAWANA	2654	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	05:12	20-Jun-2020	06:05	52	0.00262	INTERRUPTION DUE TO FAULTS
506	20-Jun-2020	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI	224	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	05:36	20-Jun-2020	06:30	54	0.00015	INTERRUPTION DUE TO FAULTS
507	20-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	149	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	06:44	20-Jun-2020	07:30	47	0.00013	INTERRUPTION DUE TO FAULTS
508	20-Jun-2020	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA	602	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:09	20-Jun-2020	09:07	58	0.00024	INTERRUPTION DUE TO FAULTS
509	20-Jun-2020	PARTS OF ON CONNECTION OF PUMP AT CHEMICAL TRADER LAND, HARIZAN BASTI	967	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:08	20-Jun-2020	08:30	21	0.00009	INTERRUPTION DUE TO FAULTS
510	20-Jun-2020	PARTS OF TEJSINGH KHERAKALAN , JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN	688	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:16	20-Jun-2020	08:50	34	0.00011	INTERRUPTION DUE TO FAULTS
511	20-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	481	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:12	20-Jun-2020	09:14	62	0.00014	INTERRUPTION DUE TO FAULTS
512	20-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	566	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:12	20-Jun-2020	11:56	223	0.00062	FORCE MAJEURE DUE TO SABOTAGE
513	20-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3409	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	10:15	20-Jun-2020	10:45	30	0.00041	INTERRUPTION DUE TO FAULTS
514	20-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	175	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	12:29	20-Jun-2020	13:35	66	0.00009	INTERRUPTION DUE TO FAULTS
515	20-Jun-2020	PARTS OF A BLOCK (DSIDC NARELA)	103	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	18:04	20-Jun-2020	18:22	18	0.00010	INTERRUPTION DUE TO FAULTS
516	20-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	54	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	19:27	20-Jun-2020	20:30	63	0.00009	INTERRUPTION DUE TO FAULTS
517	20-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	158	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	22:49	20-Jun-2020	23:35	46	0.00019	INTERRUPTION DUE TO FAULTS
518	20-Jun-2020	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	2931	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	23:43	20-Jun-2020	23:56	14	0.00017	INTERRUPTION DUE TO FAULTS
519	21-Jun-2020	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	2949	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	00:18	21-Jun-2020	00:50	32	0.00040	INTERRUPTION DUE TO FAULTS
520	21-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	84	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	04:30	21-Jun-2020	05:10	40	0.00013	INTERRUPTION DUE TO FAULTS
521	21-Jun-2020	PARTS OF DJB-1 KHERA KHURD NARELA	548	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	05:35	21-Jun-2020	06:30	55	0.00046	INTERRUPTION DUE TO FAULTS
522	21-Jun-2020	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL.	906	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	05:54	21-Jun-2020	06:27	33	0.00032	INTERRUPTION DUE TO FAULTS
523	21-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	27	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	07:50	21-Jun-2020	09:26	96	0.00011	INTERRUPTION DUE TO FAULTS
524	21-Jun-2020	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY,PREEM NAGAR.	214	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	01:24	21-Jun-2020	02:00	36	0.00012	INTERRUPTION DUE TO FAULTS
525	21-Jun-2020	PARTS OF NAYA BANS VILLAGE, KHERA KHURD VILLAGE, METRO VIHAR HOLAMBI KHURD.	1827	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	05:10	21-Jun-2020	06:00	50	0.00101	INTERRUPTION DUE TO FAULTS
526	21-Jun-2020	PARTS OF METRO VIHAR HOLAMBI KHURD.	1057	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	10:01	21-Jun-2020	11:10	69	0.00040	INTERRUPTION DUE TO FAULTS
527	21-Jun-2020	PARTS OF NAYA BANS VILLAGE, KHERA KHURD VILLAGE, METRO VIHAR HOLAMBI KHURD.	216	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	10:42	21-Jun-2020	12:27	105	0.00015	INTERRUPTION DUE TO FAULTS
528	21-Jun-2020	PARTS OF ALL BLOCK OF DSIDC INDUSTRIAL AREA	88	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	11:38	21-Jun-2020	12:02	24	0.00008	INTERRUPTION DUE TO FAULTS
529	21-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	84	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	15:15	21-Jun-2020	15:50	35	0.00012	INTERRUPTION DUE TO FAULTS
530	21-Jun-2020	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I	169	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	15:08	21-Jun-2020	16:08	60	0.00013	INTERRUPTION DUE TO FAULTS
531	21-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	138	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	20:23	21-Jun-2020	20:50	27	0.00001	INTERRUPTION DUE TO FAULTS
532	22-Jun-2020	PART OF SINGHOLA VILLAGE NARELA	15	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	08:15	22-Jun-2020	10:00	105	0.00006	INTERRUPTION DUE TO FAULTS
533	22-Jun-2020	PART OF H BLOCK (DSIDC NARELA)	2	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	16:50	22-Jun-2020	18:12	82	0.00002	INTERRUPTION DUE TO FAULTS
534	22-Jun-2020	PART OF G BLOCK (DSIDC NARELA)	4	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	22:23	22-Jun-2020	23:20	57	0.00002	INTERRUPTION DUE TO FAULTS
535	22-Jun-2020	PART OF D-BLOCK DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	12:09	22-Jun-2020	14:00	111	0.00003	INTERRUPTION DUE TO FAULTS
536	22-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3878	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	12:51	22-Jun-2020	13:18	27	0.00030	INTERRUPTION DUE TO FAULTS
537	22-Jun-2020	PARTS OF I BLOCK,DSIDC NARELA	99	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	13:03	22-Jun-2020	18:15	312	0.00009	FORCE MAJEURE DUE TO SABOTAGE
538	22-Jun-2020	PARTS OF D BLOCK DSIDC NARELA, POLICE STATION OFFICE & BHORGARH SCHOOL(HT) NARELA.	37	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	14:26	22-Jun-2020	15:15	49	0.00001	INTERRUPTION DUE TO FAULTS
539	22-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	166	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	13:24	22-Jun-2020	16:00	155	0.00009	FORCE MAJEURE DUE TO SABOTAGE
540	22-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3256	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	15:08	22-Jun-2020	16:00	52	0.00051	INTERRUPTION DUE TO FAULTS
541	22-Jun-2020	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING	2007	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	01:43	22-Jun-2020	02:00	17	0.00062	INTERRUPTION DUE TO FAULTS
542	22-Jun-2020	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	83	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	02:03	22-Jun-2020	02:55	51	0.00001	INTERRUPTION DUE TO FAULTS
543	22-Jun-2020	PARTS OF I BLOCK,DSIDC NARELA	153	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	04:12	22-Jun-2020	04:35	22	0.00032	INTERRUPTION DUE TO FAULTS
544	22-Jun-2020	PARTS OF I BLOCK,DSIDC NARELA	153	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	07:10	22-Jun-2020	08:22	72	0.00002	INTERRUPTION DUE TO FAULTS
545	22-Jun-2020	PARTS OF I BLOCK,DSIDC NARELA	71	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	07:10	22-Jun-2020	08:29	79	0.00002	INTERRUPTION DUE TO FAULTS
546	22-Jun-2020	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL.	906	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:25	22-Jun-2020	06:20	55	0.00014	INTERRUPTION DUE TO FAULTS
547	22-Jun-2020	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	909	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:26	22-Jun-2020	06:55	89	0.00022	INTERRUPTION DUE TO FAULTS
548	22-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2635	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:31	22-Jun-2020	05:50	19	0.00026	INTERRUPTION DUE TO FAULTS
549	22-Jun-2020	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING	2007	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:47	22-Jun-2020	06:15	28	0.00031	INTERRUPTION DUE TO FAULTS
550	22-Jun-2020	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER	6595	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:58	22-Jun-2020	06:29	31	0.00113	INTERRUPTION DUE TO FAULTS
551	22-Jun-2020	PARTS OF A5 POLICE COLONY, A5 PKT 6 FLATS	2562	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	06:32	22-Jun-2020	07:00	28	0.00112	INTERRUPTION DUE TO FAULTS
552	22-Jun-2020	PARTS OF METRO VIHAR HOLAMBI KHURD.	1057	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	06:35	22-Jun-2020	07:40	65	0.00238	INTERRUPTION DUE TO FAULTS
553	22-Jun-2020	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI	2592	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	08:09	22-Jun-2020	08:20	11	0.00040	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
554	22-Jun-2020	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL.	906	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	09:56	22-Jun-2020	10:50	54	0.00015	INTERRUPTION DUE TO FAULTS
555	22-Jun-2020	PARTS OF JHANGOLA VILLAGE, KARAM SINGH TIGIPUR WALA, SCHOOL WALA JHANGOLA VILL.	3422	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	09:57	22-Jun-2020	10:50	53	0.00052	INTERRUPTION DUE TO FAULTS
556	22-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	118	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	09:49	22-Jun-2020	10:30	41	0.00001	INTERRUPTION DUE TO FAULTS
557	22-Jun-2020	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	2212	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	10:17	22-Jun-2020	11:00	43	0.00030	INTERRUPTION DUE TO FAULTS
558	22-Jun-2020	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	65	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	11:30	22-Jun-2020	17:00	330	0.00009	FORCE MAJEURE DUE TO SABOTAGE
559	22-Jun-2020	PARTS OF H BLOCK (DSIDC NARELA)	105	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	13:15	22-Jun-2020	13:30	15	0.000004	INTERRUPTION DUE TO FAULTS
560	22-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	3298	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	20:20	22-Jun-2020	20:49	29	0.00029	INTERRUPTION DUE TO FAULTS
561	22-Jun-2020	PARTS OF H BLOCK (DSIDC NARELA)	53	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	20:57	22-Jun-2020	21:15	18	0.00003	INTERRUPTION DUE TO FAULTS
562	22-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	472	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	21:05	22-Jun-2020	21:35	29	0.00012	INTERRUPTION DUE TO FAULTS
563	22-Jun-2020	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI	54	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	21:17	22-Jun-2020	21:55	38	0.00005	INTERRUPTION DUE TO FAULTS
564	22-Jun-2020	PART OF D-1543 DSIDC NARELA	4	315 kVA	UNPLANNED OUTAGE	22-Jun-2020	13:48	22-Jun-2020	14:34	46	0.00001	SYSTEM SCHEDULE OUTAGE
565	22-Jun-2020	PART OF E-695 DSIDC NARELA	4	315 kVA	UNPLANNED OUTAGE	22-Jun-2020	15:33	22-Jun-2020	16:34	61	0.00002	SYSTEM SCHEDULE OUTAGE
566	23-Jun-2020	PART OF J-3368 DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	14:21	23-Jun-2020	15:30	69	0.00002	INTERRUPTION DUE TO FAULTS
567	23-Jun-2020	PART OF DSIIDC FACTORY NO: F-1829 NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	19:58	23-Jun-2020	21:05	67	0.00002	INTERRUPTION DUE TO FAULTS
568	23-Jun-2020	PART OF D-1543 DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	22:36	23-Jun-2020	22:55	19	0.00001	INTERRUPTION DUE TO FAULTS
569	23-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3422	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	08:36	23-Jun-2020	09:43	67	0.00065	INTERRUPTION DUE TO FAULTS
570	23-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	84	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	06:58	23-Jun-2020	07:22	24	0.00013	INTERRUPTION DUE TO FAULTS
571	23-Jun-2020	PARTS OF C BLK DSIDC BHORGARH BAWANA	89	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	00:06	23-Jun-2020	00:40	35	0.00008	INTERRUPTION DUE TO FAULTS
572	23-Jun-2020	PARTS OF C BLK DSIDC BHORGARH BAWANA	200	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	04:18	23-Jun-2020	04:50	31	0.00007	INTERRUPTION DUE TO FAULTS
573	23-Jun-2020	PARTS OF AMAN VIHAR, SHAMSHAN GHAT NANGLI POONA, MURGI FARM KADIPUR, GURUDWARA GT ROAD NANGLI, MOHAN VILAS, DALMILL NANGLI POONA	2677	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	09:59	23-Jun-2020	10:25	26	0.00022	INTERRUPTION DUE TO FAULTS
574	23-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	685	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	09:53	23-Jun-2020	12:46	174	0.00048	FORCE MAJEURE DUE TO SABOTAGE
575	23-Jun-2020	PARTS OF SANNOTH VILLAGE NARELA	1294	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	13:21	23-Jun-2020	14:15	54	0.00023	INTERRUPTION DUE TO FAULTS
576	23-Jun-2020	PARTS OF I BLOCK,DSIDC NARELA	99	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	14:27	23-Jun-2020	15:10	42	0.00001	INTERRUPTION DUE TO FAULTS
577	23-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	24	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	14:42	23-Jun-2020	15:54	71	0.00002	INTERRUPTION DUE TO FAULTS
578	23-Jun-2020	PARTS OF I BLOCK,DSIDC NARELA	99	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	15:49	23-Jun-2020	17:09	80	0.00002	INTERRUPTION DUE TO FAULTS
579	23-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	186	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	18:11	23-Jun-2020	18:35	24	0.00001	INTERRUPTION DUE TO FAULTS
580	23-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	175	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	19:47	23-Jun-2020	20:11	25	0.00001	INTERRUPTION DUE TO FAULTS
581	23-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	141	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	20:37	23-Jun-2020	21:00	23	0.00006	INTERRUPTION DUE TO FAULTS
582	23-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	3152	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	21:14	23-Jun-2020	22:00	45	0.00141	INTERRUPTION DUE TO FAULTS
583	23-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	87	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	22:32	23-Jun-2020	23:05	33	0.00014	INTERRUPTION DUE TO FAULTS
584	24-Jun-2020	PART OF SINGHOLA VILLAGE NARELA	15	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	15:23	24-Jun-2020	18:00	157	0.00013	FORCE MAJEURE DUE TO SABOTAGE
585	24-Jun-2020	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	243	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	10:20	24-Jun-2020	11:00	40	0.00008	INTERRUPTION DUE TO FAULTS
586	24-Jun-2020	PART OF A5 POLICE COLONY NARELA	15	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	13:13	24-Jun-2020	13:35	22	0.00002	SYSTEM SCHEDULE OUTAGE
587	24-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	248	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	17:03	24-Jun-2020	19:25	142	0.00020	FORCE MAJEURE DUE TO SABOTAGE
588	24-Jun-2020	PARTS OF DEDICATED EXPRESS CONSUMER - IAMR	46	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	17:00	24-Jun-2020	23:51	411	0.00114	FORCE MAJEURE DUE TO SABOTAGE
589	24-Jun-2020	PARTS OF I BLOCK, DSIDC & SHAHPUR VILLAGE(RESIDENTAIL) NARELA	897	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	00:20	24-Jun-2020	00:48	27	0.00068	INTERRUPTION DUE TO FAULTS
590	24-Jun-2020	PARTS OF I BLOCK, DSIDC & SHAHPUR VILLAGE(RESIDENTAIL) NARELA	71	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	00:20	24-Jun-2020	01:10	49	0.00027	INTERRUPTION DUE TO FAULTS
591	24-Jun-2020	PARTS OF I BLOCK, DSIDC & SHAHPUR VILLAGE(RESIDENTAIL) NARELA	170	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	00:20	24-Jun-2020	01:15	54	0.00053	INTERRUPTION DUE TO FAULTS
592	24-Jun-2020	PARTS OF C BLK DSIDC BHORGARH BAWANA	311	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	01:38	24-Jun-2020	02:25	47	0.00013	INTERRUPTION DUE TO FAULTS
593	24-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	840	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	08:38	24-Jun-2020	11:00	142	0.00170	FORCE MAJEURE DUE TO SABOTAGE
594	24-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	1884	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	08:38	24-Jun-2020	13:00	262	0.00582	FORCE MAJEURE DUE TO SABOTAGE
595	24-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	1475	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	12:25	24-Jun-2020	13:00	35	0.00010	INTERRUPTION DUE TO FAULTS
596	24-Jun-2020	PARTS OF HVDS ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	2898	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	11:02	24-Jun-2020	11:15	13	0.00018	INTERRUPTION DUE TO FAULTS
597	24-Jun-2020	PARTS OF HVDS ALTERNATE PLOTS SECTOR A-9, A-10, P-2, 4, 5, 6 NARELA	1560	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	11:22	24-Jun-2020	11:30	8	0.00004	INTERRUPTION DUE TO FAULTS
598	24-Jun-2020	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	659	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	13:06	24-Jun-2020	13:40	34	0.00008	INTERRUPTION DUE TO FAULTS
599	24-Jun-2020	PARTS OF SWAROOP VIHAR ALI PUR NARELA	107	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	14:58	24-Jun-2020	15:10	12	0.00002	INTERRUPTION DUE TO FAULTS
600	24-Jun-2020	PARTS OF RICHPAL WALA , NATIONAL PUBLIC SCHOOL, SHIV MANDIR COLONY WALA, HAZARI-BIHARI, NPS SAFIYABAD ROAD	341	400 kVA	PLANNED OUTAGE	24-Jun-2020	13:19	24-Jun-2020	15:15	116	0.00013	PLANNED OUTAGE
601	24-Jun-2020	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER	516	400 kVA	PLANNED OUTAGE	24-Jun-2020	10:32	24-Jun-2020	11:40	68	0.00009	PLANNED OUTAGE
602	24-Jun-2020	PARTS OF NAYA BANS VILLAGE, KHERA KHURD VILLAGE, METRO VIHAR HOLAMBI KHURD.	1610	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	10:21	24-Jun-2020	17:00	399	0.00166	PLANNED OUTAGE
603	25-Jun-2020	PART OF PREM NAGAR NARELA	11	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	23:59	26-Jun-2020	00:35	36	0.00002	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
604	25-Jun-2020	PARTS OF KURENI VILLAGE, MANDI EXTN, PANJABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT.	1490	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:38	25-Jun-2020	15:30	52	0.00022	INTERRUPTION DUE TO FAULTS
605	25-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	1993	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	16:57	25-Jun-2020	17:50	53	0.00044	INTERRUPTION DUE TO FAULTS
606	25-Jun-2020	PART OF KABIR MANDIR WALA NO.2	6	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	20:29	25-Jun-2020	21:00	31	0.00002	INTERRUPTION DUE TO FAULTS
607	25-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2621	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	15:35	25-Jun-2020	16:20	45	0.00031	INTERRUPTION DUE TO FAULTS
608	25-Jun-2020	PARTS OF HAMID PUR, PART OF BAKOLI, TAJ PUR, PALLA, AKBAR PUR MAZARA, OM VIHAR COLONY	437	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	18:56	25-Jun-2020	19:21	25	0.00008	INTERRUPTION DUE TO FAULTS
609	25-Jun-2020	PARTS OF DSIIDC E-860 TO E-871 AND E-776 TO E-797	121	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	06:00	25-Jun-2020	06:50	50	0.00083	INTERRUPTION DUE TO FAULTS
610	25-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	87	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	06:44	25-Jun-2020	07:25	41	0.00011	INTERRUPTION DUE TO FAULTS
611	25-Jun-2020	PART OF E BLOCK DSIDC DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	08:00	25-Jun-2020	09:25	85	0.00012	INTERRUPTION DUE TO FAULTS
612	25-Jun-2020	PARTS OF E BLOCK (DSIDC NARELA)	41	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	08:21	25-Jun-2020	09:25	64	0.00075	INTERRUPTION DUE TO FAULTS
613	25-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	1464	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	11:41	25-Jun-2020	12:15	34	0.00028	INTERRUPTION DUE TO FAULTS
614	25-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	242	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	11:41	25-Jun-2020	13:05	84	0.00012	INTERRUPTION DUE TO FAULTS
615	25-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	412	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	11:41	25-Jun-2020	13:05	84	0.00033	INTERRUPTION DUE TO FAULTS
616	25-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	412	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	13:09	25-Jun-2020	14:35	86	0.00033	INTERRUPTION DUE TO FAULTS
617	25-Jun-2020	PARTS OF KURENI VILLAGE, MANDI EXTN, PANJABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT.	3858	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	13:04	25-Jun-2020	13:15	11	0.00038	INTERRUPTION DUE TO FAULTS
618	25-Jun-2020	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING	2007	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:09	25-Jun-2020	15:00	51	0.00139	INTERRUPTION DUE TO FAULTS
619	25-Jun-2020	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	909	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:13	25-Jun-2020	15:10	57	0.00173	INTERRUPTION DUE TO FAULTS
620	25-Jun-2020	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION	4548	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:16	25-Jun-2020	14:30	14	0.00019	INTERRUPTION DUE TO FAULTS
621	25-Jun-2020	PARTS OF NARELA CITY (PARTLY), INDIRA COLONY, BANKNER VILLAGE, J. J. COLONY (NARELA), RLY. ROAD NRL, LAMPUR ROAD, PYAU MANIHARI TO SINGHU BORDER	2978	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:20	25-Jun-2020	14:50	29	0.00072	INTERRUPTION DUE TO FAULTS
622	25-Jun-2020	PARTS OF TEJSINGH KHERAKALAN , JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN	404	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:26	25-Jun-2020	14:40	14	0.00003	INTERRUPTION DUE TO FAULTS
623	25-Jun-2020	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3256	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:40	25-Jun-2020	14:55	15	0.00019	INTERRUPTION DUE TO FAULTS
624	25-Jun-2020	PARTS OF DJB MW CONSUMER, PART OF HOLAMBI KALAN.	2754	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	15:54	25-Jun-2020	16:55	61	0.00067	INTERRUPTION DUE TO FAULTS
625	25-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	143	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	17:38	25-Jun-2020	18:35	57	0.00003	INTERRUPTION DUE TO FAULTS
626	25-Jun-2020	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	628	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	19:25	25-Jun-2020	19:58	33	0.00011	INTERRUPTION DUE TO FAULTS
627	25-Jun-2020	PARTS OF AIRTEL MOBILE TOWER & MOTHER DAIRY, A5 POLICE COLONY	1266	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	19:48	25-Jun-2020	20:35	47	0.00014	INTERRUPTION DUE TO FAULTS
628	25-Jun-2020	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I	169	OTHER OUTAGE	PLANNED OUTAGE	25-Jun-2020	10:44	25-Jun-2020	17:42	418	0.00023	PLANNED OUTAGE
629	26-Jun-2020	PART OF NO - 7 B-BLOCK DSIDC NARELA	3	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	16:27	26-Jun-2020	17:10	43	0.00001	INTERRUPTION DUE TO FAULTS
630	26-Jun-2020	PARTS OF STAND WALA KUSHAK HIRANKI, RAGHUBEER WALA RAMJANPUR, HIRANKI BUS STAND NO-1	91	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	07:20	26-Jun-2020	07:45	25	0.00004	INTERRUPTION DUE TO FAULTS
631	26-Jun-2020	PARTS OF E BLOCK (DSIDC NARELA)	113	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	05:35	26-Jun-2020	06:05	30	0.00008	INTERRUPTION DUE TO FAULTS
632	26-Jun-2020	PART OF KABIR MANDIR WALA NO.2	6	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	05:42	26-Jun-2020	07:59	137	0.00008	FORCE MAJEURE DUE TO SABOTAGE
633	26-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	2632	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	07:28	26-Jun-2020	07:59	31	0.00035	INTERRUPTION DUE TO FAULTS
634	26-Jun-2020	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA	528	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	08:10	26-Jun-2020	09:00	50	0.00014	INTERRUPTION DUE TO FAULTS
635	26-Jun-2020	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA	74	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	08:10	26-Jun-2020	10:30	140	0.00016	FORCE MAJEURE DUE TO RAIN/STORM
636	26-Jun-2020	PARTS OF NANGLI KIOSK ALIPUR NARELA	89	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	10:21	26-Jun-2020	15:40	319	0.00133	FORCE MAJEURE DUE TO SABOTAGE
637	26-Jun-2020	PART OF DEDICATED HT CONSUMER - RAJA HARISHCHAND GOVT. HOSPITAL	3	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	10:30	26-Jun-2020	10:50	20	0.00001	INTERRUPTION DUE TO FAULTS
638	26-Jun-2020	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	909	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	11:24	26-Jun-2020	12:20	56	0.00031	INTERRUPTION DUE TO FAULTS
639	26-Jun-2020	PARTS OF NEW KAUSHIK ENCLAVE NO-1 ALIPUR NARELA	2824	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	11:54	26-Jun-2020	12:45	51	0.00186	INTERRUPTION DUE TO FAULTS
640	26-Jun-2020	PART OF BLOCK-B DSIDC NARELA INDUSTRIAL AREA.	6	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	12:30	26-Jun-2020	13:00	30	0.00001	SYSTEM SCHEDULE OUTAGE
641	26-Jun-2020	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	909	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	13:56	26-Jun-2020	15:45	109	0.00273	INTERRUPTION DUE TO FAULTS
642	26-Jun-2020	PART OF H BLOCK (DSIDC NARELA)	2	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	14:47	26-Jun-2020	15:30	43	0.00001	SYSTEM SCHEDULE OUTAGE
643	26-Jun-2020	PARTS OF B BLOCK (DSIDC ,NARELA)	28	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	18:09	26-Jun-2020	18:32	23	0.00001	INTERRUPTION DUE TO FAULTS
644	26-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	412	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	06:35	26-Jun-2020	07:40	65	0.00018	INTERRUPTION DUE TO FAULTS
645	26-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	259	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	06:49	26-Jun-2020	07:40	51	0.00011	INTERRUPTION DUE TO FAULTS
646	26-Jun-2020	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	2638	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	00:47	26-Jun-2020	01:06	20	0.00016	INTERRUPTION DUE TO FAULTS
647	26-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	87	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	04:51	26-Jun-2020	05:30	39	0.00005	INTERRUPTION DUE TO FAULTS
648	26-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	239	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	11:23	26-Jun-2020	13:15	111	0.00046	INTERRUPTION DUE TO FAULTS
649	26-Jun-2020	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	106	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	15:54	26-Jun-2020	16:50	56	0.00016	INTERRUPTION DUE TO FAULTS
650	26-Jun-2020	PARTS OF GHOGHA VILLAGE NARELA	424	630 kVA	PLANNED OUTAGE	26-Jun-2020	11:53	26-Jun-2020	13:05	72	0.0001	PLANNED OUTAGE
651	27-Jun-2020	PART OF DSIIDC FACTORY NO:D-1501 NARELA	5	315 kVA	PLANNED OUTAGE	27-Jun-2020	11:17	27-Jun-2020	11:59	42	0.00001	PLANNED OUTAGE
652	27-Jun-2020	PARTS OF G BLOCK (DSIDC NARELA)	87	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	03:37	27-Jun-2020	04:00	23	0.00006	INTERRUPTION DUE TO FAULTS
653	27-Jun-2020	PART OF BAKHTAWAR PUR NARELA	9	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	10:00	27-Jun-2020	10:27	27	0.00002	INTERRUPTION DUE TO FAULTS
654	27-Jun-2020	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY,PREEM NAGAR.	1755	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	01:24	27-Jun-2020	01:32	8	0.00007	INTERRUPTION DUE TO FAULTS
655	27-Jun-2020	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI	206	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	13:15	27-Jun-2020	15:14	119	0.00433	INTERRUPTION DUE TO FAULTS
656	27-Jun-2020	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	1306	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	13:36	27-Jun-2020	13:55	19	0.00069	INTERRUPTION DUE TO FAULTS
657	27-Jun-2020	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	916	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	13:57	27-Jun-2020	14:50	53	0.00022	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
658	27-Jun-2020	PARTS OF ALIPUR AND HOLAMBI KALA CROSSING	383	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	17:35	27-Jun-2020	18:30	56	0.00008	INTERRUPTION DUE TO FAULTS
659	27-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	167	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	19:17	27-Jun-2020	20:34	76	0.00021	INTERRUPTION DUE TO FAULTS
660	27-Jun-2020	PARTS OF G BLOCK & CHEMICAL TRADERS DSIDC NARELA	88	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	20:44	27-Jun-2020	22:00	76	0.00017	INTERRUPTION DUE TO FAULTS
661	27-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	43	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	20:47	27-Jun-2020	21:30	43	0.00006	INTERRUPTION DUE TO FAULTS
662	27-Jun-2020	PARTS OF H BLOCK (DSIDC NARELA)	44	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	21:07	27-Jun-2020	22:10	63	0.00009	INTERRUPTION DUE TO FAULTS
663	27-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	43	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	22:27	27-Jun-2020	23:16	49	0.00011	INTERRUPTION DUE TO FAULTS
664	27-Jun-2020	PARTS OF NAYA BANS VILLAGE, KHERA KHURD VILLAGE, METRO VIHAR HOLAMBI KHURD.	436	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	22:26	27-Jun-2020	23:25	59	0.00008	INTERRUPTION DUE TO FAULTS
665	27-Jun-2020	PART OF D-1543 DSIDC NARELA	3	315 kVA	PLANNED OUTAGE	27-Jun-2020	11:33	27-Jun-2020	15:50	257	0.00007	PLANNED OUTAGE
666	27-Jun-2020	PARTS OF D BLOCK DSIDC NARELA, POLICE STATION OFFICE & BHORGARH SCHOOL(HT) NARELA.	33	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	12:37	27-Jun-2020	14:31	114	0.00003	PLANNED OUTAGE
667	27-Jun-2020	PARTS OF BLOCK - G DSIDC NARELA INDUSTRIAL AREA.	28	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	13:20	27-Jun-2020	15:19	119	0.00003	PLANNED OUTAGE
668	27-Jun-2020	PARTS OF D-1543 DSIDC NARELA	31	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	14:22	27-Jun-2020	15:12	50	0.00001	PLANNED OUTAGE
669	27-Jun-2020	PARTS OF C BLOCK 1272 DSIDC NARELA	84	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	11:53	27-Jun-2020	17:50	357	0.0001	PLANNED OUTAGE
670	27-Jun-2020	PARTS OF I BLOCK,DSIDC NARELA	54	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	11:46	27-Jun-2020	17:20	334	0.00009	PLANNED OUTAGE
671	27-Jun-2020	PART OF D-1543 DSIDC NARELA	4	400 kVA	PLANNED OUTAGE	27-Jun-2020	12:01	27-Jun-2020	15:51	230	0.00006	PLANNED OUTAGE
672	27-Jun-2020	PART OF F BLOCK (DSIDC ,NARELA)	4	315 kVA	PLANNED OUTAGE	27-Jun-2020	11:03	27-Jun-2020	14:10	187	0.00005	PLANNED OUTAGE
673	27-Jun-2020	PART OF F BLOCK (DSIDC ,NARELA)	2	315 kVA	PLANNED OUTAGE	27-Jun-2020	11:10	27-Jun-2020	14:11	181	0.00005	PLANNED OUTAGE
674	27-Jun-2020	PART OF D-BLOCK DSIDC NARELA	7	400 kVA	PLANNED OUTAGE	27-Jun-2020	10:45	27-Jun-2020	15:03	258	0.00007	PLANNED OUTAGE
675	28-Jun-2020	PART OF SUNGER PUR VILLAGE NARELA	6	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	17:55	28-Jun-2020	18:30	35	0.00001	INTERRUPTION DUE TO FAULTS
676	28-Jun-2020	PART OF NO-10 C BLOCK NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	20:11	28-Jun-2020	21:00	49	0.00001	SYSTEM SCHEDULE OUTAGE
677	28-Jun-2020	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY,PREEM NAGAR.	214	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	01:44	28-Jun-2020	02:25	40	0.00006	INTERRUPTION DUE TO FAULTS
678	28-Jun-2020	PARTS OF DJB MW CONSUMER, PART OF HOLAMBI KALAN.	1768	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	02:42	28-Jun-2020	03:50	68	0.00057	INTERRUPTION DUE TO FAULTS
679	28-Jun-2020	PARTS OF SINGHOLA BHAKTAWARPUR NARELA	82	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	23:10	29-Jun-2020	07:00	470	0.00065	FORCE MAJEURE DUE TO SABOTAGE
680	28-Jun-2020	PARTS OF KHAM PUR, TIKARI, GANGA RAM COLONY	1474	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	06:42	28-Jun-2020	07:27	45	0.00038	INTERRUPTION DUE TO FAULTS
681	28-Jun-2020	PARTS OF KURENI VILLAGE, MANDI EXTN, PANJABI COLONY, ANAJ MANDI, NAI BASTI MANDI, SHIWAJI NAGAR, KHADI ASHRAM DISTT.	271	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	13:36	28-Jun-2020	15:15	99	0.00028	INTERRUPTION DUE TO FAULTS
682	28-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	131	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	19:09	28-Jun-2020	19:20	11	0.00003	INTERRUPTION DUE TO FAULTS
683	28-Jun-2020	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY,PREEM NAGAR.	214	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	21:57	28-Jun-2020	23:00	63	0.00009	INTERRUPTION DUE TO FAULTS
684	28-Jun-2020	PARTS OF PETROL PUMP ALIPUR, PANCHYAT WALA NO-1, 2 & 3 , DAYAL MARKET, SHAMSHAN GHAT, NAV BHARAT INTERNATION	4910	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	22:20	28-Jun-2020	22:32	12	0.00074	INTERRUPTION DUE TO FAULTS
685	28-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	653	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	22:25	28-Jun-2020	23:07	42	0.00008	INTERRUPTION DUE TO FAULTS
686	28-Jun-2020	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	3443	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	22:25	28-Jun-2020	23:07	42	0.00056	INTERRUPTION DUE TO FAULTS
687	28-Jun-2020	PARTS OF KADIPUR VILLAGE, PREM NAGAR	270	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	23:03	28-Jun-2020	23:59	56	0.00008	INTERRUPTION DUE TO FAULTS
688	29-Jun-20	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	867	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	10:24	29-Jun-20	11:02	38	0.00008	PLANNED OUTAGE
689	29-Jun-20	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	372	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	14:20	29-Jun-20	15:20	60	0.00005	PLANNED OUTAGE
690	29-Jun-20	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	495	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	11:11	29-Jun-20	15:20	249	0.00028	PLANNED OUTAGE
691	29-Jun-20	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	839	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	11:52	29-Jun-20	12:30	38	0.00011	INTERRUPTION DUE TO FAULTS
692	29-Jun-20	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	1085	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	14:23	29-Jun-20	14:50	27	0.00038	INTERRUPTION DUE TO FAULTS
693	29-Jun-20	PARTS OF AIR NANGL, NEAR SAMSUNG GODOWN FACTORY,NAGALI PUNA, MTNL ALIPUR, TIVOLI GRAND, ASHOK LEYLAND,PYARE LAL, BUDHPUR GT ROAD NEW	2653	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:33	29-Jun-20	17:50	17	0.00021	INTERRUPTION DUE TO FAULTS
694	29-Jun-20	PARTS OF NAFE SINGH NO-2, KUSUM FARM, SINGHOLA VILLAGE	122	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:43	29-Jun-20	19:10	87	0.00065	INTERRUPTION DUE TO FAULTS
695	29-Jun-20	PARTS OF D-BLOCK KADI VIHAR NALE WALA ALIPUR NARELA	2914	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	19:56	29-Jun-20	20:25	29	0.00024	INTERRUPTION DUE TO FAULTS
696	29-Jun-20	PARTS OF KADIPUR VILLAGE, PREM NAGAR	158	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	09:15	29-Jun-20	10:14	59	0.00005	INTERRUPTION DUE TO FAULTS
697	29-Jun-20	PARTS OF ZONAL OFFICE (OM VIHAR COLONY), NEAR SURENDER JATIWALA, TIGGIPUR MANDIR, KABIR MANDIR WALA NO.2	2638	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	11:19	29-Jun-20	11:45	27	0.00019	INTERRUPTION DUE TO FAULTS
698	29-Jun-20	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	291	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	11:46	29-Jun-20	12:30	44	0.00005	INTERRUPTION DUE TO FAULTS
699	29-Jun-20	PARTS OF SINGHOLA VLIIAGE AND BHAKTAWARPUR NARELA	1925	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	00:40	29-Jun-20	01:34	54	0.00060	INTERRUPTION DUE TO FAULTS
700	29-Jun-20	PARTS OF PANCHAYATGHAR IBRAHAMPUR, NATHU PURA, SUSHANT VIHAR, NATHU COLONY,PREEM NAGAR.	86	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	15:10	29-Jun-20	16:00	50	0.00003	INTERRUPTION DUE TO FAULTS
701	29-Jun-20	PART OF E BLOCK (DSIDC NARELA)	4	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	16:36	29-Jun-20	17:03	27	0.00001	INTERRUPTION DUE TO FAULTS
702	29-Jun-20	PARTS OF SINGHOLA VLIIAGE AND BHAKTAWARPUR NARELA	718	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	01:25	29-Jun-20	01:34	9	0.00008	INTERRUPTION DUE TO FAULTS
703	29-Jun-20	PARTS OF SANK NO ZERO TO SANK NO 7, PART OF AGRICULTURE LAND OF PALLA ,	916	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:19	29-Jun-20	19:00	101	0.00295	INTERRUPTION DUE TO FAULTS
704	29-Jun-20	PARTS OF BRAHAM PRAKASH SUNGER PUR, IQBAL SINGH JHANGOLA	602	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:35	29-Jun-20	18:35	60	0.00042	INTERRUPTION DUE TO FAULTS
705	29-Jun-20	PARTS OF BAKOLI, BAKHTAWAR PUR, JHANGOLA, TIGGI PUR, SUNGAR PUR, TRIVENI COLONY PART TUBEWELL NETWORK	1354	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:38	29-Jun-20	18:15	37	0.00051	INTERRUPTION DUE TO FAULTS
706	29-Jun-20	PARTS OF ALIPUR, ZINDPUR, ZINDPUR COLONY, MUKHMAILPUR,, KUSAK , HIRANKI, MOHAMMADPUR, RAMJANPUR, PART OF BAKOLI	84	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:20	29-Jun-20	18:15	55	0.00015	INTERRUPTION DUE TO FAULTS
707	29-Jun-20	PARTS OF NARELA MAIN MARKET AND NARELA SUBJI MANDI	3030	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:26	29-Jun-20	18:10	44	0.00031	INTERRUPTION DUE TO FAULTS
708	29-Jun-20	PARTS OF SDM OFFICE ALIPUR & ZINDPUR AND ALI PUR VILLAGE	2589	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:31	29-Jun-20	17:55	25	0.00034	INTERRUPTION DUE TO FAULTS
709	29-Jun-20	PARTS OF TEJSINGH KHERAKALAN , JAGAT RICE MILL KHERA KALAN, JAGAT FARM NO-1 KHERA KALAN	404	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:25	29-Jun-20	19:35	70	0.00010	INTERRUPTION DUE TO FAULTS
710	29-Jun-20	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI	54	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	19:58	29-Jun-20	21:00	62	0.00003	INTERRUPTION DUE TO FAULTS
711	29-Jun-20	PARTS OF PUSHTA ROAD ALONG VILLAGES MUHAMMEDPUR-RAMJANPUR, HIRANKI, IBRAHIMPUR AND BURARI	103	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	21:57	29-Jun-20	22:15	18	0.00002	INTERRUPTION DUE TO FAULTS
712	29-Jun-20	PARTS OF C BLK DSIDC BHORGARH BAWANA	1754	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	22:44	29-Jun-20	23:30	46	0.00025	INTERRUPTION DUE TO FAULTS
713	29-Jun-20	PARTS OF C BLK DSIDC BHORGARH BAWANA	34	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	22:44	30-Jun-20	00:40	116	0.00006	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
714	29-Jun-20	PARTS OF C BLK DSIDC BHORGARH BAWANA	4944	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	22:44	30-Jun-20	00:55	131	0.00182	FORCE MAJEURE DUE TO SABOTAGE
715	29-Jun-20	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3842	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:46	29-Jun-20	18:20	34	0.00096	INTERRUPTION DUE TO FAULTS
716	30-Jun-20	PART OF E-695 DSIDC NARELA	4	315 kVA	UNPLANNED OUTAGE	30-Jun-20	14:43	30-Jun-20	15:37	54	0.00002	SYSTEM SCHEDULE OUTAGE
717	30-Jun-20	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	584	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	17:21	30-Jun-20	18:49	88	0.00049	INTERRUPTION DUE TO FAULTS
718	30-Jun-20	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3220	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	13:29	30-Jun-20	13:40	11	0.00033	INTERRUPTION DUE TO FAULTS
719	30-Jun-20	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3293	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	17:12	30-Jun-20	18:00	47	0.00132	INTERRUPTION DUE TO FAULTS
720	30-Jun-20	PARTS OF SHASTRIPARK, KAUSHIK ENCLAVE B-BLOCK, JMP SCHOOL	4775	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	12:06	30-Jun-20	12:30	24	0.00073	INTERRUPTION DUE TO FAULTS
721	30-Jun-20	PART OF F-1884 DSIDC NARELA	4	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	12:36	30-Jun-20	13:09	33	0.00001	INTERRUPTION DUE TO FAULTS
722	30-Jun-20	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	4957	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	15:04	30-Jun-20	16:55	111	0.00435	INTERRUPTION DUE TO FAULTS
723	30-Jun-20	PARTS OF PLY FACTORY BURARI ROAD, SUNGER PUR VILLAGE , MCD GIRLS PRIMARY SCHOOL, CHHATURAM PUBLIC SCHOOL	3877	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	19:58	30-Jun-20	20:20	22	0.00075	INTERRUPTION DUE TO FAULTS
724	30-Jun-20	PARTS OF SEC-B AND SEC-C DSIDC BHORGARH NARELA	1788	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	16:04	30-Jun-20	17:04	60	0.00100	INTERRUPTION DUE TO FAULTS
725	30-Jun-20	PARTS OF KADIPUR VILLAGE, PREM NAGAR	43	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	00:35	30-Jun-20	01:15	40	0.00002	INTERRUPTION DUE TO FAULTS
726	30-Jun-20	PARTS OF SEC-B AND SEC-C DSIDC BHORGARH NARELA	861	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	16:55	30-Jun-20	17:04	9	0.00008	INTERRUPTION DUE TO FAULTS
727	30-Jun-20	PARTS OF 1272 RESIDENTIAL FLATS BHORGARH INDUSTRIAL AREA	43	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	08:53	30-Jun-20	09:30	37	0.00005	INTERRUPTION DUE TO FAULTS
728	30-Jun-20	PARTS OF E BLOCK (DSIDC NARELA)	68	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	10:16	30-Jun-20	10:40	24	0.00040	INTERRUPTION DUE TO FAULTS
729	30-Jun-20	PARTS OF E BLOCK (DSIDC NARELA)	45	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	10:16	30-Jun-20	11:20	64	0.00071	INTERRUPTION DUE TO FAULTS
730	30-Jun-20	PART OF G BLOCK (DSIDC NARELA)	4	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	14:33	30-Jun-20	14:46	13	0.000004	SYSTEM SCHEDULE OUTAGE
731	30-Jun-20	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I	307	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	15:55	30-Jun-20	18:24	149	0.00124	FORCE MAJEURE DUE TO SABOTAGE
732	30-Jun-20	PARTS OF GHOGHA DAIRY COLONY BLOCK J,H,G & I	307	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	18:28	30-Jun-20	18:39	11	0.00009	INTERRUPTION DUE TO FAULTS
733	30-Jun-20	PARTS OF GHOGHA COLONY, SWATANTER NAGAR, PREM COLONY	106	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	18:53	30-Jun-20	19:25	32	0.00009	INTERRUPTION DUE TO FAULTS
734	30-Jun-20	PARTS OF NANGLI, PART OF KHERAKALAN, BAKOLI STAND.	189	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	21:16	30-Jun-20	22:15	60	0.00008	INTERRUPTION DUE TO FAULTS
					PITAMPURA							
1	4-Jun-2020	PART OF A BLOCK MANGOL PURI INDS.AREA PH-2	16	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	11:10	4-Jun-2020	13:25	134	0.00011	FORCE MAJEURE DUE TO SABOTAGE
2	11-Jun-2020	PART OF A BLOCK MANGOL PURI INDS.AREA PH-2	3	160 kVA	UNPLANNED OUTAGE	11-Jun-2020	16:19	11-Jun-2020	16:57	38	0.00001	SYSTEM SCHEDULE OUTAGE
3	1-Jun-2020	PARTS OF KAPIL VIHAR, JHULE LAL APPARTMENT, LOK VIHAR A BLOCK, PART OF CHANDER LOK	328	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	06:32	1-Jun-2020	06:50	18	0.00004	INTERRUPTION DUE TO FAULTS
4	2-Jun-2020	PARTS OF NARENDRA AUTO WORK HOUSE, B&C BLOCK	173	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	10:16	2-Jun-2020	11:35	79	0.00007	INTERRUPTION DUE TO FAULTS
5	2-Jun-2020	PARTS OF KASTURBA POLYTECHNIC, TP, ZP, SP, YP, WP,PART OF QP,PP BLOCK PITAM PURA	978	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	21:59	2-Jun-2020	22:18	19	0.00016	INTERRUPTION DUE TO FAULTS
6	30-Jun-20	PART OF BA BLOCK PITAM PURA	5	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	15:10	30-Jun-20	17:02	112	0.00003	INTERRUPTION DUE TO FAULTS
7	16-Jun-2020	PART OF BA BLOCK PITAM PURA	4	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	14:20	16-Jun-2020	15:52	92	0.00003	INTERRUPTION DUE TO FAULTS
8	17-Jun-2020	PART OF BA BLOCK PITAM PURA	10	OTHER OUTAGE	PLANNED OUTAGE	17-Jun-2020	08:07	17-Jun-2020	12:00	233	0.00006	PLANNED OUTAGE
9	3-Jun-2020	PARTS OF DEEPALI VARDHMAN MALL, TARUN ENCLAVE, DEEPALI	408	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	20:08	3-Jun-2020	21:35	87	0.00012	INTERRUPTION DUE TO FAULTS
10	4-Jun-2020	PARTS OF KASTURBA POLYTECHNIC, TP, ZP, SP, YP, WP,PART OF QP,PP BLOCK PITAM PURA	978	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	08:48	4-Jun-2020	09:10	22	0.00017	INTERRUPTION DUE TO FAULTS
11	4-Jun-2020	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	66	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:28	4-Jun-2020	18:00	31	0.00009	INTERRUPTION DUE TO FAULTS
12	5-Jun-2020	PARTS OF KOHAT ENCLAVE, B - BLOCK LOK VIHAR	1431	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	07:46	5-Jun-2020	08:01	15	0.00006	INTERRUPTION DUE TO FAULTS
13	5-Jun-2020	PARTS OF BHAGWAN MAHAVIR HOSPITAL, KEHSAV MAHAVIDYALAYA,BHAGWAN MAHAVIR STAFF QTRS	399	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	15:58	5-Jun-2020	16:50	52	0.00017	INTERRUPTION DUE TO FAULTS
14	6-Jun-2020	PARTS OF RANI BAGH, PART OF MULTANI MOHALLA	297	990 kVA	PLANNED OUTAGE	6-Jun-2020	08:02	6-Jun-2020	09:35	93	0.00008	PLANNED OUTAGE
15	7-Jun-2020	PART OF MAULANA AZAD PITAM PURA	18	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	13:35	7-Jun-2020	14:44	69	0.00004	INTERRUPTION DUE TO FAULTS
16	7-Jun-2020	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	66	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	06:11	7-Jun-2020	07:30	79	0.00007	INTERRUPTION DUE TO FAULTS
17	7-Jun-2020	PARTS OF DP, RP, QD, FP, MD, LD, PD PART OF GP BLOCK PITAM PURA	597	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	07:08	7-Jun-2020	07:35	27	0.00006	INTERRUPTION DUE TO FAULTS
18	7-Jun-2020	PARTS OF E-70 MIA PH-2, E-54 MIA PH-2, E-89,MIA PH-II	39	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:58	7-Jun-2020	11:50	112	0.00009	INTERRUPTION DUE TO FAULTS
19	7-Jun-2020	PARTS OF E-70 MIA PH-2, E-54 MIA PH-2, E-89,MIA PH-II	29	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	11:09	7-Jun-2020	11:50	41	0.00006	INTERRUPTION DUE TO FAULTS
20	7-Jun-2020	PARTS OF SANSAD VIHAR SARASWATI VIHAR PITAM PURA	64	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:57	7-Jun-2020	12:28	150	0.00021	FORCE MAJEURE DUE TO SABOTAGE
21	7-Jun-2020	PARTS OF E-70 MIA PH-2, E-54 MIA PH-2, E-89,MIA PH-II	33	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	12:28	7-Jun-2020	13:18	50	0.00007	INTERRUPTION DUE TO FAULTS
22	7-Jun-2020	PARTS OF ANAND VIHAR, PUNDRIK VIHAR, RANG MAHAL, MITRA VIHAR. PART OF SHARDA NIKTEN, RAIL VIHAR, GOLD WEDDING SOUK MALL AND RASMI APPARTMENT.	807	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	21:13	7-Jun-2020	22:20	67	0.00074	INTERRUPTION DUE TO FAULTS
23	7-Jun-2020	PARTS OF SADBHAWANA APPARTMENT. BANK VIHAR, MCD PUMP HOUSE NEAR AJAY APPARTMENT, B-BLOCK PUSHPANJLI, TARUN ENCLAVE	223	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	21:54	7-Jun-2020	22:40	47	0.00032	INTERRUPTION DUE TO FAULTS
24	8-Jun-2020	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR	2597	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	23:24	8-Jun-2020	23:40	16	0.00044	INTERRUPTION DUE TO FAULTS
25	9-Jun-2020	PART OF SADBHAWANA APPARTMENT	7	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	10:52	9-Jun-2020	13:02	130	0.00004	FORCE MAJEURE DUE TO SABOTAGE
26	10-Jun-2020	PARTS OF SANDESH VIHAR PSS, NISHANT KUNJ, POLICE COLONY, ROHIT KUNJ, M.M.PUBLIC SCHOOL, KOHAT TIKONA PARK, SIDHARTHA APPARTMENTS	636	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:09	10-Jun-2020	17:35	26	0.00018	INTERRUPTION DUE TO FAULTS
27	11-Jun-2020	PARTS OF KU, DU,AU,AU EKTA CAMP JU, G & JU, GU MARKET PITAM PURA	1216	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	12:26	11-Jun-2020	12:45	19	0.00008	INTERRUPTION DUE TO FAULTS
28	11-Jun-2020	PARTS OF SANDESH VIHAR PSS, NISHANT KUNJ, POLICE COLONY, ROHIT KUNJ, M.M.PUBLIC SCHOOL, KOHAT TIKONA PARK, SIDHARTHA APPARTMENTS	492	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	14:27	11-Jun-2020	14:51	25	0.00008	INTERRUPTION DUE TO FAULTS
29	11-Jun-2020	PARTS OF SANDESH VIHAR PSS, NISHANT KUNJ, POLICE COLONY, ROHIT KUNJ, M.M.PUBLIC SCHOOL, KOHAT TIKONA PARK, SIDHARTHA APPARTMENTS	144	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	14:27	11-Jun-2020	14:55	28	0.00012	INTERRUPTION DUE TO FAULTS
30	12-Jun-2020	PARTS OF G-BLOCK J.J COLONY, CNG PUMP RING ROAD, OMAXE, G - BLOCK	2653	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	09:58	12-Jun-2020	10:30	31	0.00044	INTERRUPTION DUE TO FAULTS
31	12-Jun-2020	PARTS OF G-BLOCK J.J COLONY, CNG PUMP RING ROAD, OMAXE, G - BLOCK	1326	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	09:58	12-Jun-2020	10:35	36	0.00020	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
32	12-Jun-2020	PARTS OF G-BLOCK J.J COLONY, CNG PUMP RING ROAD, OMAXE, G - BLOCK	503	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	09:58	12-Jun-2020	11:15	76	0.00021	INTERRUPTION DUE TO FAULTS
33	19-Jun-2020	PARTS OF KAPIL VIHAR, JHULE LAL APPARTMENT	25	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	05:33	19-Jun-2020	05:42	8	0.000002	INTERRUPTION DUE TO FAULTS
34	21-Jun-2020	PARTS OF KAPIL VIHAR, JHULE LAL APPARTMENT	25	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	16:18	21-Jun-2020	16:46	28	0.00002	SYSTEM SCHEDULE OUTAGE
35	14-Jun-2020	PARTS OF VARUN NIKETAN, BU, AU BLOCK PITAM PURA	24	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	23:42	15-Jun-2020	00:07	25	0.00001	INTERRUPTION DUE TO FAULTS
36	15-Jun-2020	PARTS OF KOHAT ENCLAVE, B - BLOCK LOK VIHAR	315	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	21:18	15-Jun-2020	22:00	42	0.00052	INTERRUPTION DUE TO FAULTS
37	16-Jun-2020	PART OF CB BLOCK EAST PITAM PURA	3	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	16:23	16-Jun-2020	17:25	61	0.00002	INTERRUPTION DUE TO FAULTS
38	16-Jun-2020	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	62	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	15:01	16-Jun-2020	15:52	51	0.00007	INTERRUPTION DUE TO FAULTS
39	16-Jun-2020	PARTS OF CB BLOCK EAST, PETROL PUMP (M. T. D.)	1738	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	16:23	16-Jun-2020	16:35	11	0.00027	INTERRUPTION DUE TO FAULTS
40	16-Jun-2020	PARTS OF KU, DU,AU,AU EKTA CAMP JU, G & JU, GU MARKET PITAM PURA	1627	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	14:20	16-Jun-2020	14:35	15	0.00016	INTERRUPTION DUE TO FAULTS
41	16-Jun-2020	PARTS OF KU, DU,AU,AU EKTA CAMP JU, G & JU, GU MARKET PITAM PURA	111	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	14:20	16-Jun-2020	15:25	65	0.00018	INTERRUPTION DUE TO FAULTS
42	17-Jun-2020	PART OF KALASH ENCLAVE PITAM PURA	2	100 kVA	UNPLANNED OUTAGE	17-Jun-2020	10:51	17-Jun-2020	12:27	96	0.00003	SYSTEM SCHEDULE OUTAGE
43	17-Jun-2020	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR	441	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	16:13	17-Jun-2020	16:44	31	0.00004	INTERRUPTION DUE TO FAULTS
44	17-Jun-2020	PARTS OF RANI BAGH NO-2, RAILWAY INDOOR, RAILWAY OUTDOOR, CAPT.SATISH MARG RISHI NAGAR, ROSHAN LAL AHUJA, OLD SABZI MANDI RISHI NAGAR	936	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	16:15	17-Jun-2020	16:44	29	0.00010	INTERRUPTION DUE TO FAULTS
45	17-Jun-2020	PARTS OF SD, RADIO MIRCHI, T V TOWER IGNOU, SPORTS COMPLEX, DTDC, PART OF GP BLK, KP KIOSK	309	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	08:59	17-Jun-2020	09:15	16	0.00004	INTERRUPTION DUE TO FAULTS
46	17-Jun-2020	PARTS OF SD, RADIO MIRCHI, T V TOWER IGNOU, SPORTS COMPLEX, DTDC, PART OF GP BLK, KP KIOSK	1025	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	08:59	17-Jun-2020	09:23	24	0.00007	INTERRUPTION DUE TO FAULTS
47	17-Jun-2020	PARTS OF SD, RADIO MIRCHI, T V TOWER IGNOU, SPORTS COMPLEX, DTDC, PART OF GP BLK, KP KIOSK	245	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	08:59	17-Jun-2020	09:30	31	0.00004	INTERRUPTION DUE TO FAULTS
48	17-Jun-2020	PARTS OF BALBIR APPARTMENT.SANGAM APPARTMENT. MILAN APPARTMENT. HARIT NIKTEN.	303	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	08:56	17-Jun-2020	10:40	104	0.00029	INTERRUPTION DUE TO FAULTS
49	17-Jun-2020	PARTS OF KASTURBA POLYTECHNIC, TP, ZP, SP, YP, WP,PART OF QP,PP BLOCK PITAM PURA	978	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	20:15	17-Jun-2020	20:42	27	0.00008	INTERRUPTION DUE TO FAULTS
50	18-Jun-2020	PARTS OF H - BLOCK TOWERS NSP + ASIA PECIFIC , H-1,2,3,4,,6,7,8,9,10 NSP	119	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	10:45	18-Jun-2020	11:06	21	0.00002	INTERRUPTION DUE TO FAULTS
51	18-Jun-2020	PARTS OF AP-1 BLOCK PITAM PURA	374	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	23:10	18-Jun-2020	23:28	19	0.00003	INTERRUPTION DUE TO FAULTS
52	19-Jun-2020	PARTS OF KU, DU,AU,AU EKTA CAMP JU, G & JU, GU MARKET PITAM PURA	111	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	07:49	19-Jun-2020	08:15	26	0.00002	INTERRUPTION DUE TO FAULTS
53	19-Jun-2020	PARTS OF KAPIL VIHAR, JHULE LAL APPARTMENT, LOK VIHAR A BLOCK, PART OF CHANDER LOK	398	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	05:33	19-Jun-2020	05:48	14	0.00002	INTERRUPTION DUE TO FAULTS
54	19-Jun-2020	PARTS OF POLICE COMPLAX, PUSHPANJALI , TARUN ENCLAVE	300	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	23:16	20-Jun-2020	03:05	228	0.00032	FORCE MAJEURE DUE TO SABOTAGE
55	19-Jun-2020	PARTS OF GGS COLLEGE OF COMMERCE, GD GOENKA, KASTURBA POLYTECHNIC, DELHI HAAT, GP & RP BLOCK	951	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	09:31	19-Jun-2020	09:55	24	0.00007	INTERRUPTION DUE TO FAULTS
56	20-Jun-2020	PART OF GP BLK PITAM PURA	11	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	17:55	20-Jun-2020	18:53	58	0.00003	INTERRUPTION DUE TO FAULTS
57	20-Jun-2020	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	66	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	12:16	20-Jun-2020	13:37	80	0.00018	INTERRUPTION DUE TO FAULTS
58	20-Jun-2020	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	86	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	12:27	20-Jun-2020	13:35	68	0.00023	INTERRUPTION DUE TO FAULTS
59	20-Jun-2020	PARTS OF POLICE COMPLAX, PUSHPANJALI , TARUN ENCLAVE	522	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	23:59	21-Jun-2020	00:25	26	0.00006	SYSTEM SCHEDULE OUTAGE
60	20-Jun-2020	PARTS OF FU, EU, CU & PART OF KP BLOCK COMERCIAL COMPLEX PITAM PURA, HOTEL CITY PARK,NARSINGH SEWA SADAN,MRG DEVLOPERS	2000	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:28	20-Jun-2020	05:10	42	0.00047	INTERRUPTION DUE TO FAULTS
61	20-Jun-2020	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	66	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	10:25	20-Jun-2020	12:11	106	0.00024	INTERRUPTION DUE TO FAULTS
62	20-Jun-2020	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	66	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	14:14	20-Jun-2020	15:39	84	0.00019	INTERRUPTION DUE TO FAULTS
63	21-Jun-2020	PARTS OF BHAGWAN MAHAVIR HOSPITAL, KEHSAV MAHAVIDYALAYA,BHAGWAN MAHAVIR STAFF QTRS	399	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	10:17	21-Jun-2020	10:47	30	0.00008	INTERRUPTION DUE TO FAULTS
64	21-Jun-2020	PARTS OF COMPLAINT CENTRE RANI BAGH	661	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	11:22	21-Jun-2020	12:13	51	0.00028	INTERRUPTION DUE TO FAULTS
65	21-Jun-2020	PARTS OF COMPLAINT CENTRE RANI BAGH	1342	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	11:22	21-Jun-2020	12:18	56	0.00047	INTERRUPTION DUE TO FAULTS
66	21-Jun-2020	PARTS OF NARENDRA AUTO WORK HOUSE, B&C BLOCK	317	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	20:45	21-Jun-2020	21:30	45	0.00004	INTERRUPTION DUE TO FAULTS
67	22-Jun-2020	PARTS OF A-BLOCK MANGOLPURI INDUSTRIAL AREA AND PARTS OF BC-BLOCK MANGOLPURI INDUSTRIAL AREA.	41	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	19:06	22-Jun-2020	19:25	19	0.00001	INTERRUPTION DUE TO FAULTS
68	22-Jun-2020	PARTS OF SAINIK VIHAR GATE NO - 4, VENUS APPT, NEELAMBER APPT, JAGRITI APPT, NAVEEN APPARTMENT	296	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	23:50	23-Jun-2020	00:31	40	0.00013	INTERRUPTION DUE TO FAULTS
69	22-Jun-2020	PARTS OF SAINIK VIHAR GATE NO - 4, VENUS APPT, NEELAMBER APPT, JAGRITI APPT, NAVEEN APPARTMENT	435	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	23:50	23-Jun-2020	00:46	55	0.00077	INTERRUPTION DUE TO FAULTS
70	22-Jun-2020	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	66	OTHER OUTAGE	PLANNED OUTAGE	22-Jun-2020	10:40	22-Jun-2020	13:28	168	0.00005	PLANNED OUTAGE
71	23-Jun-2020	PARTS OF TELEPHONE EXCHANGE, FESHION MALL, SUVIDHA KUNJ (H4/5), PITAMPURA CLUB. KESHMIRE APPARTMENT. SURKSHA APPARTMENT, KUSTURBA APPARTMENT, BANNU APPARTMENT, MAHAVIR HOSPITAL STAFF QTR	1347	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	00:12	23-Jun-2020	00:24	11	0.00007	INTERRUPTION DUE TO FAULTS
72	23-Jun-2020	PARTS OF E-70 MIA PH-2, E-54 MIA PH-2, E-89,MIA PH-II	68	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	12:45	23-Jun-2020	13:44	59	0.00002	INTERRUPTION DUE TO FAULTS
73	23-Jun-2020	PARTS OF E-70 MIA PH-2, E-54 MIA PH-2, E-89,MIA PH-II	29	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	12:45	23-Jun-2020	15:23	158	0.00004	FORCE MAJEURE DUE TO SABOTAGE
74	25-Jun-2020	PART OF BC BLOCK MANGOL PURI PH - 2	2	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	17:58	25-Jun-2020	18:30	32	0.00001	INTERRUPTION DUE TO FAULTS
75	25-Jun-2020	PARTS OF SANDESH VIHAR PSS, NISHANT KUNJ, POLICE COLONY, ROHIT KUNJ, M.M.PUBLIC SCHOOL, KOHAT TIKONA PARK, SIDHARTHA APPARTMENTS	1488	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	15:17	25-Jun-2020	15:43	26	0.00012	INTERRUPTION DUE TO FAULTS
76	26-Jun-2020	PARTS OF DUDIYAL APPTT.,MADHUBAN CHOCK DDA PUMP HOUSE.,MADHUBAN APPTT.DAKSHANI DELHI APPTT. RAMA MKT., CHUPAL VILLAGE PITAMPURA..AND PART OF B BLOCK SARASWATI VIHAR.	57	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	13:49	26-Jun-2020	14:10	21	0.00001	INTERRUPTION DUE TO FAULTS
77	27-Jun-2020	PARTS OF KOHAT ENCLAVE AND VASUDHA KUNJ PITAM PURA	542	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	08:18	27-Jun-2020	08:25	6	0.00002	INTERRUPTION DUE TO FAULTS
78	27-Jun-2020	PARTS OF KOHAT ENCLAVE AND VASUDHA KUNJ PITAM PURA	504	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	08:18	27-Jun-2020	08:30	12	0.00003	INTERRUPTION DUE TO FAULTS
79	27-Jun-2020	PARTS OF JHULA LAL NO-1, A BLOCK LOK VIHAR	248	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	09:04	27-Jun-2020	09:26	22	0.00003	INTERRUPTION DUE TO FAULTS
80	27-Jun-2020	PARTS OF ENGINEERS ENCLAVE, PART OF E BLOCK SARASWATI VIHAR.	1039	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	16:20	27-Jun-2020	16:43	22	0.00061	INTERRUPTION DUE TO FAULTS
81	27-Jun-2020	PARTS OF ENGINEERS ENCLAVE, PART OF E BLOCK SARASWATI VIHAR.	649	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	16:20	27-Jun-2020	16:50	29	0.00025	INTERRUPTION DUE TO FAULTS
82	28-Jun-2020	PARTS OF AP-1 BLOCK PITAM PURA	405	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	11:12	28-Jun-2020	11:25	13	0.00004	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
83	28-Jun-2020	PARTS OF RAJA ENCLAVE, ASHIYANA APPARTMENT, MANDAKNI APPARTMENT, EMINABAD MARKET, EMINABAD APPARTMENT, RAJASTHALI APPARTMENT, PART OF PITAMPURA VILLAGE	113	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	11:12	28-Jun-2020	11:45	33	0.00009	INTERRUPTION DUE TO FAULTS
84	28-Jun-2020	PARTS OF RAJA ENCLAVE, ASHIYANA APPARTMENT, MANDAKNI APPARTMENT, EMINABAD MARKET, EMINABAD APPARTMENT, RAJASTHALI APPARTMENT, PART OF PITAMPURA VILLAGE	919	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	11:12	28-Jun-2020	11:53	41	0.00057	INTERRUPTION DUE TO FAULTS
85	29-Jun-20	PARTS OF NARENDRA AUTO WORK HOUSE, B&C BLOCK	317	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	07:33	29-Jun-20	08:15	42	0.00008	INTERRUPTION DUE TO FAULTS
86	7-Jun-2020	PARTS OF ZP BLOCK SCHOOL , YP & TP BLOCK PITAM PURA	1695	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	10:06	7-Jun-2020	10:18	12	0.00012	INTERRUPTION DUE TO FAULTS
87	30-Jun-20	PARTS OF C & D - BLOCK J.J COLONY, M-BLOCK RAJIV GANDHI MARKET PSS, SAMRAT CINEMA PITAM PURA	1526	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	15:29	30-Jun-20	15:46	17	0.00012	INTERRUPTION DUE TO FAULTS
88	30-Jun-20	PARTS OF BA BLOCK MIA PH-2 PITAM PURA	86	OTHER OUTAGE	PLANNED OUTAGE	30-Jun-20	06:43	30-Jun-20	08:34	111	0.00003	PLANNED OUTAGE
89	30-Jun-20	PARTS OF QU, SU, BD, AD & CD BLOCK PITAM PURA	203	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	13:01	30-Jun-20	13:29	28	0.00008	INTERRUPTION DUE TO FAULTS
90	30-Jun-20	PARTS OF SIDHARTHA APPARTMENTS, M.P ENCLAVE, JEEVAN JYOTI -I & II	257	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	16:45	30-Jun-20	17:10	24	0.00008	INTERRUPTION DUE TO FAULTS
					ROHINI							
1	1-Jun-2020	PARTS OF S. T. PLANT RITHALA ROHINI	23	OTHER OUTAGE	PLANNED OUTAGE	1-Jun-2020	12:49	1-Jun-2020	16:55	246	0.00007	PLANNED OUTAGE
2	1-Jun-2020	PARTS OF TEMPO STAND WALA MANGOL PUR KALAN, KHATE WALA, MANGOLPURI POLICE STATION, PATHAR WALA, TALAB WALA	1002	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	08:21	1-Jun-2020	08:38	17	0.00009	INTERRUPTION DUE TO FAULTS
3	1-Jun-2020	PARTS OF RITHALA ROHINI	2819	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	12:31	1-Jun-2020	13:15	44	0.00038	INTERRUPTION DUE TO FAULTS
4	1-Jun-2020	PART OF SECTOR - 13 ROHINI	1	OTHER OUTAGE	PLANNED OUTAGE	1-Jun-2020	11:15	1-Jun-2020	15:32	257	0.00007	PLANNED OUTAGE
5	2-Jun-2020	PARTS OF PKT- 26 SEC-24 RITHALA ROHINI	305	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	08:17	2-Jun-2020	10:30	133	0.00037	FORCE MAJEURE DUE TO SABOTAGE
6	2-Jun-2020	PARTS OF RYAN PUBLIC SCHOOL, PKT A-5-SEC-25,	1363	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	09:17	2-Jun-2020	09:37	21	0.00012	INTERRUPTION DUE TO FAULTS
7	3-Jun-2020	PARTS OF SECTOR - 13 ROHINI (PARTLY)	133	630 kVA	PLANNED OUTAGE	3-Jun-2020	10:57	3-Jun-2020	11:55	58	0.00003	PLANNED OUTAGE
8	3-Jun-2020	PARTS OF S. T. PLANT RITHALA ROHINI	23	OTHER OUTAGE	PLANNED OUTAGE	3-Jun-2020	11:38	3-Jun-2020	16:30	292	0.00008	PLANNED OUTAGE
9	3-Jun-2020	PARTS OF RYAN PUBLIC SCHOOL, PKT A-5-SEC-25,	867	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	20:06	3-Jun-2020	20:45	39	0.00012	INTERRUPTION DUE TO FAULTS
10	3-Jun-2020	PARTS OF TPS & RITHALA KIOSK ROHINI	3096	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	06:38	3-Jun-2020	07:00	22	0.00025	INTERRUPTION DUE TO FAULTS
11	3-Jun-2020	PARTS OF B-BLOCK AVANTIKA ROHINI	3139	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	06:53	3-Jun-2020	07:18	25	0.00035	INTERRUPTION DUE TO FAULTS
12	3-Jun-2020	PART OF AMUSEMENT PARK ROHINI	12	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	12:38	3-Jun-2020	12:58	20	0.00001	INTERRUPTION DUE TO FAULTS
13	4-Jun-2020	PARTS OF RAZA PUR, SECTOR - 9 ROHINI (PARTLY)	618	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	10:49	4-Jun-2020	12:45	116	0.00048	PLANNED OUTAGE
14	4-Jun-2020	PARTS OF RYAN PUBLIC SCHOOL, PKT A-5-SEC-25,	1363	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	10:01	4-Jun-2020	10:33	32	0.00011	INTERRUPTION DUE TO FAULTS
15	4-Jun-2020	PARTS OF POKET 7,8 & 9 ROHINI	3557	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	17:45	4-Jun-2020	17:53	8	0.00014	INTERRUPTION DUE TO FAULTS
16	4-Jun-2020	PARTS OF AMUSEMENT PARK AND NALA WALA ROHINI	982	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	19:13	4-Jun-2020	19:35	21	0.00005	INTERRUPTION DUE TO FAULTS
17	5-Jun-2020	PARTS OF D & F BLOCK SECTOR - 11 ROHINI	329	630 kVA	PLANNED OUTAGE	5-Jun-2020	12:25	5-Jun-2020	13:20	55	0.00006	PLANNED OUTAGE
18	5-Jun-2020	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	462	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	09:46	5-Jun-2020	10:15	30	0.00003	INTERRUPTION DUE TO FAULTS
19	5-Jun-2020	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	106	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	09:46	5-Jun-2020	10:22	36	0.00002	INTERRUPTION DUE TO FAULTS
20	5-Jun-2020	PARTS OF PKT- 26 SEC-24 RITHALA ROHINI	1230	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	20:35	5-Jun-2020	20:55	20	0.00013	INTERRUPTION DUE TO FAULTS
21	5-Jun-2020	PARTS OF PKT- 26 SEC-24 RITHALA ROHINI	125	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	20:35	6-Jun-2020	00:20	224	0.00013	FORCE MAJEURE DUE TO SABOTAGE
22	5-Jun-2020	PARTS OF D & F BLOCK SECTOR - 11 ROHINI	611	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	13:49	5-Jun-2020	15:20	91	0.00013	INTERRUPTION DUE TO FAULTS
23	6-Jun-2020	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	102	250 kVA	PLANNED OUTAGE	6-Jun-2020	11:38	6-Jun-2020	13:12	94	0.00005	PLANNED OUTAGE
24	6-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR ROHINI	27	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	11:56	6-Jun-2020	15:03	187	0.00005	PLANNED OUTAGE
25	6-Jun-2020	PARTS OF RITHALA ROHINI	2819	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	08:41	6-Jun-2020	09:00	18	0.00025	INTERRUPTION DUE TO FAULTS
26	6-Jun-2020	PARTS OF LONG STAY HOME AND A BLOCK 3,4,5,6	1129	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	11:48	6-Jun-2020	12:30	42	0.00046	INTERRUPTION DUE TO FAULTS
27	6-Jun-2020	PARTS OF SECTOR 15 ROHIN INSTITUTIONAL AREA (PARTLY), DTC DEPOT, AUTHORITY, PETROL PUMP	156	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	19:04	6-Jun-2020	19:28	24	0.00007	INTERRUPTION DUE TO FAULTS
28	7-Jun-2020	PARTS OF PKT- 26 SEC-24 RITHALA ROHINI	305	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	00:08	7-Jun-2020	00:10	2	0.000003	INTERRUPTION DUE TO FAULTS
29	7-Jun-2020	PARTS OF SECTOR - 13 ROHINI (PARTLY)	1228	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	06:52	7-Jun-2020	07:20	29	0.00019	INTERRUPTION DUE TO FAULTS
30	7-Jun-2020	PARTS OF SECTOR - 13 ROHINI (PARTLY)	133	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	07:29	7-Jun-2020	07:36	7	0.00001	INTERRUPTION DUE TO FAULTS
31	7-Jun-2020	PARTS OF B-BLOCK AVANTIKA ROHINI	1786	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	11:29	7-Jun-2020	12:05	36	0.00015	INTERRUPTION DUE TO FAULTS
32	8-Jun-2020	PART OF 4/A RIHINI SEC-23	2	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	11:53	8-Jun-2020	15:49	236	0.00007	FORCE MAJEURE DUE TO SABOTAGE
33	8-Jun-2020	PARTS OF RITHALA ROHINI	1283	OTHER OUTAGE	PLANNED OUTAGE	8-Jun-2020	11:08	8-Jun-2020	15:30	262	0.00087	PLANNED OUTAGE
34	8-Jun-2020	PARTS OF TEMPO STAND WALA MANGOL PUR KALAN, KHATE WALA, MANGOLPURI POLICE STATION, PATHAR WALA, TALAB WALA	628	OTHER OUTAGE	PLANNED OUTAGE	8-Jun-2020	15:02	8-Jun-2020	16:40	98	0.00019	PLANNED OUTAGE
35	9-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	962	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	11:26	9-Jun-2020	11:39	13	0.00005	INTERRUPTION DUE TO FAULTS
36	9-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	215	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	11:26	9-Jun-2020	13:04	98	0.00011	INTERRUPTION DUE TO FAULTS
37	9-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	962	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	12:51	9-Jun-2020	13:04	13	0.00005	INTERRUPTION DUE TO FAULTS
38	9-Jun-2020	PARTS OF RAZA PUR, SECTOR - 9 ROHINI (PARTLY)	1442	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	03:55	9-Jun-2020	04:16	21	0.00026	INTERRUPTION DUE TO FAULTS
39	9-Jun-2020	PARTS OF JJ CLUSTER SEC 3, JAIPUR GOLDEN HOSPITAL, CRIMINOLOGY, NDPL DISPENSARY,JJ CLUSTER SEC 3,	1325	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	22:16	9-Jun-2020	22:35	19	0.00026	INTERRUPTION DUE TO FAULTS
40	9-Jun-2020	PARTS OF JJ CLUSTER SEC 3, JAIPUR GOLDEN HOSPITAL, CRIMINOLOGY, NDPL DISPENSARY,JJ CLUSTER SEC 3,	764	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	22:16	9-Jun-2020	22:57	41	0.00040	INTERRUPTION DUE TO FAULTS
41	9-Jun-2020	PARTS OF JJ CLUSTER SEC 3, JAIPUR GOLDEN HOSPITAL, CRIMINOLOGY, NDPL DISPENSARY,JJ CLUSTER SEC 3,	449	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	22:16	9-Jun-2020	23:52	96	0.00067	SYSTEM SCHEDULE OUTAGE
42	9-Jun-2020	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	474	OTHER OUTAGE	PLANNED OUTAGE	9-Jun-2020	11:10	9-Jun-2020	13:30	140	0.00019	PLANNED OUTAGE
43	9-Jun-2020	PART OF SECTOR - 9 ROHINI	2	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	03:55	9-Jun-2020	06:10	135	0.00004	FORCE MAJEURE DUE TO SABOTAGE
44	10-Jun-2020	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	106	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	14:20	10-Jun-2020	14:51	31	0.00002	INTERRUPTION DUE TO FAULTS
45	11-Jun-2020	PART OF FORENSIC LAB ROHINI	1	OTHER OUTAGE	PLANNED OUTAGE	11-Jun-2020	10:57	11-Jun-2020	14:29	212	0.00006	PLANNED OUTAGE
46	11-Jun-2020	PARTS OF SECTOR 24 RITHALA ROHINI	61	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	11:25	11-Jun-2020	13:20	115	0.00016	INTERRUPTION DUE TO FAULTS
47	11-Jun-2020	PARTS OF SECTOR 24 RITHALA ROHINI	61	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	14:39	11-Jun-2020	16:30	111	0.00015	INTERRUPTION DUE TO FAULTS
48	11-Jun-2020	PARTS OF RITHALA ROHINI	1536	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	06:41	11-Jun-2020	07:05	24	0.00008	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
49	11-Jun-2020	PARTS OF RITHALA ROHINI	1283	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	06:41	11-Jun-2020	07:12	31	0.00009	INTERRUPTION DUE TO FAULTS
50	11-Jun-2020	PARTS OF SECTOR 24 RITHALA ROHINI	1244	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	09:11	11-Jun-2020	09:30	19	0.00013	INTERRUPTION DUE TO FAULTS
51	11-Jun-2020	PARTS OF SECTOR 24 RITHALA ROHINI	93	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	09:11	11-Jun-2020	10:45	94	0.00013	INTERRUPTION DUE TO FAULTS
52	11-Jun-2020	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	771	OTHER OUTAGE	PLANNED OUTAGE	11-Jun-2020	11:24	11-Jun-2020	11:40	16	0.00003	PLANNED OUTAGE
53	11-Jun-2020	PART OF SECTOR - 9 ROHINI	2	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	11:51	11-Jun-2020	13:16	86	0.00002	INTERRUPTION DUE TO FAULTS
54	12-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR HVDS VIJAY VIHAR, A-BLOCK VIJAY VIHAR	1340	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:11	12-Jun-2020	15:10	119	0.00050	INTERRUPTION DUE TO FAULTS
55	12-Jun-2020	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	568	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	23:30	12-Jun-2020	23:52	22	0.00003	INTERRUPTION DUE TO FAULTS
56	12-Jun-2020	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	771	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	13:02	12-Jun-2020	13:25	23	0.00004	INTERRUPTION DUE TO FAULTS
57	12-Jun-2020	PARTS OF S. T. PLANT RITHALA ROHINI	1164	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:58	12-Jun-2020	13:52	53	0.00015	INTERRUPTION DUE TO FAULTS
58	12-Jun-2020	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	568	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	23:08	12-Jun-2020	23:20	11	0.00002	INTERRUPTION DUE TO FAULTS
59	12-Jun-2020	PARTS OF RYAN PUBLIC SCHOOL, PKT A-5-SEC-25,	870	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	11:18	12-Jun-2020	13:25	127	0.00028	PLANNED OUTAGE
60	13-Jun-2020	PARTS OF B-BLOCK AVANTIKA ROHINI	1760	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	19:33	13-Jun-2020	20:35	62	0.00045	INTERRUPTION DUE TO FAULTS
61	13-Jun-2020	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	142	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	11:37	13-Jun-2020	12:15	38	0.00011	INTERRUPTION DUE TO FAULTS
62	13-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	1150	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	11:52	13-Jun-2020	13:05	73	0.00024	PLANNED OUTAGE
63	13-Jun-2020	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	106	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	10:18	13-Jun-2020	12:20	122	0.00003	PLANNED OUTAGE
64	14-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR HVDS VIJAY VIHAR, A-BLOCK VIJAY VIHAR	1340	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	06:29	14-Jun-2020	07:42	73	0.00037	INTERRUPTION DUE TO FAULTS
65	15-Jun-2020	PARTS OF PKT- 26 SEC-24 RITHALA ROHINI	326	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	09:53	15-Jun-2020	12:00	127	0.00011	PLANNED OUTAGE
66	15-Jun-2020	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	284	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	03:57	15-Jun-2020	05:05	68	0.00009	INTERRUPTION DUE TO FAULTS
67	15-Jun-2020	PARTS OF JAI AMBA TOWER, RG COMPLEX SEC-9, TELEPHONE EXCHANGE, CRESCENT MALL	86	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	09:10	15-Jun-2020	09:23	13	0.000004	INTERRUPTION DUE TO FAULTS
68	15-Jun-2020	PARTS OF RITHALA ROHINI	1283	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	05:37	15-Jun-2020	06:10	34	0.00029	INTERRUPTION DUE TO FAULTS
69	15-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	40	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	23:07	16-Jun-2020	00:06	58	0.00003	INTERRUPTION DUE TO FAULTS
70	15-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	1137	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	23:50	16-Jun-2020	00:06	16	0.00010	INTERRUPTION DUE TO FAULTS
71	17-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	1177	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	23:59	18-Jun-2020	00:20	21	0.00003	INTERRUPTION DUE TO FAULTS
72	18-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	389	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	00:35	18-Jun-2020	01:25	50	0.00010	INTERRUPTION DUE TO FAULTS
73	18-Jun-2020	PARTS OF 11 B SECTOR 23 ROHINI, HERITAGE PUBLIC SCHOOL SEC-23, 11B DDA FLAT,SEC-23 FLAT RHN TR NO.2	1157	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:30	18-Jun-2020	12:50	20	0.00006	INTERRUPTION DUE TO FAULTS
74	18-Jun-2020	PARTS OF 11 B SECTOR 23 ROHINI, HERITAGE PUBLIC SCHOOL SEC-23, 11B DDA FLAT,SEC-23 FLAT RHN TR NO.2	216	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:30	18-Jun-2020	13:00	30	0.00003	INTERRUPTION DUE TO FAULTS
75	18-Jun-2020	PARTS OF 11 B SECTOR 23 ROHINI, HERITAGE PUBLIC SCHOOL SEC-23, 11B DDA FLAT,SEC-23 FLAT RHN TR NO.2	82	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:30	18-Jun-2020	14:15	105	0.00006	INTERRUPTION DUE TO FAULTS
76	18-Jun-2020	PARTS OF MURLIWALA RITHALA ROHINI	1006	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	17:19	18-Jun-2020	17:44	25	0.00062	INTERRUPTION DUE TO FAULTS
77	18-Jun-2020	PARTS OF AMUSEMENT PARK AND NALA WALA ROHINI	982	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	22:34	18-Jun-2020	23:10	36	0.00010	INTERRUPTION DUE TO FAULTS
78	18-Jun-2020	PARTS OF H.R HOSPITA, POKET 4&7 PARSHANT VIHAR	662	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	23:43	19-Jun-2020	03:00	197	0.00044	FORCE MAJEURE DUE TO SABOTAGE
79	19-Jun-2020	PARTS OF J.I.M.S. NO-1,2 & 3 AVANTIKA ROHINI	346	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	10:55	19-Jun-2020	11:23	28	0.00007	INTERRUPTION DUE TO FAULTS
80	19-Jun-2020	PARTS OF 11 B SECTOR 23 ROHINI, HERITAGE PUBLIC SCHOOL SEC-23, 11B DDA FLAT,SEC-23 FLAT RHN TR NO.2	100	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	12:30	19-Jun-2020	13:00	30	0.00002	INTERRUPTION DUE TO FAULTS
81	19-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	1121	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	23:32	19-Jun-2020	23:50	18	0.00006	INTERRUPTION DUE TO FAULTS
82	19-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	56	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	23:32	20-Jun-2020	03:00	208	0.00029	FORCE MAJEURE DUE TO SABOTAGE
83	19-Jun-2020	PARTS OF SECTOR - 2 ROHINI (PARTLY)	2146	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	02:29	19-Jun-2020	02:45	16	0.00009	INTERRUPTION DUE TO FAULTS
84	20-Jun-2020	PART OF RITHALA S T PLANT ROHINI	2	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	07:58	20-Jun-2020	22:36	878	0.00024	FORCE MAJEURE DUE TO SABOTAGE
85	20-Jun-2020	PART OF AMUSEMENT PARK ROHINI	10	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	10:31	20-Jun-2020	15:27	296	0.00008	PLANNED OUTAGE
86	20-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR HVDS VIJAY VIHAR, A-BLOCK VIJAY VIHAR	3371	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:14	20-Jun-2020	04:45	31	0.00036	INTERRUPTION DUE TO FAULTS
87	20-Jun-2020	PARTS OF LANCER CONVENT SCHOOL SEC-9 RIHINI	1538	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:21	20-Jun-2020	05:00	39	0.00016	INTERRUPTION DUE TO FAULTS
88	20-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR HVDS VIJAY VIHAR, A-BLOCK VIJAY VIHAR	425	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	14:38	20-Jun-2020	15:28	50	0.00013	INTERRUPTION DUE TO FAULTS
89	20-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR HVDS VIJAY VIHAR, A-BLOCK VIJAY VIHAR	37	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	14:38	20-Jun-2020	18:40	242	0.00007	FORCE MAJEURE DUE TO SABOTAGE
90	20-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR HVDS VIJAY VIHAR, A-BLOCK VIJAY VIHAR	425	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	16:55	20-Jun-2020	18:40	105	0.00026	INTERRUPTION DUE TO FAULTS
91	20-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR HVDS VIJAY VIHAR, A-BLOCK VIJAY VIHAR	2031	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	14:39	20-Jun-2020	14:50	11	0.00011	INTERRUPTION DUE TO FAULTS
92	20-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR HVDS VIJAY VIHAR, A-BLOCK VIJAY VIHAR	878	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	14:39	20-Jun-2020	15:00	21	0.00006	INTERRUPTION DUE TO FAULTS
93	20-Jun-2020	PARTS OF SECTOR 24 RITHALA ROHINI	534	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:18	20-Jun-2020	05:10	52	0.00015	INTERRUPTION DUE TO FAULTS
94	20-Jun-2020	PARTS OF SECTOR 24 RITHALA ROHINI	294	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:18	20-Jun-2020	05:45	87	0.00019	INTERRUPTION DUE TO FAULTS
95	20-Jun-2020	PARTS OF B-BLOCK MASJID WALA, E-BLOCK AVANTIKA, M.R HOSPITAL, SEWAGE PUMP AVANTIKA	3166	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:40	20-Jun-2020	06:00	79	0.00331	INTERRUPTION DUE TO FAULTS
96	20-Jun-2020	PARTS OF JAI AMBA TOWER, RG COMPLEX SEC-9, TELEPHONE EXCHANGE, CRESCENT MALL	34	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:42	20-Jun-2020	05:28	46	0.00006	INTERRUPTION DUE TO FAULTS
97	20-Jun-2020	PART OF RITHALA SEWAGE PUMPING STN.	7	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	07:58	20-Jun-2020	09:50	112	0.00006	INTERRUPTION DUE TO FAULTS
98	21-Jun-2020	PARTS OF B-BLOCK AVANTIKA ROHINI	3219	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	05:18	21-Jun-2020	05:50	32	0.00027	INTERRUPTION DUE TO FAULTS
99	22-Jun-2020	PART OF RITHALA S T PLANT ROHINI	2	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	11:16	22-Jun-2020	12:00	44	0.00001	INTERRUPTION DUE TO FAULTS
100	22-Jun-2020	PART OF GOPAL VIHAR ROHINI	10	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	15:45	22-Jun-2020	20:25	280	0.00008	FORCE MAJEURE DUE TO SABOTAGE
101	22-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR HVDS VIJAY VIHAR, A-BLOCK VIJAY VIHAR	452	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	15:45	22-Jun-2020	16:05	20	0.00003	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
102	22-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR HVDS VIJAY VIHAR, A-BLOCK VIJAY VIHAR	878	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	20:14	22-Jun-2020	20:25	11	0.00002	INTERRUPTION DUE TO FAULTS
103	22-Jun-2020	PARTS OF D-BLOCK AVANTIKA, GOPAL VIHAR NO-2,GOPAL VIHAR HVDS VIJAY VIHAR, A-BLOCK VIJAY VIHAR	452	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	20:14	22-Jun-2020	20:25	11	0.00001	INTERRUPTION DUE TO FAULTS
104	22-Jun-2020	PARTS OF B-BLOCK AVANTIKA ROHINI	1932	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:22	22-Jun-2020	05:45	23	0.00013	INTERRUPTION DUE TO FAULTS
105	22-Jun-2020	PARTS OF B-BLOCK AVANTIKA ROHINI	1287	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:22	22-Jun-2020	05:50	28	0.00012	INTERRUPTION DUE TO FAULTS
106	22-Jun-2020	PARTS OF F-17, 18, 19, A-1 & RG COMPLEX OF SECTOR-8	82	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	06:20	22-Jun-2020	06:40	20	0.00003	INTERRUPTION DUE TO FAULTS
107	22-Jun-2020	PARTS OF TEMPO STAND WALA MANGOL PUR KALAN, KHATE WALA, MANGOLPURI POLICE STATION, PATHAR WALA, TALAB WALA	2572	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	10:46	22-Jun-2020	11:05	19	0.00031	INTERRUPTION DUE TO FAULTS
108	22-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	3561	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	16:06	22-Jun-2020	16:20	14	0.00027	INTERRUPTION DUE TO FAULTS
109	23-Jun-2020	PARTS OF RYAN PUBLIC SCHOOL, PKT A-5-SEC-25,	27	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	06:09	23-Jun-2020	07:56	107	0.00006	INTERRUPTION DUE TO FAULTS
110	23-Jun-2020	PARTS OF RYAN PUBLIC SCHOOL, PKT A-5-SEC-25,	1664	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	06:23	23-Jun-2020	07:21	58	0.00016	INTERRUPTION DUE TO FAULTS
111	23-Jun-2020	PARTS OF RYAN PUBLIC SCHOOL, PKT A-5-SEC-25,	582	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	06:23	23-Jun-2020	07:30	67	0.00007	INTERRUPTION DUE TO FAULTS
112	23-Jun-2020	PARTS OF JAI AMBA TOWER, RG COMPLEX SEC-9, TELEPHONE EXCHANGE, CRESCENT MALL	1039	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	08:42	23-Jun-2020	09:15	33	0.00009	INTERRUPTION DUE TO FAULTS
113	23-Jun-2020	PART OF RITHALA SEWAGE PUMPING STN.	10	OTHER OUTAGE	PLANNED OUTAGE	23-Jun-2020	14:39	23-Jun-2020	17:33	174	0.00005	PLANNED OUTAGE
114	24-Jun-2020	PART OF AMUSEMENT PARK ROHINI	11	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	02:43	24-Jun-2020	03:30	46	0.00003	INTERRUPTION DUE TO FAULTS
115	24-Jun-2020	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	98	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	11:53	24-Jun-2020	12:40	47	0.00010	SYSTEM SCHEDULE OUTAGE
116	24-Jun-2020	PARTS OF POKET 7,8 & 9 ROHINI	4688	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	14:41	24-Jun-2020	14:51	9	0.00033	INTERRUPTION DUE TO FAULTS
117	24-Jun-2020	PARTS OF PKT- 26 SEC-24 RITHALA ROHINI	446	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	12:09	24-Jun-2020	14:45	156	0.00017	PLANNED OUTAGE
118	25-Jun-2020	PART OF RITHALA S T PLANT ROHINI	2	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	12:45	25-Jun-2020	13:22	37	0.00001	INTERRUPTION DUE TO FAULTS
119	25-Jun-2020	PARTS OF SECTOR 24 RITHALA ROHINI	538	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	15:11	25-Jun-2020	15:32	21	0.00009	INTERRUPTION DUE TO FAULTS
120	25-Jun-2020	PARTS OF SECTOR 24 RITHALA ROHINI	448	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	15:11	25-Jun-2020	15:52	41	0.00017	INTERRUPTION DUE TO FAULTS
121	26-Jun-2020	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	44	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	12:09	26-Jun-2020	13:30	81	0.00023	INTERRUPTION DUE TO FAULTS
122	26-Jun-2020	PARTS OF DPS, PKT 2 & 24 RITHALA ROHINI	328	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	14:10	26-Jun-2020	14:50	40	0.00028	INTERRUPTION DUE TO FAULTS
123	26-Jun-2020	PART OF TELEPHONE EXCHANGE ROHINI	7	315 kVA	UNPLANNED OUTAGE	26-Jun-2020	14:55	26-Jun-2020	15:32	37	0.00001	SYSTEM SCHEDULE OUTAGE
124	27-Jun-2020	PARTS OF 11 B SECTOR 23 ROHINI, HERITAGE PUBLIC SCHOOL SEC-23, 11B DDA FLAT,SEC-23 FLAT RHN TR NO.2	216	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	22:45	27-Jun-2020	23:40	55	0.00012	INTERRUPTION DUE TO FAULTS
125	8-Jun-2020	PART OF SPD VIJAY VIHAR J-BLK. ROHINI	18	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	13:05	8-Jun-2020	16:45	219	0.00006	FORCE MAJEURE DUE TO SABOTAGE
126	27-Jun-2020	PARTS OF JAI AMBA TOWER, RG COMPLEX SEC-9, TELEPHONE EXCHANGE, CRESCENT MALL	119	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	08:24	27-Jun-2020	11:41	197	0.00011	PLANNED OUTAGE
127	27-Jun-2020	PARTS OF 11 B SECTOR 23 ROHINI, HERITAGE PUBLIC SCHOOL SEC-23, 11B DDA FLAT,SEC-23 FLAT RHN TR NO.2	42	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	10:33	27-Jun-2020	13:15	162	0.00005	PLANNED OUTAGE
128	27-Jun-2020	PARTS OF 11 B SECTOR 23 ROHINI, HERITAGE PUBLIC SCHOOL SEC-23, 11B DDA FLAT,SEC-23 FLAT RHN TR NO.2	119	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	10:30	27-Jun-2020	13:15	165	0.00009	PLANNED OUTAGE
129	28-Jun-2020	PARTS OF TPS & RITHALA KIOSK ROHINI	1395	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	11:34	28-Jun-2020	11:52	18	0.00008	INTERRUPTION DUE TO FAULTS
130	28-Jun-2020	PARTS OF SECTOR - 8 ROHINI (PARTLY)	1557	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	05:51	28-Jun-2020	06:15	23	0.00026	INTERRUPTION DUE TO FAULTS
131	28-Jun-2020	PARTS OF SECTOR - 13 ROHINI (PARTLY), A & B BLOCK	174	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	07:59	28-Jun-2020	08:19	19	0.00002	INTERRUPTION DUE TO FAULTS
132	28-Jun-2020	PARTS OF SECTOR - 13 ROHINI (PARTLY), A & B BLOCK	290	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	07:59	28-Jun-2020	08:50	50	0.00006	INTERRUPTION DUE TO FAULTS
133	28-Jun-2020	PARTS OF SECTOR - 13 ROHINI (PARTLY), A & B BLOCK	486	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	07:59	28-Jun-2020	08:55	55	0.00015	INTERRUPTION DUE TO FAULTS
134	29-Jun-20	PARTS OF SECTOR - 13 ROHINI (PARTLY)	1227	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:34	29-Jun-20	17:50	16	0.00022	INTERRUPTION DUE TO FAULTS
135	29-Jun-20	PARTS OF BEGAMPURA-4, PKT-9 SEC-25 RITHALA ROHINI	771	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:01	29-Jun-20	19:50	108	0.00033	INTERRUPTION DUE TO FAULTS
136	29-Jun-20	PARTS OF TPS & RITHALA KIOSK ROHINI	1395	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:34	29-Jun-20	19:00	26	0.00017	INTERRUPTION DUE TO FAULTS
137	29-Jun-20	PARTS OF PITAM PURA- 3 DTC DEPOT ROHINI, PETROL PUMP, DDA OFFICE ROHINI	4792	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	14:50	29-Jun-20	15:10	20	0.00128	INTERRUPTION DUE TO FAULTS
138	29-Jun-20	PARTS OF PITAM PURA- 3 DTC DEPOT ROHINI, PETROL PUMP, DDA OFFICE ROHINI	1519	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	15:21	29-Jun-20	15:25	4	0.00011	INTERRUPTION DUE TO FAULTS
139	29-Jun-20	PARTS OF PITAM PURA- 3 DTC DEPOT ROHINI, PETROL PUMP, DDA OFFICE ROHINI	3273	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	15:21	29-Jun-20	15:30	9	0.00045	INTERRUPTION DUE TO FAULTS
140	29-Jun-20	PARTS OF POKET 7,8 & 9 AVANTIKA ROHINI	2374	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	06:33	29-Jun-20	06:45	12	0.00008	INTERRUPTION DUE TO FAULTS
141	30-Jun-20	PARTS OF SPD VIJAY VIHAR PH-2, K-218,VIJAY VIHAR PH-2, J-BLK. VIJAY VIHAR,SPD VIJAY VIHAR J-BLK.	1290	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	17:46	30-Jun-20	18:25	39	0.00011	INTERRUPTION DUE TO FAULTS
					SHAKTI NAGAR							
1	3-Jun-2020	PARTS OF A BLOCK GULABI BAGH AND PETROL PUMP	704	1000 kVA	PLANNED OUTAGE	3-Jun-2020	11:16	3-Jun-2020	13:15	119	0.0002	PLANNED OUTAGE
2	10-Jun-2020	PARTS OF SHASTRI NAGAR, SHIV VATIKA, B-BLK,CHAR MINAR	627	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	11:44	10-Jun-2020	12:22	38	0.00005	SYSTEM SCHEDULE OUTAGE
3	10-Jun-2020	PARTS OF SHASTRI NAGAR, SHIV VATIKA, B-BLK,CHAR MINAR	819	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	06:22	10-Jun-2020	06:50	29	0.00007	INTERRUPTION DUE TO FAULTS
4	12-Jun-2020	PARTS OF SWISS APARTMENT & BARA HINDU RAO HOSPITAL AND MKT.	277	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	00:12	12-Jun-2020	00:30	18	0.00005	INTERRUPTION DUE TO FAULTS
5	12-Jun-2020	PARTS OF SWISS APARTMENT & BARA HINDU RAO HOSPITAL AND MKT.	941	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	00:12	12-Jun-2020	01:02	50	0.00035	INTERRUPTION DUE TO FAULTS
6	12-Jun-2020	PARTS OF SWISS APARTMENT & BARA HINDU RAO HOSPITAL AND MKT.	1377	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	00:12	12-Jun-2020	01:10	58	0.00048	INTERRUPTION DUE TO FAULTS
7	12-Jun-2020	PARTS OF SWISS APARTMENT & BARA HINDU RAO HOSPITAL AND MKT.	277	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	01:00	12-Jun-2020	01:10	10	0.00003	INTERRUPTION DUE TO FAULTS
8	13-Jun-2020	PARTS OF V. N.PURI, M. C. D. FLAT PADAM NAGAR, D. N. COLONY. EAST MOTI BAGH, PADAM NAGAR.	842	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:49	13-Jun-2020	15:15	26	0.00011	SYSTEM SCHEDULE OUTAGE
9	14-Jun-2020	PARTS OF SADAR, BHAGAT SINGH NAGAR, PUNJABI BASTI	1301	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	04:05	14-Jun-2020	04:55	50	0.00017	INTERRUPTION DUE TO FAULTS
10	14-Jun-2020	PARTS OF SADAR, BHAGAT SINGH NAGAR, PUNJABI BASTI	788	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	04:05	14-Jun-2020	05:10	65	0.00014	INTERRUPTION DUE TO FAULTS
11	16-Jun-2020	PART OF SHAHZADA BAGH INDUSTRIAL AREA SHAKTI NAGAR	16	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	18:36	16-Jun-2020	18:53	17	0.00002	INTERRUPTION DUE TO FAULTS
12	16-Jun-2020	PARTS OF ROHTAK ROAD ,PART OF 65, 66 & 67 BLOCKS MOTI NAGAR, RATTAN NAGAR, KATRA GANGA BISHAN, BAGH RAO JI DHOBHI WALI GALI, GAU SALA ROAD	338	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	11:47	16-Jun-2020	11:58	11	0.00005	INTERRUPTION DUE TO FAULTS
13	17-Jun-2020	PARTS OF SHASTRI NAGAR, SHIV VATIKA, B-BLK,CHAR MINAR	819	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	15:45	17-Jun-2020	16:00	15	0.00004	SYSTEM SCHEDULE OUTAGE
14	17-Jun-2020	PARTS OF SHASTRI NAGAR M - BLOCK OLD (GOL CHAKKAR), SHASTRI NGR. M - BLOCK NEW COMMUNITY CENTRE, PSS NEW SAI MANDIR SHASTRI NAGAR, NAAG MANDIR	592	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	07:49	17-Jun-2020	08:47	58	0.00010	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
15	19-Jun-2020	PARTS OF SADAR, BHAGAT SINGH NAGAR, PUNJABI BASTI	787	630 kVA	PLANNED OUTAGE	19-Jun-2020	11:02	19-Jun-2020	13:25	143	0.00032	PLANNED OUTAGE
16	19-Jun-2020	PARTS OF SHASTRI NAGAR M - BLOCK OLD (GOL CHAKKAR), SHASTRI NGR. M - BLOCK NEW COMMUNITY CENTRE, PSS NEW SAI MANDIR SHASTRI NAGAR, NAAG MANDIR	476	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	12:59	19-Jun-2020	13:32	34	0.00005	INTERRUPTION DUE TO FAULTS
17	19-Jun-2020	PARTS OF SHASTRI NAGAR M - BLOCK OLD (GOL CHAKKAR), SHASTRI NGR. M - BLOCK NEW COMMUNITY CENTRE, PSS NEW SAI MANDIR SHASTRI NAGAR, NAAG MANDIR	1038	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	16:49	19-Jun-2020	17:06	17	0.00003	SYSTEM SCHEDULE OUTAGE
18	19-Jun-2020	PARTS OF ANAND NAGAR NEW, ANAND NAGAR OLD NALA, TULSI NAGAR GANDA NALA, TIKONA PARK ,B-38 (INDERLOK)	573	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	22:10	19-Jun-2020	22:22	12	0.00003	SYSTEM SCHEDULE OUTAGE
19	20-Jun-2020	PART OF SHAHZADA BAGH INDUSTRIAL AREA SHAKTI NAGAR	10	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	20:10	20-Jun-2020	20:29	19	0.00001	SYSTEM SCHEDULE OUTAGE
20	20-Jun-2020	PART OF SHAHZADA BAGH INDUSTRIAL AREA SHAKTI NAGAR	20	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	13:19	20-Jun-2020	14:38	78	0.00004	INTERRUPTION DUE TO FAULTS
21	20-Jun-2020	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA	43	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	14:16	20-Jun-2020	14:38	22	0.00003	INTERRUPTION DUE TO FAULTS
22	20-Jun-2020	PARTS OF MANAK PURA AND TIBYA COLLEGE	891	990 kVA	PLANNED OUTAGE	20-Jun-2020	10:58	20-Jun-2020	13:05	127	0.00032	PLANNED OUTAGE
23	21-Jun-2020	PARTS OF B - BLOCK (OUTER), GANDA NALA SHASTRI NAGAR NO-1, STATUE PARK	700	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	00:46	21-Jun-2020	01:10	24	0.00010	SYSTEM SCHEDULE OUTAGE
24	22-Jun-2020	PARTS OF SARAI ROHILLA , AHATA THAKUR DASS, 1C, 2C, 3C, 4C BLOCKS SARAI ROHILLA RAILWAY STATION	246	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:46	22-Jun-2020	06:07	21	0.00009	INTERRUPTION DUE TO FAULTS
25	23-Jun-2020	PARTS OF B - BLOCK (OUTER), GANDA NALA SHASTRI NAGAR NO-1, STATUE PARK	964	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	11:13	23-Jun-2020	11:57	44	0.00012	SYSTEM SCHEDULE OUTAGE
26	25-Jun-2020	PARTS OF ROHTAK ROAD ,PART OF 65, 66, 5C BLOCKS MOTI NAGAR, JEEWAN MALA HOSPITAL	1365	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	12:57	25-Jun-2020	13:15	18	0.00008	INTERRUPTION DUE TO FAULTS
27	25-Jun-2020	PARTS OF ROHTAK ROAD ,PART OF 65, 66, 5C BLOCKS MOTI NAGAR, JEEWAN MALA HOSPITAL	64	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	12:57	25-Jun-2020	13:20	23	0.00001	INTERRUPTION DUE TO FAULTS
28	25-Jun-2020	PARTS OF G. B. ADMINISTRATION FLATS, G. B. GARRIAGE AND ANDHA MUGHAL AREA	347	630 kVA	PLANNED OUTAGE	25-Jun-2020	11:03	25-Jun-2020	13:00	117	0.0001	PLANNED OUTAGE
29	25-Jun-2020	PARTS OF PETROL PUMP AND SINDHORA KALAN SHASTRI NAGAR	437	630 kVA	PLANNED OUTAGE	25-Jun-2020	11:12	25-Jun-2020	13:20	128	0.00018	PLANNED OUTAGE
30	25-Jun-2020	PARTS OF PETROL PUMP AND SINDHORA KALAN SHASTRI NAGAR	570	630 kVA	PLANNED OUTAGE	25-Jun-2020	13:37	25-Jun-2020	14:20	43	0.00007	PLANNED OUTAGE
31	27-Jun-2020	PARTS OF DDA , LIG , MIG FLATS, SARAI ROHILA POLICE STATION, PART OF EAST MOTI BAGH, PART OF ADMINISTRATION FLATS GULABI BAGH, PART OF V N PURI	296	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	22:30	27-Jun-2020	22:50	21	0.00005	INTERRUPTION DUE TO FAULTS
32	27-Jun-2020	PARTS OF DDA , LIG , MIG FLATS, SARAI ROHILA POLICE STATION, PART OF EAST MOTI BAGH, PART OF ADMINISTRATION FLATS GULABI BAGH, PART OF V N PURI	296	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	23:01	28-Jun-2020	00:00	59	0.00013	INTERRUPTION DUE TO FAULTS
33	28-Jun-2020	PARTS OF DDA , LIG , MIG FLATS, SARAI ROHILA POLICE STATION, PART OF EAST MOTI BAGH, PART OF ADMINISTRATION FLATS GULABI BAGH, PART OF V N PURI	296	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	10:43	28-Jun-2020	11:04	21	0.00006	INTERRUPTION DUE TO FAULTS
34	28-Jun-2020	PARTS OF DDA , LIG , MIG FLATS, SARAI ROHILA POLICE STATION, PART OF EAST MOTI BAGH, PART OF ADMINISTRATION FLATS GULABI BAGH, PART OF V N PURI	296	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	21:07	28-Jun-2020	21:20	13	0.00002	INTERRUPTION DUE TO FAULTS
35	28-Jun-2020	PARTS OF DDA , LIG , MIG FLATS, SARAI ROHILA POLICE STATION, PART OF EAST MOTI BAGH, PART OF ADMINISTRATION FLATS GULABI BAGH, PART OF V N PURI	296	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	21:45	28-Jun-2020	21:50	5	0.00001	INTERRUPTION DUE TO FAULTS
36	28-Jun-2020	PARTS OF CHUNA BHATTI, HARIJAN BASTI, TIKONA PARK KALAPAHAR, KALAPAHAR PETROL PUMP	1024	OTHER OUTAGE	PLANNED OUTAGE	28-Jun-2020	06:58	28-Jun-2020	07:57	59	0.0002	PLANNED OUTAGE
37	29-Jun-20	PARTS OF M.C.D. FLATS & A - BLOCK SHASTRI NAGAR, PETROL PUMP SHASTRI NAGAR, HEALTH CENTER	2064	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	19:37	29-Jun-20	20:30	53	0.00029	INTERRUPTION DUE TO FAULTS
38	29-Jun-20	PARTS OF ROHTAK ROAD ,PART OF 65, 66, 5C BLOCKS MOTI NAGAR, JEEWAN MALA HOSPITAL	1369	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	11:35	29-Jun-20	12:10	35	0.00010	INTERRUPTION DUE TO FAULTS
39	29-Jun-20	PARTS OF ROHTAK ROAD ,PART OF 65, 66, 5C BLOCKS MOTI NAGAR, JEEWAN MALA HOSPITAL	64	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	11:35	29-Jun-20	12:32	56	0.00005	INTERRUPTION DUE TO FAULTS
40	29-Jun-20	PARTS OF SHAHZADA BAGH INDUSTRIAL AREA	364	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:00	29-Jun-20	18:49	49	0.00006	INTERRUPTION DUE TO FAULTS
41	29-Jun-20	PART OF A-BLOCK SHASTRI NAGAR SHAKTI NAGAR	2	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	19:37	29-Jun-20	20:45	68	0.00002	INTERRUPTION DUE TO FAULTS
SHALIMAR BAGH												
1	6-Jun-2020	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP	21	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	01:09	6-Jun-2020	01:23	14	0.00001	SYSTEM SCHEDULE OUTAGE
2	1-Jun-2020	PARTS OF PWD STREET LIGHT NO.-2 SANT NAGAR SHALIMAR BAGH	2932	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	18:26	1-Jun-2020	19:35	69	0.00071	INTERRUPTION DUE TO FAULTS
3	1-Jun-2020	PARTS OF SANT NAGER PARTLY (B-BLOCK) BABA COLONY, JOGI MOHALLA, ARORA FARM, MILAN VIHAR, PRADHAN ENCLAVE, PARVATIA ANCHAL, TEACHER COLONY & VASISTH ENCLAVE, BURARI	1205	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	23:39	2-Jun-2020	00:03	24	0.00003	INTERRUPTION DUE TO FAULTS
4	1-Jun-2020	PARTS OF JAHANGIRABAD, RADHA VIHAR, C&D BLOCK MUKUNDPUR, SAMTA VIHAR, ISHU VIHAR	1135	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	12:46	1-Jun-2020	13:12	26	0.00012	INTERRUPTION DUE TO FAULTS
5	1-Jun-2020	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL,PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B C,D E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE	291	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	17:16	1-Jun-2020	18:00	43	0.00007	INTERRUPTION DUE TO FAULTS
6	1-Jun-2020	PART OF BURARI VILLAGE SHALIMAR BAGH	7	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	19:33	2-Jun-2020	18:18	1364	0.00038	FORCE MAJEURE DUE TO SABOTAGE
7	1-Jun-2020	PARTS OF BHALSWA DAIRY, JJ CLUSTER AND KALANDER COLONY	701	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	05:20	1-Jun-2020	05:50	30	0.00007	INTERRUPTION DUE TO FAULTS
8	1-Jun-2020	PARTS OF BURARI PRADHAN ENCLAVE BURARI SHALIMAR BAGH	1149	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	08:19	1-Jun-2020	08:55	36	0.00015	INTERRUPTION DUE TO FAULTS
9	1-Jun-2020	PARTS OF BURARI PRADHAN ENCLAVE BURARI SHALIMAR BAGH	283	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	08:19	1-Jun-2020	09:25	66	0.00007	INTERRUPTION DUE TO FAULTS
10	1-Jun-2020	PARTS OF AB, AC, AD, AE BLOCK, BK BLOCK SHALIMAR BAGH, AA	1161	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	10:42	1-Jun-2020	11:25	43	0.00028	INTERRUPTION DUE TO FAULTS
11	1-Jun-2020	PARTS OF SSI INDUSTRIAL AREA BHALSWA	54	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	14:58	1-Jun-2020	16:15	76	0.00066	INTERRUPTION DUE TO FAULTS
12	1-Jun-2020	PARTS OF SSI INDUSTRIAL AREA BHALSWA	69	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	14:58	1-Jun-2020	17:10	131	0.00095	FORCE MAJEURE DUE TO SABOTAGE
13	1-Jun-2020	PART OF BURARI VILLAGE SHALIMAR BAGH	8	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	19:55	1-Jun-2020	20:05	10	0.00001	INTERRUPTION DUE TO FAULTS
14	1-Jun-2020	PARTS OF HINDUSTAN PETROLEUM SANT NAGAR SHALIMAR BAGH	1068	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	10:40	1-Jun-2020	11:07	27	0.00012	SYSTEM SCHEDULE OUTAGE
15	2-Jun-2020	PARTS OF DA BLOCK, VILLAGE SHALAMAR, HAIDERPUR DISPENSARY	1087	990 kVA	PLANNED OUTAGE	2-Jun-2020	08:12	2-Jun-2020	11:10	178	0.00049	PLANNED OUTAGE
16	2-Jun-2020	PARTS OF SSI INDUSTRIAL AREA BHALSWA	32	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	13:01	2-Jun-2020	13:12	11	0.00002	INTERRUPTION DUE TO FAULTS
17	2-Jun-2020	PARTS OF WAZIRABAD FLYOVER, PRATIBHA INDUSTRY SANT NAGAR SHALIMAR BAGH	587	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	15:33	2-Jun-2020	16:08	34	0.00010	INTERRUPTION DUE TO FAULTS
18	2-Jun-2020	PARTS OF HARDEV NAGAR, SURENDER COLONY PART 3, PART OF SANAGAM VIHAR, SURRENDER COLONY PART2, SHIV KUNJ, DEEPANSHU COLONY,	511	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	16:32	2-Jun-2020	17:30	58	0.00016	SYSTEM SCHEDULE OUTAGE
19	2-Jun-2020	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL,PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B C,D E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE	40	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	19:23	2-Jun-2020	20:00	37	0.00005	INTERRUPTION DUE TO FAULTS
20	2-Jun-2020	PARTS OF SSI INDUSTRIAL AREA BHALSWA	72	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	11:11	2-Jun-2020	16:23	312	0.00087	FORCE MAJEURE DUE TO SABOTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
21	2-Jun-2020	PARTS OF JAHANGIRABAD, RADHA VIHAR, C&D BLOCK MUKUNDPUR, SAMTA VIHAR, ISHU VIHAR	3893	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	08:40	2-Jun-2020	09:07	27	0.00019	INTERRUPTION DUE TO FAULTS
22	2-Jun-2020	PARTS OF BHALSWA SMA INDUSTRIAL AREA	26	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	10:22	2-Jun-2020	10:50	28	0.00004	INTERRUPTION DUE TO FAULTS
23	2-Jun-2020	PARTS OF NEAR B-3 MARKET, A-BIK JINDAL WALA	22	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	12:22	2-Jun-2020	12:34	12	0.00002	INTERRUPTION DUE TO FAULTS
24	2-Jun-2020	PART OF K BLOCK JAHANGIR PURI	12	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	11:34	2-Jun-2020	13:16	102	0.00006	INTERRUPTION DUE TO FAULTS
25	2-Jun-2020	PARTS OF INDIAN OIL NO-1 SHALIMAR BAGH	2427	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	14:09	2-Jun-2020	14:38	29	0.00032	INTERRUPTION DUE TO FAULTS
26	2-Jun-2020	PART OF BURARI VILLAGE SHALIMAR BAGH	8	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	14:43	2-Jun-2020	18:18	215	0.00012	FORCE MAJEURE DUE TO SABOTAGE
27	2-Jun-2020	PARTS OF HINDUSTAN PETROLEUM SANT NAGAR SHALIMAR BAGH	1850	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	16:35	2-Jun-2020	17:15	40	0.00028	INTERRUPTION DUE TO FAULTS
28	2-Jun-2020	PARTS OF HINDUSTAN PETROLEUM SANT NAGAR SHALIMAR BAGH	3003	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	16:35	2-Jun-2020	17:52	77	0.00075	INTERRUPTION DUE TO FAULTS
29	3-Jun-2020	PARTS OF BL BLOCK SCHOOL, AD MARKET SHALIMAR BAGH	332	990 kVA	PLANNED OUTAGE	3-Jun-2020	09:42	3-Jun-2020	10:12	30	0.00003	PLANNED OUTAGE
30	3-Jun-2020	PARTS OF PRAGYA MALL NEAR SHALIMAR BAGH CLUB	931	630 kVA	PLANNED OUTAGE	3-Jun-2020	08:46	3-Jun-2020	13:55	309	0.00086	PLANNED OUTAGE
31	3-Jun-2020	PARTS OF IP COLONY A,B & C BLK, DAYANAND ENCLAVE, PART OF KAUSHIK ENCLAVE A & B BLK, AMRIT VIHAR A,B, C & A1 BLK & SWAROOP NAGAR ROAD	640	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	12:23	3-Jun-2020	13:08	45	0.00016	INTERRUPTION DUE TO FAULTS
32	3-Jun-2020	PARTS OF IP COLONY A,B & C BLK, DAYANAND ENCLAVE, PART OF KAUSHIK ENCLAVE A & B BLK, AMRIT VIHAR A,B, C & A1 BLK & SWAROOP NAGAR ROAD	575	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	12:23	3-Jun-2020	18:00	337	0.00094	FORCE MAJEURE DUE TO SABOTAGE
33	3-Jun-2020	PARTS OF IP COLONY A,B & C BLK, DAYANAND ENCLAVE, PART OF KAUSHIK ENCLAVE A & B BLK, AMRIT VIHAR A,B, C & A1 BLK & SWAROOP NAGAR ROAD	640	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	17:21	3-Jun-2020	18:00	39	0.00014	INTERRUPTION DUE TO FAULTS
34	3-Jun-2020	PARTS OF BL BLOCK SCHOOL, AD MARKET SHALIMAR BAGH	332	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	12:31	3-Jun-2020	13:37	66	0.00022	INTERRUPTION DUE TO FAULTS
35	3-Jun-2020	PARTS OF BL BLOCK SCHOOL, AD MARKET SHALIMAR BAGH	50	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	13:00	3-Jun-2020	13:37	37	0.00002	INTERRUPTION DUE TO FAULTS
36	3-Jun-2020	PARTS OF INDIAN OIL NO-1 SHALIMAR BAGH	2532	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	18:22	3-Jun-2020	18:50	28	0.00032	INTERRUPTION DUE TO FAULTS
37	3-Jun-2020	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI	1958	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	06:47	3-Jun-2020	07:20	33	0.00009	INTERRUPTION DUE TO FAULTS
38	3-Jun-2020	PARTS OF INDIAN OIL NO-1 SHALIMAR BAGH	1248	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	08:41	3-Jun-2020	10:05	84	0.00044	INTERRUPTION DUE TO FAULTS
39	3-Jun-2020	PARTS OF INDIAN OIL NO-1 SHALIMAR BAGH	1284	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	08:41	3-Jun-2020	11:45	184	0.00107	FORCE MAJEURE DUE TO SABOTAGE
40	3-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	4324	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	09:28	3-Jun-2020	10:35	67	0.00164	INTERRUPTION DUE TO FAULTS
41	3-Jun-2020	PARTS OF DJB,PART OF HIMGIRI ENCLAVE, A,B & A2 BLK, PART OF CHANDAN VIHAR & A2 BLK SANT NAGAR, HARIT VIHAR A B C & D BLK	1960	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	14:01	3-Jun-2020	14:40	38	0.00033	INTERRUPTION DUE TO FAULTS
42	3-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	6110	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	15:44	3-Jun-2020	16:29	45	0.00127	INTERRUPTION DUE TO FAULTS
43	3-Jun-2020	PART OF SANJAY NAGAR SHALIMAR BAGH	13	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	08:08	3-Jun-2020	09:00	51	0.00003	INTERRUPTION DUE TO FAULTS
44	3-Jun-2020	PART OF SANJAY NAGAR SHALIMAR BAGH	4	OTHER OUTAGE	UNPLANNED OUTAGE	3-Jun-2020	08:41	3-Jun-2020	09:00	19	0.00001	INTERRUPTION DUE TO FAULTS
45	9-Jun-2020	PART OF BANGALI COLONY FDR NO-2 SHALIMAR BAGH	7	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	19:17	9-Jun-2020	22:00	163	0.00014	FORCE MAJEURE DUE TO SABOTAGE
46	4-Jun-2020	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR	749	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	11:13	4-Jun-2020	14:20	187	0.00036	PLANNED OUTAGE
47	4-Jun-2020	PARTS OF AK BLOCK, AO BLOCK JJ CLUSTER NO-2	272	OTHER OUTAGE	PLANNED OUTAGE	4-Jun-2020	09:53	4-Jun-2020	13:49	236	0.00098	PLANNED OUTAGE
48	4-Jun-2020	PARTS OF C BLK , CD PARK JJ CLUSTER , CD PARK JAL BOARD & C BLK DSIDC	219	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	14:38	4-Jun-2020	16:20	102	0.00014	INTERRUPTION DUE TO FAULTS
49	4-Jun-2020	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI)	1900	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	19:16	4-Jun-2020	19:32	16	0.00007	INTERRUPTION DUE TO FAULTS
50	4-Jun-2020	PARTS OF BHAGAT COLONY SHALIMAR BAGH	60	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	21:57	4-Jun-2020	22:01	4	0.00001	INTERRUPTION DUE TO FAULTS
51	4-Jun-2020	PARTS OF DJB,PART OF HIMGIRI ENCLAVE, A,B & A2 BLK, PART OF CHANDAN VIHAR & A2 BLK SANT NAGAR, HARIT VIHAR A B C & D BLK	1984	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	07:51	4-Jun-2020	08:28	37	0.00123	INTERRUPTION DUE TO FAULTS
52	4-Jun-2020	PARTS OF DJB,PART OF HIMGIRI ENCLAVE, A,B & A2 BLK, PART OF CHANDAN VIHAR & A2 BLK SANT NAGAR, HARIT VIHAR A B C & D BLK	1328	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	07:51	4-Jun-2020	08:43	52	0.00072	INTERRUPTION DUE TO FAULTS
53	4-Jun-2020	PARTS OF D BLOCK GALI NO 3 AND 4, GALI NO 5 - 11, SWAROOP NAGAR EXTENSION, SWAROOP NAGAR SINDHI COLONY, BHATTA ROAD	3889	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	14:59	4-Jun-2020	15:35	35	0.00035	INTERRUPTION DUE TO FAULTS
54	4-Jun-2020	PARTS OF SSI INDUSTRIAL AREA BHALSWA	126	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	22:26	4-Jun-2020	23:02	36	0.00025	INTERRUPTION DUE TO FAULTS
55	4-Jun-2020	PARTS OF HINDUSTAN PETROLEUM SANT NAGAR SHALIMAR BAGH	695	OTHER OUTAGE	UNPLANNED OUTAGE	4-Jun-2020	08:53	4-Jun-2020	09:50	57	0.00008	INTERRUPTION DUE TO FAULTS
56	5-Jun-2020	PARTS OF BHALASWA AND PEPSI GODOWN	1533	OTHER OUTAGE	PLANNED OUTAGE	5-Jun-2020	12:14	5-Jun-2020	13:33	79	0.00022	PLANNED OUTAGE
57	5-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	846	OTHER OUTAGE	PLANNED OUTAGE	5-Jun-2020	11:15	5-Jun-2020	16:51	336	0.00047	PLANNED OUTAGE
58	5-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	74	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	12:57	5-Jun-2020	13:47	50	0.00014	SYSTEM SCHEDULE OUTAGE
59	5-Jun-2020	PART OF INTERCONNECTOR 1 JAHANGIRPURI	17	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	23:45	6-Jun-2020	00:50	64	0.00005	SYSTEM SCHEDULE OUTAGE
60	5-Jun-2020	PARTS OF HARDEV NAGAR, SURENDER COLONY PART 3, PART OF SANAGAM VIHAR, SURRENDER COLONY PART2, SHIV KUNJ, DEEPANSHU COLONY,	3167	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	06:18	5-Jun-2020	07:08	50	0.00072	INTERRUPTION DUE TO FAULTS
61	23-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, JJ CLUSTER EE BLOCK JAHANGIR PURI	22	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	00:07	23-Jun-2020	00:22	14	0.000004	INTERRUPTION DUE TO FAULTS
62	5-Jun-2020	PARTS OF INDIAN OIL NO-1 SHALIMAR BAGH	1284	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	15:43	5-Jun-2020	16:44	61	0.00017	INTERRUPTION DUE TO FAULTS
63	5-Jun-2020	PARTS OF BHAGAT COLONY SHALIMAR BAGH	1007	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	08:39	5-Jun-2020	09:35	56	0.00012	INTERRUPTION DUE TO FAULTS
64	5-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	312	OTHER OUTAGE	UNPLANNED OUTAGE	5-Jun-2020	13:47	5-Jun-2020	16:33	166	0.00014	FORCE MAJEURE DUE TO SABOTAGE
65	6-Jun-2020	PARTS OF JAHANGIRABAD, RADHA VIHAR, C&D BLOCK MUKUNDPUR, SAMTA VIHAR, ISHU VIHAR	143	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	10:54	6-Jun-2020	13:15	141	0.00008	PLANNED OUTAGE
66	6-Jun-2020	PARTS OF MAHINDRA PARK & SANJAY NAGAR	108	OTHER OUTAGE	PLANNED OUTAGE	6-Jun-2020	11:00	6-Jun-2020	13:16	136	0.00008	PLANNED OUTAGE
67	30-Jun-20	PARTS OF D BLOCK, E BLOCK, EE BLOCK, JJ CLUSTER EE BLOCK JAHANGIR PURI	26	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	19:07	30-Jun-20	19:30	23	0.00001	INTERRUPTION DUE TO FAULTS
68	6-Jun-2020	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS)	56	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	23:29	7-Jun-2020	00:37	68	0.00009	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
69	6-Jun-2020	PARTS OF JJ CLUSTER HAIDER PUR , HAIDERPUR DISPENSARY, BB EAST, LEPROSY COLONY JJ CLUSTER, SAHIPUR VILLAGE	520	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	09:58	6-Jun-2020	10:27	29	0.00016	INTERRUPTION DUE TO FAULTS
70	6-Jun-2020	PARTS OF JJ CLUSTER HAIDER PUR , HAIDERPUR DISPENSARY, BB EAST, LEPROSY COLONY JJ CLUSTER, SAHIPUR VILLAGE	1066	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	09:58	6-Jun-2020	11:32	94	0.00105	INTERRUPTION DUE TO FAULTS
71	6-Jun-2020	PARTS OF JJ CLUSTER HAIDER PUR , HAIDERPUR DISPENSARY, BB EAST, LEPROSY COLONY JJ CLUSTER, SAHIPUR VILLAGE	616	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	09:58	6-Jun-2020	11:32	94	0.00052	INTERRUPTION DUE TO FAULTS
72	6-Jun-2020	PARTS OF JJ CLUSTER HAIDER PUR , HAIDERPUR DISPENSARY, BB EAST, LEPROSY COLONY JJ CLUSTER, SAHIPUR VILLAGE	328	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	09:58	6-Jun-2020	11:32	94	0.00026	INTERRUPTION DUE TO FAULTS
73	6-Jun-2020	PARTS OF GURUNANAK DEV COLONY BHALSWA SHALIMAR BAGH	1250	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	10:59	6-Jun-2020	12:10	71	0.00138	INTERRUPTION DUE TO FAULTS
74	6-Jun-2020	PARTS OF GURUNANAK DEV COLONY BHALSWA SHALIMAR BAGH	3751	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	11:55	6-Jun-2020	12:10	15	0.00029	INTERRUPTION DUE TO FAULTS
75	6-Jun-2020	PARTS OF IP COLONY A,B & C BLK, DAYANAND ENCLAVE, PART OF KAUSHIK ENCLAVE A & B BLK, AMRIT VIHAR A,B, C & A1 BLK & SWAROOP NAGAR ROAD	1291	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	14:40	6-Jun-2020	15:45	65	0.00054	INTERRUPTION DUE TO FAULTS
76	6-Jun-2020	PARTS OF BADLI AND LABOUR CHOWK AREA	2398	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	15:56	6-Jun-2020	16:35	38	0.00064	INTERRUPTION DUE TO FAULTS
77	6-Jun-2020	PARTS OF INDIAN OIL NO-1 SHALIMAR BAGH	2532	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	19:10	6-Jun-2020	19:35	24	0.00037	INTERRUPTION DUE TO FAULTS
78	6-Jun-2020	PARTS OF SANT NAGER PARTLY (B-BLOCK) BABA COLONY, JOGI MOHALLA, ARORA FARM, MILAN VIHAR, PRADHAN ENCLAVE, PARVATIA ANCHAL, TEACHER COLONY & VASISTH ENCLAVE, BURARI	7478	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	10:18	6-Jun-2020	11:02	43	0.00168	INTERRUPTION DUE TO FAULTS
79	6-Jun-2020	PARTS OF SANT NAGER PARTLY (B-BLOCK) BABA COLONY, JOGI MOHALLA, ARORA FARM, MILAN VIHAR, PRADHAN ENCLAVE, PARVATIA ANCHAL, TEACHER COLONY & VASISTH ENCLAVE, BURARI	215	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	10:18	6-Jun-2020	11:28	69	0.00019	INTERRUPTION DUE TO FAULTS
80	6-Jun-2020	PART OF BURARI VILLAGE SHALIMAR BAGH	9	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	12:54	6-Jun-2020	13:30	36	0.00002	INTERRUPTION DUE TO FAULTS
81	7-Jun-2020	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK	1973	OTHER OUTAGE	PLANNED OUTAGE	7-Jun-2020	11:58	7-Jun-2020	13:45	107	0.00059	PLANNED OUTAGE
82	7-Jun-2020	PART OF A BLOCK DDA SLUM FLATS	12	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	17:50	7-Jun-2020	19:30	99	0.00003	INTERRUPTION DUE TO FAULTS
83	7-Jun-2020	PARTS OF GALI NO-12 SWAROOP NAGAR SHALIMAR BAGH	1843	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:54	7-Jun-2020	10:27	33	0.00028	INTERRUPTION DUE TO FAULTS
84	7-Jun-2020	PARTS OF FORTIS AND SHALIMAR BAGH MARKET	37	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	07:42	7-Jun-2020	09:49	127	0.00018	FORCE MAJEURE DUE TO RAIN/STORM
85	7-Jun-2020	PARTS OF BANGALI COLONY SANT NAGAR SHALIMAR BAGH	952	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:13	7-Jun-2020	10:45	93	0.00016	INTERRUPTION DUE TO FAULTS
86	7-Jun-2020	PARTS OF BANGALI COLONY SANT NAGAR SHALIMAR BAGH	1631	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:13	7-Jun-2020	11:44	151	0.00042	FORCE MAJEURE DUE TO SABOTAGE
87	7-Jun-2020	PARTS OF D BLOCK GALI NO 3 AND 4, GALI NO 5 - 11, SWAROOP NAGAR EXTENSION, SWAROOP NAGAR SINDHI COLONY, BHATTA ROAD	3889	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	09:59	7-Jun-2020	10:40	41	0.00040	INTERRUPTION DUE TO FAULTS
88	7-Jun-2020	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI	1770	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	10:14	7-Jun-2020	10:57	44	0.00021	INTERRUPTION DUE TO FAULTS
89	7-Jun-2020	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI	188	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	10:14	7-Jun-2020	10:57	44	0.00002	INTERRUPTION DUE TO FAULTS
90	7-Jun-2020	PARTS OF ARORA FARAM SNAT NAGAR SHALIMAR BAGH	2178	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	12:19	7-Jun-2020	13:04	45	0.00019	INTERRUPTION DUE TO FAULTS
91	7-Jun-2020	PARTS OF ARORA FARAM SNAT NAGAR SHALIMAR BAGH	535	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	12:19	7-Jun-2020	13:15	56	0.00008	INTERRUPTION DUE TO FAULTS
92	7-Jun-2020	PARTS OF BADLI AND LABOUR CHOWK AREA	2398	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	12:41	7-Jun-2020	13:44	63	0.00100	INTERRUPTION DUE TO FAULTS
93	7-Jun-2020	PARTS OF BANGALI COLONY SHALIMAR BAGH	2467	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	12:41	7-Jun-2020	13:37	56	0.00101	INTERRUPTION DUE TO FAULTS
94	7-Jun-2020	PARTS OF BHALSWA SMA INDUSTRIAL AREA	75	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	19:06	7-Jun-2020	19:30	24	0.00010	INTERRUPTION DUE TO FAULTS
95	7-Jun-2020	PARTS OF BHALSWA SMA INDUSTRIAL AREA	27	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	19:06	7-Jun-2020	19:38	32	0.00006	INTERRUPTION DUE TO FAULTS
96	7-Jun-2020	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI	188	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	23:07	7-Jun-2020	23:45	39	0.00001	INTERRUPTION DUE TO FAULTS
97	7-Jun-2020	PART OF SANJAY NAGAR SHALIMAR BAGH	2	OTHER OUTAGE	UNPLANNED OUTAGE	7-Jun-2020	07:57	7-Jun-2020	08:23	26	0.00001	INTERRUPTION DUE TO FAULTS
98	8-Jun-2020	PARTS OF BHALASWA VILLAGE, I BLK MCD SCHOOL	29	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	22:47	9-Jun-2020	05:15	388	0.00065	FORCE MAJEURE DUE TO FIRE
99	8-Jun-2020	PARTS OF BURARI GARHI,UTTARNCHAL ENCLAVE, KAMAL VIHAR A,B C & D& A1 BLK, PART OF BHAGAT COLONY & CHANDAN VIHAR	401	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	09:35	8-Jun-2020	10:30	55	0.00017	INTERRUPTION DUE TO FAULTS
100	8-Jun-2020	PARTS OF BURARI GARHI,UTTARNCHAL ENCLAVE, KAMAL VIHAR A,B C & D& A1 BLK, PART OF BHAGAT COLONY & CHANDAN VIHAR	2322	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	09:35	8-Jun-2020	11:00	85	0.00078	INTERRUPTION DUE TO FAULTS
101	8-Jun-2020	PARTS OF MUKUNDPUR, BHALSWA DAIRY, KALANDER COLONY, BDP NAGAR, V. N.PURI, RADHA VIHAR, JANTA VIHAR, MUKUNDPUR EXTN. PART - 1& PART - 2, HIMGIRI, SAMTA VIHAR, J J PUNARWASH COLONY, RAJEEV NAGAR	2520	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	19:28	8-Jun-2020	19:40	11	0.00010	INTERRUPTION DUE TO FAULTS
102	8-Jun-2020	PARTS OF LAXMI VIHAR, VIRENDER NAGAR, ZONAL OFFICE, PART OF BURARI VILLAGE, SUNIL COLONY,F 2 BLK PRADHAN ENCLAVE & T/W SECTION.	889	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	17:04	8-Jun-2020	17:45	41	0.00016	SYSTEM SCHEDULE OUTAGE
103	8-Jun-2020	PART OF RAJASTHANI UDHYOG NAGAR	2	OTHER OUTAGE	UNPLANNED OUTAGE	8-Jun-2020	10:47	8-Jun-2020	11:34	47	0.00001	INTERRUPTION DUE TO FAULTS
104	9-Jun-2020	PART OF MAIN MKT SANT NAGAR	17	OTHER OUTAGE	PLANNED OUTAGE	9-Jun-2020	11:14	9-Jun-2020	13:45	151	0.00004	PLANNED OUTAGE
105	9-Jun-2020	PARTS OF HATHIWALA SANT NAGAR SHALIMAR BAGH	354	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	11:02	9-Jun-2020	12:48	106	0.00018	INTERRUPTION DUE TO FAULTS
106	9-Jun-2020	PART OF JJ CLUSTER EE BLOCK JAHANGIR PURI	18	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	23:53	10-Jun-2020	00:35	41	0.00006	INTERRUPTION DUE TO FAULTS
107	9-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	888	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	07:04	9-Jun-2020	08:14	70	0.00068	INTERRUPTION DUE TO FAULTS
108	9-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	2159	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	13:40	9-Jun-2020	15:37	117	0.00178	INTERRUPTION DUE TO FAULTS
109	9-Jun-2020	PARTS OF DJB,PART OF HIMGIRI ENCLAVE, A,B & A2 BLK, PART OF CHANDAN VIHAR & A2 BLK SANT NAGAR, HARIT VIHAR A B C & D BLK	1081	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	16:00	9-Jun-2020	16:40	40	0.00018	INTERRUPTION DUE TO FAULTS
110	9-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	6085	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	17:54	9-Jun-2020	18:20	25	0.00063	INTERRUPTION DUE TO FAULTS
111	9-Jun-2020	PART OF C-BLK OLD ZONAL OFFICE	2	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	18:07	9-Jun-2020	18:30	23	0.00001	INTERRUPTION DUE TO FAULTS
112	9-Jun-2020	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI	1958	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	18:07	9-Jun-2020	18:35	27	0.00026	INTERRUPTION DUE TO FAULTS
113	9-Jun-2020	PART OF HIRANKI SHALIMAR BAGH	3	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	06:08	9-Jun-2020	07:20	72	0.00004	INTERRUPTION DUE TO FAULTS
114	9-Jun-2020	PARTS OF GALI NO-12 SWAROOP NAGAR SHALIMAR BAGH	1843	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	13:00	9-Jun-2020	14:00	60	0.00057	INTERRUPTION DUE TO FAULTS
115	9-Jun-2020	PARTS OF RAJASTHANI UDHYOG NAGAR SHALIMAR BAGH	24	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	16:21	9-Jun-2020	16:30	9	0.00005	INTERRUPTION DUE TO FAULTS
116	9-Jun-2020	PARTS OF RAJASTHANI UDHYOG NAGAR SHALIMAR BAGH	24	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	16:21	9-Jun-2020	16:50	29	0.00015	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
117	9-Jun-2020	PARTS OF D BLOCK GALI NO 3 AND 4, GALI NO 5 - 11, SWAROOP NAGAR EXTENSION, SWAROOP NAGAR SINDHI COLONY, BHATTA ROAD	6741	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	18:46	9-Jun-2020	19:20	33	0.00126	INTERRUPTION DUE TO FAULTS
118	9-Jun-2020	PARTS OF BANGALI COLONY SANT NAGAR SHALIMAR BAGH	1624	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	20:18	9-Jun-2020	21:00	42	0.00013	INTERRUPTION DUE TO FAULTS
119	9-Jun-2020	PARTS OF A-BLK SWAROOP NAGAR SHALIMAR BAGH	6147	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	21:00	9-Jun-2020	21:30	30	0.00043	INTERRUPTION DUE TO FAULTS
120	9-Jun-2020	PARTS OF A-BLK SWAROOP NAGAR SHALIMAR BAGH	2602	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	21:31	9-Jun-2020	22:06	35	0.00024	INTERRUPTION DUE TO FAULTS
121	9-Jun-2020	PART OF SANJAY NAGAR SHALIMAR BAGH	17	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	23:07	10-Jun-2020	00:15	68	0.00009	INTERRUPTION DUE TO FAULTS
122	9-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	3251	OTHER OUTAGE	PLANNED OUTAGE	9-Jun-2020	12:56	9-Jun-2020	13:23	27	0.00023	PLANNED OUTAGE
123	9-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	509	630 kVA	PLANNED OUTAGE	9-Jun-2020	11:55	9-Jun-2020	14:30	155	0.00026	PLANNED OUTAGE
124	9-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	158	OTHER OUTAGE	UNPLANNED OUTAGE	9-Jun-2020	12:11	9-Jun-2020	12:40	29	0.00003	INTERRUPTION DUE TO FAULTS
125	10-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	84	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	19:29	10-Jun-2020	20:00	31	0.00002	INTERRUPTION DUE TO FAULTS
126	10-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	6269	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	21:44	10-Jun-2020	22:10	26	0.00173	INTERRUPTION DUE TO FAULTS
127	10-Jun-2020	PARTS OF BL BLOCK SCHOOL, AD MARKET SHALIMAR BAGH	310	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:14	10-Jun-2020	18:38	84	0.00028	INTERRUPTION DUE TO FAULTS
128	10-Jun-2020	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS)	2729	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	12:41	10-Jun-2020	13:00	19	0.00018	INTERRUPTION DUE TO FAULTS
129	10-Jun-2020	PARTS OF JAHANGIRABAD, RADHA VIHAR, C&D BLOCK MUKUNDPUR, SAMTA VIHAR, ISHU VIHAR	3751	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:28	10-Jun-2020	17:23	55	0.00061	INTERRUPTION DUE TO FAULTS
130	10-Jun-2020	PARTS OF DA BLOCK, DA MARKET HAIDER PUR SHALIMAR BAGH	1142	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:14	10-Jun-2020	17:35	21	0.00009	INTERRUPTION DUE TO FAULTS
131	10-Jun-2020	PARTS OF BJR HOSPITAL, BJR HOSPTIAL RESIDENCE, MIG FLATS (JAHANGIR PURI), ITI (JAHANGIR PURI), POLICE STATION (JAHANGIR PURI), POLICE RESDENTIAL COMPLEX,, FIRE STATION (JAHANGIR PURI), EE BLOCK PUMPING STATION (JAHANGIR PURI), DJB SEWAGE PUMPING STATION & PRAYAS, ITD PLANT	273	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:20	10-Jun-2020	18:16	56	0.00008	INTERRUPTION DUE TO FAULTS
132	10-Jun-2020	PART OF EE BLOCK PUMPING STATION	4	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:20	10-Jun-2020	18:45	85	0.00002	INTERRUPTION DUE TO FAULTS
133	10-Jun-2020	PART OF EE BLOCK PUMPING STATION	2	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:20	10-Jun-2020	18:45	85	0.00002	INTERRUPTION DUE TO FAULTS
134	10-Jun-2020	PARTS OF BURARI PRADHAN ENCLAVE BURARI SHALIMAR BAGH	1459	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:17	10-Jun-2020	19:50	153	0.00068	FORCE MAJEURE DUE TO RAIN/STORM
135	10-Jun-2020	PARTS OF NEAR B-3 MARKET, A-BIK JINDAL WALA	397	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:31	10-Jun-2020	18:04	33	0.00006	INTERRUPTION DUE TO FAULTS
136	10-Jun-2020	PARTS OF ARORA FARAM SNAT NAGAR SHALIMAR BAGH	2714	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:20	10-Jun-2020	20:30	191	0.00106	FORCE MAJEURE DUE TO SABOTAGE
137	10-Jun-2020	PARTS OF NEEL KANTH SNAT NAGAR SHALIMAR BAGH	3553	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:24	10-Jun-2020	19:00	96	0.00107	INTERRUPTION DUE TO FAULTS
138	10-Jun-2020	PARTS OF BANGALI COLONY SANT NAGAR SHALIMAR BAGH	2576	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:15	10-Jun-2020	18:28	73	0.00041	INTERRUPTION DUE TO FAULTS
139	10-Jun-2020	PARTS OF BANGALI COLONY SANT NAGAR SHALIMAR BAGH	1526	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:15	10-Jun-2020	18:28	73	0.00024	INTERRUPTION DUE TO FAULTS
140	10-Jun-2020	PARTS OF BANGALI COLONY SANT NAGAR SHALIMAR BAGH	2474	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:15	10-Jun-2020	19:05	110	0.00055	INTERRUPTION DUE TO FAULTS
141	10-Jun-2020	PARTS OF BHAGAT COLONY SHALIMAR BAGH	1007	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:23	10-Jun-2020	19:15	111	0.00034	INTERRUPTION DUE TO FAULTS
142	10-Jun-2020	PARTS OF AMBEDKAR NAGAR & J. J. CLUSTER (HAIDER PUR), GALAXY TOYOTA, AGGRAWAL AUTO MALL AND PWD STREET LIGHT	1144	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:09	10-Jun-2020	18:20	11	0.00004	INTERRUPTION DUE TO FAULTS
143	10-Jun-2020	PARTS OF BURARI GARHI,UTTARNCHAL ENCLAVE, KAMAL VIHAR A,B C & D& A1 BLK, PART OF BHAGAT COLONY & CHANDAN VIHAR	2723	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:06	10-Jun-2020	20:00	173	0.00264	FORCE MAJEURE DUE TO RAIN/STORM
144	10-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	1664	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:31	10-Jun-2020	22:30	239	0.00100	FORCE MAJEURE DUE TO RAIN/STORM
145	10-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	495	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:31	11-Jun-2020	15:10	1239	0.00241	FORCE MAJEURE DUE TO RAIN/STORM
146	10-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	1080	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	23:41	11-Jun-2020	00:11	30	0.00007	INTERRUPTION DUE TO FAULTS
147	10-Jun-2020	PARTS OF LAXMI VIHAR, VIRENDER NAGAR, ZONAL OFFICE, PART OF BURARI VILLAGE, SUNIL COLONY,F 2 BLK PRADHAN ENCLAVE & T/W SECTION.	889	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:12	10-Jun-2020	19:10	118	0.00131	INTERRUPTION DUE TO FAULTS
148	10-Jun-2020	PARTS OF APEX SCHOOL SNAT NAGAR SHALIMAR BAGH	1477	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:41	10-Jun-2020	20:01	80	0.00022	INTERRUPTION DUE TO FAULTS
149	10-Jun-2020	PARTS OF APEX SCHOOL SNAT NAGAR SHALIMAR BAGH	137	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:41	10-Jun-2020	22:30	228	0.00019	FORCE MAJEURE DUE TO SABOTAGE
150	10-Jun-2020	PARTS OF BURARI PRADHAN ENCLAVE BURARI SHALIMAR BAGH	1103	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	18:56	10-Jun-2020	19:30	34	0.00014	INTERRUPTION DUE TO FAULTS
151	10-Jun-2020	PARTS OF BURARI TOMAR COLONY SHALIMAR BAGH	3096	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	20:51	10-Jun-2020	21:45	53	0.00223	INTERRUPTION DUE TO FAULTS
152	10-Jun-2020	PARTS OF BURARI TOMAR COLONY SHALIMAR BAGH	2723	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	20:51	10-Jun-2020	23:00	129	0.00179	FORCE MAJEURE DUE TO RAIN/STORM
153	10-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	2057	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	23:04	10-Jun-2020	23:20	17	0.00041	INTERRUPTION DUE TO FAULTS
154	10-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	4212	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	23:04	10-Jun-2020	23:40	37	0.00132	INTERRUPTION DUE TO FAULTS
155	10-Jun-2020	PARTS OF BHALASWA VILLAGE, I BLK MCD SCHOOL	27	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	13:39	10-Jun-2020	14:00	21	0.00001	INTERRUPTION DUE TO FAULTS
156	10-Jun-2020	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL,PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B C,D E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE	2286	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:01	10-Jun-2020	17:55	54	0.00095	INTERRUPTION DUE TO FAULTS
157	10-Jun-2020	PARTS OF GALI NO-12 SWAROOP NAGAR SHALIMAR BAGH	1843	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:04	10-Jun-2020	17:40	35	0.00020	INTERRUPTION DUE TO FAULTS
158	10-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	846	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	11:21	10-Jun-2020	17:55	394	0.00099	PLANNED OUTAGE
159	10-Jun-2020	PARTS OF I.P. COLONY BURARI SHALIMAR BAGH	2884	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	11:26	10-Jun-2020	12:22	56	0.00045	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
160	10-Jun-2020	PARTS OF DDA GOLF COURSE, JANTA VIHAR, SHUKLA COLONY, MUKUNDPUR PART 2, HIMGIRI ENCLAVE, FAUJI COLONY, MUKUNDPUR VILLAGE, HARIT PARK	2897	OTHER OUTAGE	PLANNED OUTAGE	10-Jun-2020	11:02	10-Jun-2020	14:20	198	0.0016	PLANNED OUTAGE
161	10-Jun-2020	PARTS OF AK BLOCK, AO BLOCK JJ CLUSTER NO-2	294	990 kVA	PLANNED OUTAGE	10-Jun-2020	09:49	10-Jun-2020	12:40	171	0.00009	PLANNED OUTAGE
162	10-Jun-2020	PARTS OF AK BLOCK, AO BLOCK JJ CLUSTER NO-2	126	630 kVA	PLANNED OUTAGE	10-Jun-2020	08:48	10-Jun-2020	10:35	107	0.00006	PLANNED OUTAGE
163	10-Jun-2020	PARTS OF HINDUSTAN PETROLEUM SANT NAGAR SHALIMAR BAGH	1850	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:43	10-Jun-2020	19:12	89	0.00030	INTERRUPTION DUE TO FAULTS
164	10-Jun-2020	PARTS OF HINDUSTAN PETROLEUM SANT NAGAR SHALIMAR BAGH	1664	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:43	10-Jun-2020	19:25	102	0.00028	INTERRUPTION DUE TO FAULTS
165	10-Jun-2020	PARTS OF HINDUSTAN PETROLEUM SANT NAGAR SHALIMAR BAGH	3004	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	17:43	10-Jun-2020	19:35	112	0.00078	INTERRUPTION DUE TO FAULTS
166	10-Jun-2020	PART OF TRANSPORT AUTHORITY SHALIMAR BAGH	7	250 kVA	UNPLANNED OUTAGE	10-Jun-2020	12:45	10-Jun-2020	13:59	74	0.00002	SYSTEM SCHEDULE OUTAGE
167	10-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	6217	OTHER OUTAGE	UNPLANNED OUTAGE	10-Jun-2020	16:58	10-Jun-2020	18:20	81	0.00181	INTERRUPTION DUE TO FAULTS
168	11-Jun-2020	PART OF JAGAT PURVILLAGE SHALIMAR BAGH	8	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	10:49	11-Jun-2020	11:25	36	0.00002	INTERRUPTION DUE TO FAULTS
169	11-Jun-2020	PART OF BURARI PRADHAN ENCLAVE SHALIMAR BAGH	2	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	06:24	11-Jun-2020	09:20	176	0.00005	FORCE MAJEURE DUE TO SABOTAGE
170	11-Jun-2020	PART OF BURARI VILLAGE SHALIMAR BAGH	15	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	10:38	11-Jun-2020	11:05	27	0.00002	INTERRUPTION DUE TO FAULTS
171	11-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	1306	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	00:55	11-Jun-2020	02:00	65	0.00018	INTERRUPTION DUE TO FAULTS
172	11-Jun-2020	PARTS OF ARORA FARAM SNAT NAGAR SHALIMAR BAGH	80	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	02:39	11-Jun-2020	04:23	103	0.00009	INTERRUPTION DUE TO FAULTS
173	11-Jun-2020	PARTS OF ARORA FARAM SNAT NAGAR SHALIMAR BAGH	2630	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	04:08	11-Jun-2020	04:23	14	0.00007	INTERRUPTION DUE TO FAULTS
174	11-Jun-2020	PARTS OF BURARI GARHI,UTTARNCHAL ENCLAVE, KAMAL VIHAR A,B C & D& A1 BLK, PART OF BHAGAT COLONY & CHANDAN VIHAR	401	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	14:43	11-Jun-2020	16:14	91	0.00013	INTERRUPTION DUE TO FAULTS
175	11-Jun-2020	PARTS OF BURARI GARHI,UTTARNCHAL ENCLAVE, KAMAL VIHAR A,B C & D& A1 BLK, PART OF BHAGAT COLONY & CHANDAN VIHAR	401	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	16:15	11-Jun-2020	18:14	119	0.00132	INTERRUPTION DUE TO FAULTS
176	11-Jun-2020	PARTS OF BHALSWA SMA INDUSTRIAL AREA	46	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	16:46	11-Jun-2020	17:30	44	0.00049	INTERRUPTION DUE TO FAULTS
177	11-Jun-2020	PARTS OF BHALSWA SMA INDUSTRIAL AREA	27	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	16:46	11-Jun-2020	17:35	49	0.00020	INTERRUPTION DUE TO FAULTS
178	11-Jun-2020	PARTS OF BHALSWA SMA INDUSTRIAL AREA	29	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	16:46	11-Jun-2020	17:35	49	0.00020	INTERRUPTION DUE TO FAULTS
179	11-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	87	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	19:14	11-Jun-2020	19:44	30	0.00004	INTERRUPTION DUE TO FAULTS
180	11-Jun-2020	PARTS OF BADLI AND LABOUR CHOWK AREA	2398	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	04:52	11-Jun-2020	05:20	28	0.00072	INTERRUPTION DUE TO FAULTS
181	11-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	272	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	23:39	12-Jun-2020	00:44	65	0.00005	INTERRUPTION DUE TO FAULTS
182	11-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	1080	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	13:59	11-Jun-2020	15:10	71	0.00020	INTERRUPTION DUE TO FAULTS
183	11-Jun-2020	PARTS OF BHALSWA DAIRY SHALIMAR BAGH	4605	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	12:59	11-Jun-2020	13:30	32	0.00044	INTERRUPTION DUE TO FAULTS
184	11-Jun-2020	PARTS OF MUKUNDPUR, BHALSWA DAIRY, KALANDER COLONY, BDP NAGAR, V. N.PURI, RADHA VIHAR, JANTA VIHAR, MUKUNDPUR EXTN. PART - 1& PART - 2, HIMGIRI, SAMTA VIHAR, J J PUNARWASH COLONY, RAJEEV NAGAR	2520	OTHER OUTAGE	PLANNED OUTAGE	11-Jun-2020	11:39	11-Jun-2020	14:50	191	0.00138	PLANNED OUTAGE
185	11-Jun-2020	PARTS OF BHALASWA VILLAGE, I BLK MCD SCHOOL	356	OTHER OUTAGE	PLANNED OUTAGE	11-Jun-2020	13:15	11-Jun-2020	15:25	130	0.00014	PLANNED OUTAGE
186	6-Jun-2020	PARTS OF G BLOCK & G BLOCK JJ CLUSTER (JAHANGIR PURI)	21	OTHER OUTAGE	UNPLANNED OUTAGE	6-Jun-2020	07:38	6-Jun-2020	07:55	17	0.00002	SYSTEM SCHEDULE OUTAGE
187	11-Jun-2020	PARTS OF HINDUSTAN PETROLEUM SANT NAGAR SHALIMAR BAGH	6502	OTHER OUTAGE	UNPLANNED OUTAGE	11-Jun-2020	12:31	11-Jun-2020	13:05	34	0.00080	INTERRUPTION DUE TO FAULTS
188	12-Jun-2020	PART OF J BLOCK JAHANGIR PURI SHALIMAR BAGH	10	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:35	12-Jun-2020	13:55	79	0.00004	SYSTEM SCHEDULE OUTAGE
189	12-Jun-2020	PART OF BURARI VILLAGE SHALIMAR BAGH	19	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	04:14	12-Jun-2020	04:55	41	0.00001	SYSTEM SCHEDULE OUTAGE
190	12-Jun-2020	PARTS OF BHAGAT COLONY SHALIMAR BAGH	1007	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	16:46	12-Jun-2020	18:00	74	0.00020	SYSTEM SCHEDULE OUTAGE
191	12-Jun-2020	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI	26	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	02:23	12-Jun-2020	03:25	62	0.00002	INTERRUPTION DUE TO FAULTS
192	12-Jun-2020	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR	590	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	11:14	12-Jun-2020	12:40	86	0.00019	SYSTEM SCHEDULE OUTAGE
193	12-Jun-2020	PARTS OF MAHINDRA PARK & SANJAY NAGAR	30	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	15:45	12-Jun-2020	16:20	35	0.00003	INTERRUPTION DUE TO FAULTS
194	12-Jun-2020	PARTS OF D BLOCK GALI NO 3 AND 4, GALI NO 5 - 11, SWAROOP NAGAR EXTENSION, SWAROOP NAGAR SINDHI COLONY, BHATTA ROAD	493	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	22:38	12-Jun-2020	23:13	35	0.00004	INTERRUPTION DUE TO FAULTS
195	12-Jun-2020	PARTS OF BHAGAT COLONY SHALIMAR BAGH	1007	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	12:06	12-Jun-2020	13:25	79	0.00022	SYSTEM SCHEDULE OUTAGE
196	12-Jun-2020	PARTS OF HOTEL PREMIER INN, CA BLOCK SHALIMAR BAGH	25	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	10:27	12-Jun-2020	10:40	13	0.00001	INTERRUPTION DUE TO FAULTS
197	12-Jun-2020	PARTS OF SANGAM VIHAR GALI NO. 1,2,3 4,, 5,6,7,8,9.	4783	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	10:55	12-Jun-2020	11:25	30	0.00075	INTERRUPTION DUE TO FAULTS
198	12-Jun-2020	PARTS OF HARDEV NAGAR, SURENDER COLONY PART 3, PART OF SANAGAM VIHAR, SURRENDER COLONY PART2, SHIV KUNJ, DEEPANSHU COLONY,	3167	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	10:55	12-Jun-2020	11:30	35	0.00058	INTERRUPTION DUE TO FAULTS
199	12-Jun-2020	PARTS OF HARDEV NAGAR, SURENDER COLONY PART 3, PART OF SANAGAM VIHAR, SURRENDER COLONY PART2, SHIV KUNJ, DEEPANSHU COLONY,	3004	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	10:55	12-Jun-2020	11:32	37	0.00051	INTERRUPTION DUE TO FAULTS
200	12-Jun-2020	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS)	2516	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	16:40	12-Jun-2020	17:02	23	0.00019	INTERRUPTION DUE TO FAULTS
201	12-Jun-2020	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS)	213	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	16:40	12-Jun-2020	17:17	37	0.00005	INTERRUPTION DUE TO FAULTS
202	12-Jun-2020	PART OF BURARI VILLAGE SHALIMAR BAGH	9	OTHER OUTAGE	UNPLANNED OUTAGE	12-Jun-2020	18:53	12-Jun-2020	19:45	52	0.00003	INTERRUPTION DUE TO FAULTS
203	12-Jun-2020	PARTS OF BHALSWA DAIRY, JJ CLUSTER AND KALANDER COLONY	701	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	11:33	12-Jun-2020	11:57	24	0.00005	PLANNED OUTAGE
204	12-Jun-2020	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK	1119	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	10:00	12-Jun-2020	13:30	210	0.0007	PLANNED OUTAGE
205	12-Jun-2020	PART OF A BLOCK DDA SLUM FLATS	1	OTHER OUTAGE	PLANNED OUTAGE	12-Jun-2020	08:26	12-Jun-2020	13:30	304	0.00008	PLANNED OUTAGE
206	13-Jun-2020	PART OF JJ PUNARWASH COLONY SHALIMAR BAGH	5	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	10:58	13-Jun-2020	12:29	91	0.00003	PLANNED OUTAGE
207	13-Jun-2020	PART OF BURARI PRADHAN ENCLAVE SHALIMAR BAGH	3	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:30	13-Jun-2020	19:00	270	0.00015	FORCE MAJEURE DUE TO RAIN/STORM

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
208	13-Jun-2020	PARTS OF NEAR B-3 MARKET, A-BlK JINDAL WALA	24	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	18:13	13-Jun-2020	18:42	29	0.00004	INTERRUPTION DUE TO FAULTS
209	13-Jun-2020	PART OF JJ CLUSTER EE BLOCK JAHANGIR PURI	18	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	20:44	13-Jun-2020	20:56	12	0.000003	SYSTEM SCHEDULE OUTAGE
210	13-Jun-2020	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE HVDS VIJAY COLONY & JOGI MOHALLA	3693	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	06:58	13-Jun-2020	07:34	36	0.00045	INTERRUPTION DUE TO FAULTS
211	13-Jun-2020	PARTS OF BHALSWA DAIRY SHALIMAR BAGH	908	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	02:10	13-Jun-2020	02:30	20	0.00004	INTERRUPTION DUE TO FAULTS
212	13-Jun-2020	PARTS OF INDIAN OIL NO-1 SHALIMAR BAGH	2532	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	05:37	13-Jun-2020	07:00	84	0.00151	INTERRUPTION DUE TO FAULTS
213	13-Jun-2020	PARTS OF BHALASWA AND PEPSI GODOWN	2759	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	06:58	13-Jun-2020	08:00	63	0.00035	INTERRUPTION DUE TO FAULTS
214	13-Jun-2020	PARTS OF BURARI PRADHAN ENCLAVE BURARI SHALIMAR BAGH	1333	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:30	13-Jun-2020	16:25	115	0.00143	INTERRUPTION DUE TO FAULTS
215	13-Jun-2020	PARTS OF BURARI PRADHAN ENCLAVE BURARI SHALIMAR BAGH	1348	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:30	13-Jun-2020	16:50	140	0.00058	FORCE MAJEURE DUE TO RAIN/STORM
216	13-Jun-2020	PARTS OF BURARI PRADHAN ENCLAVE BURARI SHALIMAR BAGH	102	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:30	13-Jun-2020	17:15	165	0.00055	FORCE MAJEURE DUE TO RAIN/STORM
217	13-Jun-2020	PARTS OF INDIAN OIL, HP,& BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, ,RELIANCE TOWER, PART OF PARVATIANCHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN,	650	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:40	13-Jun-2020	15:35	55	0.00038	INTERRUPTION DUE TO FAULTS
218	13-Jun-2020	PARTS OF INDIAN OIL, HP,& BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, ,RELIANCE TOWER, PART OF PARVATIANCHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN,	354	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	14:40	13-Jun-2020	16:25	105	0.00044	INTERRUPTION DUE TO FAULTS
219	13-Jun-2020	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK	137	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:13	13-Jun-2020	16:20	67	0.00022	INTERRUPTION DUE TO FAULTS
220	13-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	2104	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:26	13-Jun-2020	16:16	50	0.00073	INTERRUPTION DUE TO FAULTS
221	13-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	966	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:44	13-Jun-2020	17:20	96	0.00067	INTERRUPTION DUE TO FAULTS
222	13-Jun-2020	PART OF A BLOCK DDA SLUM FLATS	9	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	15:24	13-Jun-2020	16:35	71	0.00010	INTERRUPTION DUE TO FAULTS
223	13-Jun-2020	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI	1641	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:05	13-Jun-2020	16:29	24	0.00017	INTERRUPTION DUE TO FAULTS
224	13-Jun-2020	PART OF C-BLK OLD ZONAL OFFICE	7	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:05	13-Jun-2020	18:50	165	0.00014	FORCE MAJEURE DUE TO RAIN/STORM
225	13-Jun-2020	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI	706	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	16:13	13-Jun-2020	16:48	35	0.00024	INTERRUPTION DUE TO FAULTS
226	13-Jun-2020	PARTS OF JJ CLUSTER HAIDER PUR , HAIDERPUR DISPENSARY, BB EAST, LEPROSY COLONY JJ CLUSTER, SAHIPUR VILLAGE	767	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:51	13-Jun-2020	18:53	62	0.00060	INTERRUPTION DUE TO FAULTS
227	13-Jun-2020	PARTS OF JJ CLUSTER HAIDER PUR , HAIDERPUR DISPENSARY, BB EAST, LEPROSY COLONY JJ CLUSTER, SAHIPUR VILLAGE	1865	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	17:59	13-Jun-2020	18:36	37	0.00026	INTERRUPTION DUE TO FAULTS
228	13-Jun-2020	PARTS OF I.P. COLONY BURARI SHALIMAR BAGH	920	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	13:23	13-Jun-2020	14:00	37	0.00009	PLANNED OUTAGE
229	13-Jun-2020	PARTS OF I.P. COLONY BURARI SHALIMAR BAGH	1964	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	12:42	13-Jun-2020	14:00	78	0.00041	PLANNED OUTAGE
230	13-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	312	OTHER OUTAGE	PLANNED OUTAGE	13-Jun-2020	10:21	13-Jun-2020	15:08	287	0.00024	PLANNED OUTAGE
231	13-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	5190	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	10:07	13-Jun-2020	11:10	62	0.00090	INTERRUPTION DUE TO FAULTS
232	13-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	1027	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	10:07	13-Jun-2020	12:15	127	0.00053	FORCE MAJEURE DUE TO SABOTAGE
233	13-Jun-2020	PARTS OF INTERCONNECTOR 1 & 2 JAHANGIRPURI SHALIMAR BAGH	43	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	19:00	13-Jun-2020	20:00	60	0.00008	INTERRUPTION DUE TO FAULTS
234	13-Jun-2020	PARTS OF INTERCONNECTOR 1 & 2 JAHANGIRPURI SHALIMAR BAGH	977	OTHER OUTAGE	UNPLANNED OUTAGE	13-Jun-2020	21:29	13-Jun-2020	22:20	51	0.00023	INTERRUPTION DUE TO FAULTS
235	14-Jun-2020	PARTS OF BURARI GARHI,UTTARNCHAL ENCLAVE, KAMAL VIHAR A,B C & D& A1 BLK, PART OF BHAGAT COLONY & CHANDAN VIHAR	401	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	12:51	14-Jun-2020	13:34	43	0.00006	INTERRUPTION DUE TO FAULTS
236	14-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	143	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	10:54	14-Jun-2020	11:55	61	0.00002	INTERRUPTION DUE TO FAULTS
237	14-Jun-2020	PART OF A-BlK JINDAL WALA SHALIMAR BAGH	16	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	09:15	14-Jun-2020	11:08	112	0.00003	SYSTEM SCHEDULE OUTAGE
238	14-Jun-2020	PART OF A BLOCK DDA SLUM FLATS	20	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	16:45	14-Jun-2020	17:05	20	0.00001	SYSTEM SCHEDULE OUTAGE
239	14-Jun-2020	PARTS OF SANT NAGER PARTLY (B-BLOCK) BABA COLONY, JOGI MOHALLA, ARORA FARM, MILAN VIHAR, PRADHAN ENCLAVE, PARVATIA ANCHAL, TEACHER COLONY & VASISTH ENCLAVE, BURARI	645	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	13:35	14-Jun-2020	14:20	45	0.00019	INTERRUPTION DUE TO FAULTS
240	14-Jun-2020	PARTS OF SANT NAGER PARTLY (B-BLOCK) BABA COLONY, JOGI MOHALLA, ARORA FARM, MILAN VIHAR, PRADHAN ENCLAVE, PARVATIA ANCHAL, TEACHER COLONY & VASISTH ENCLAVE, BURARI	621	OTHER OUTAGE	UNPLANNED OUTAGE	14-Jun-2020	13:35	14-Jun-2020	15:55	140	0.00019	FORCE MAJEURE DUE TO SABOTAGE
241	15-Jun-2020	PART OF JAGAT PURVILLAGE SHALIMAR BAGH	10	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	18:02	15-Jun-2020	19:30	88	0.00002	SYSTEM SCHEDULE OUTAGE
242	15-Jun-2020	PART OF MCD QUARTER JAHANGIR PURI	7	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	22:40	15-Jun-2020	22:55	15	0.000004	SYSTEM SCHEDULE OUTAGE
243	15-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	1949	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	10:35	15-Jun-2020	12:00	85	0.00043	PLANNED OUTAGE
244	15-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	2104	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	12:45	15-Jun-2020	14:00	75	0.00042	PLANNED OUTAGE
245	15-Jun-2020	PARTS OF BANGALI COLONY SANT NAGAR SHALIMAR BAGH	1482	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	13:30	15-Jun-2020	14:07	37	0.00015	PLANNED OUTAGE
246	15-Jun-2020	PARTS OF BANGALI COLONY SANT NAGAR SHALIMAR BAGH	1624	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	10:35	15-Jun-2020	11:24	49	0.00023	PLANNED OUTAGE
247	15-Jun-2020	PARTS OF BANGALI COLONY SANT NAGAR SHALIMAR BAGH	142	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	11:26	15-Jun-2020	14:08	162	0.00009	PLANNED OUTAGE
248	15-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	1220	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	14:40	15-Jun-2020	15:22	42	0.00014	PLANNED OUTAGE
249	15-Jun-2020	PARTS OF BL BLOCK SCHOOL, AD MARKET SHALIMAR BAGH	310	OTHER OUTAGE	PLANNED OUTAGE	15-Jun-2020	08:52	15-Jun-2020	13:00	248	0.00021	PLANNED OUTAGE
250	15-Jun-2020	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI	1002	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	02:09	15-Jun-2020	03:00	51	0.00027	INTERRUPTION DUE TO FAULTS
251	15-Jun-2020	PARTS OF NEEL KANTH SNAT NAGAR SHALIMAR BAGH	3553	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	22:24	15-Jun-2020	23:17	52	0.00176	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
252	15-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	143	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	12:27	15-Jun-2020	14:00	93	0.00003	INTERRUPTION DUE TO FAULTS
253	15-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	169	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	18:52	15-Jun-2020	19:32	40	0.00001	SYSTEM SCHEDULE OUTAGE
254	15-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	1027	OTHER OUTAGE	UNPLANNED OUTAGE	15-Jun-2020	12:42	15-Jun-2020	13:26	44	0.00018	INTERRUPTION DUE TO FAULTS
255	16-Jun-2020	PART OF J BLOCK JAHANGIR PURI SHALIMAR BAGH	18	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	22:45	17-Jun-2020	00:20	95	0.00003	SYSTEM SCHEDULE OUTAGE
256	16-Jun-2020	PARTS OF SSI INDUSTRIAL AREA BHALSWA SHALIMAR BAGH	286	OTHER OUTAGE	PLANNED OUTAGE	16-Jun-2020	09:31	16-Jun-2020	10:40	68	0.0001	PLANNED OUTAGE
257	16-Jun-2020	PART OF KAUSHIK ENCLAVE B BLK SHALIMAR BAGH	7	OTHER OUTAGE	PLANNED OUTAGE	16-Jun-2020	12:05	16-Jun-2020	15:27	202	0.00006	PLANNED OUTAGE
258	16-Jun-2020	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI)	1129	OTHER OUTAGE	PLANNED OUTAGE	16-Jun-2020	10:24	16-Jun-2020	16:00	336	0.00093	PLANNED OUTAGE
259	16-Jun-2020	PARTS OF WAZIRABAD FLYOVER, PRATIBHA INDUSTRY SANT NAGAR SHALIMAR BAGH	784	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	05:20	16-Jun-2020	05:48	28	0.00009	SYSTEM SCHEDULE OUTAGE
260	16-Jun-2020	PART OF K BLOCK JAHANGIR PURI	20	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	09:12	16-Jun-2020	10:45	93	0.00003	INTERRUPTION DUE TO FAULTS
261	16-Jun-2020	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS)	468	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	10:21	16-Jun-2020	10:45	24	0.00002	INTERRUPTION DUE TO FAULTS
262	16-Jun-2020	PARTS OF GALI NO 12 - 17 SWAROOP NAGAR, SHRADHA NAND COLONY, JJ CLUSTER 1 & 2	485	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	19:17	16-Jun-2020	19:29	12	0.00001	SYSTEM SCHEDULE OUTAGE
263	16-Jun-2020	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL,PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B C,D E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE	2286	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	18:15	16-Jun-2020	19:15	59	0.00083	INTERRUPTION DUE TO FAULTS
264	16-Jun-2020	PARTS OF IP COLONY A,B & C BLK, DAYANAND ENCLAVE, PART OF KAUSHIK ENCLAVE A & B BLK, AMRIT VIHAR A,B, C & A1 BLK & SWAROOP NAGAR ROAD	1291	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	18:25	16-Jun-2020	19:05	40	0.00039	INTERRUPTION DUE TO FAULTS
265	16-Jun-2020	PARTS OF MAHINDRA PARK & SANJAY NAGAR	2700	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	23:58	17-Jun-2020	00:23	24	0.00035	INTERRUPTION DUE TO FAULTS
266	16-Jun-2020	PARTS OF BURARI ROAD SWAROOP NAGAR, A BLOCK SWAROOP NAGAR, KHADDA COLONY, RAVI ICE FACTORY, SAYA WALA, XYZ COLONY	4627	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	05:17	16-Jun-2020	06:20	63	0.00212	INTERRUPTION DUE TO FAULTS
267	16-Jun-2020	PARTS OF SANGAM VIHAR GALI NO. 1,2,3 4,, 5,6,7,8,9.	4784	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	07:31	16-Jun-2020	08:14	43	0.00077	INTERRUPTION DUE TO FAULTS
268	16-Jun-2020	PARTS OF GOPI WALA , JHARODA SCHOOL , BHAGWAN PARK, SURNDER COLONY PART 1 &2,,KAYAKALP HOSPITAL,	3824	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	19:07	16-Jun-2020	19:26	18	0.00046	INTERRUPTION DUE TO FAULTS
269	16-Jun-2020	PARTS OF GALI NO-12 SWAROOP NAGAR SHALIMAR BAGH	1843	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	20:19	16-Jun-2020	20:45	26	0.00018	SYSTEM SCHEDULE OUTAGE
270	16-Jun-2020	PARTS OF NEAR B-3 MARKET, A-BIK JINDAL WALA	37	OTHER OUTAGE	UNPLANNED OUTAGE	16-Jun-2020	23:04	16-Jun-2020	23:22	18	0.00001	INTERRUPTION DUE TO FAULTS
271	17-Jun-2020	PART OF BHALASWA VILLAGE SHALIMAR BAGH	19	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	08:35	17-Jun-2020	09:12	37	0.00005	INTERRUPTION DUE TO FAULTS
272	17-Jun-2020	PART OF JAGAT PURVILLAGE SHALIMAR BAGH	16	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	16:13	17-Jun-2020	16:40	27	0.00001	INTERRUPTION DUE TO FAULTS
273	17-Jun-2020	PART OF JJ CLUSTER EE BLOCK JAHANGIR PURI	12	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	01:48	17-Jun-2020	02:11	23	0.00001	INTERRUPTION DUE TO FAULTS
274	17-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	169	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	11:29	17-Jun-2020	13:27	118	0.00010	SYSTEM SCHEDULE OUTAGE
275	17-Jun-2020	PART OF JJ CLUSTER EE BLOCK JAHANGIR PURI	12	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	12:41	17-Jun-2020	13:11	30	0.00002	INTERRUPTION DUE TO FAULTS
276	17-Jun-2020	PARTS OF GALI NO 12 - 17 SWAROOP NAGAR, SHRADHA NAND COLONY, JJ CLUSTER 1 & 2	48	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	17:57	17-Jun-2020	18:08	12	0.00003	INTERRUPTION DUE TO FAULTS
277	17-Jun-2020	PARTS OF MAHINDRA PARK & SANJAY NAGAR	242	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	00:26	17-Jun-2020	01:05	39	0.00003	INTERRUPTION DUE TO FAULTS
278	17-Jun-2020	PARTS OF BANGALI COLONY SANT NAGAR SHALIMAR BAGH	1526	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	07:24	17-Jun-2020	08:00	36	0.00018	INTERRUPTION DUE TO FAULTS
279	17-Jun-2020	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE HVDS VIJAY COLONY & JOGI MOHALLA	4503	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	08:19	17-Jun-2020	09:10	51	0.00056	INTERRUPTION DUE TO FAULTS
280	17-Jun-2020	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR	3306	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	10:43	17-Jun-2020	11:10	27	0.00019	INTERRUPTION DUE TO FAULTS
281	17-Jun-2020	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI	1452	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	18:03	17-Jun-2020	18:50	46	0.00013	INTERRUPTION DUE TO FAULTS
282	17-Jun-2020	PARTS OF NEAR B-3 MARKET, A-BIK JINDAL WALA	22	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	20:30	17-Jun-2020	20:52	22	0.00001	INTERRUPTION DUE TO FAULTS
283	17-Jun-2020	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI	184	OTHER OUTAGE	UNPLANNED OUTAGE	17-Jun-2020	22:57	17-Jun-2020	23:35	38	0.00008	INTERRUPTION DUE TO FAULTS
284	18-Jun-2020	PARTS OF PRAGYA MALL NEAR SHALIMAR BAGH CLUB	41	400 kVA	PLANNED OUTAGE	18-Jun-2020	11:00	18-Jun-2020	12:40	100	0.00003	PLANNED OUTAGE
285	18-Jun-2020	PARTS OF NEAR B-3 MARKET, A-BIK JINDAL WALA	186	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	10:36	18-Jun-2020	13:35	179	0.00015	FORCE MAJEURE DUE TO FIRE
286	18-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	82	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	13:50	18-Jun-2020	15:46	116	0.00006	INTERRUPTION DUE TO FAULTS
287	18-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	1219	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	14:16	18-Jun-2020	15:46	90	0.00025	INTERRUPTION DUE TO FAULTS
288	18-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	2165	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	01:51	18-Jun-2020	02:30	38	0.00075	INTERRUPTION DUE TO FAULTS
289	18-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	2159	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	01:51	18-Jun-2020	02:35	44	0.00079	INTERRUPTION DUE TO FAULTS
290	18-Jun-2020	PARTS OF RAJEEV NAGAR BHALSWA SHALIMAR BAGH	2246	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	06:50	18-Jun-2020	07:50	61	0.00042	INTERRUPTION DUE TO FAULTS
291	18-Jun-2020	PARTS OF NEAR B-3 MARKET, A-BIK JINDAL WALA	36	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	09:16	18-Jun-2020	10:35	78	0.00002	INTERRUPTION DUE TO FAULTS
292	18-Jun-2020	PARTS OF INDIAN OIL NO-1 SHALIMAR BAGH	816	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	22:28	19-Jun-2020	00:18	109	0.00030	SYSTEM SCHEDULE OUTAGE
293	18-Jun-2020	PARTS OF NEAR B-3 MARKET, A-BIK JINDAL WALA	33	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	23:39	18-Jun-2020	23:49	10	0.000003	INTERRUPTION DUE TO FAULTS
294	18-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	931	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:42	18-Jun-2020	14:00	78	0.00013	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
295	18-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	1027	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:42	18-Jun-2020	14:10	88	0.00025	INTERRUPTION DUE TO FAULTS
296	18-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	700	OTHER OUTAGE	UNPLANNED OUTAGE	18-Jun-2020	12:42	18-Jun-2020	15:00	138	0.00019	FORCE MAJEURE DUE TO SABOTAGE
297	19-Jun-2020	PART OF J BLOCK JAHANGIR PURI SHALIMAR BAGH	7	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	02:29	19-Jun-2020	03:26	56	0.00002	INTERRUPTION DUE TO FAULTS
298	19-Jun-2020	PART OF MCD QUARTER JAHANGIR PURI	3	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	11:00	19-Jun-2020	12:00	60	0.00002	INTERRUPTION DUE TO FAULTS
299	19-Jun-2020	PART OF MILLAN VIHAR SHALIMAR BAGH	13	OTHER OUTAGE	PLANNED OUTAGE	19-Jun-2020	11:11	19-Jun-2020	13:40	149	0.00004	PLANNED OUTAGE
300	19-Jun-2020	PARTS OF AMBEDKAR NAGAR EXTENSION	613	630 kVA	PLANNED OUTAGE	19-Jun-2020	09:38	19-Jun-2020	11:34	116	0.00019	PLANNED OUTAGE
301	19-Jun-2020	PARTS OF HAIDER PUR VILLAGE & GOVIND MOHALLA	493	990 kVA	PLANNED OUTAGE	19-Jun-2020	10:55	19-Jun-2020	13:19	144	0.00016	PLANNED OUTAGE
302	19-Jun-2020	PARTS OF AMBEDKAR NAGAR EXTENSION	500	630 kVA	PLANNED OUTAGE	19-Jun-2020	09:41	19-Jun-2020	11:36	115	0.00016	PLANNED OUTAGE
303	19-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	1590	OTHER OUTAGE	PLANNED OUTAGE	19-Jun-2020	12:11	19-Jun-2020	16:05	234	0.00098	PLANNED OUTAGE
304	19-Jun-2020	PARTS OF MAHINDRA PARK & SANJAY NAGAR	33	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	10:37	19-Jun-2020	14:06	209	0.00006	FORCE MAJEURE DUE TO SABOTAGE
305	19-Jun-2020	PARTS OF A BLK KAUSHIK ENCLAVE, OSKAR SCHOOL,PINKI COLONY, PART OF AJIT VIHAR,GANDA TANK, WEST KAMAL VIHAR, TOMAR COLONY A,B C,D E & F BLK, PART OF SATYA VIHAR & EKTA ENCLAVE	1938	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	14:37	19-Jun-2020	15:09	32	0.00045	INTERRUPTION DUE TO FAULTS
306	19-Jun-2020	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI	2122	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	18:08	19-Jun-2020	18:40	31	0.00031	INTERRUPTION DUE TO FAULTS
307	19-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	1796	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	19:34	19-Jun-2020	20:25	51	0.00034	INTERRUPTION DUE TO FAULTS
308	19-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	312	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	19:34	19-Jun-2020	21:15	101	0.00022	INTERRUPTION DUE TO FAULTS
309	19-Jun-2020	PARTS OF INDIAN OIL NO-1 SHALIMAR BAGH	2532	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	01:10	19-Jun-2020	02:59	109	0.00091	INTERRUPTION DUE TO FAULTS
310	19-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	1306	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	00:45	19-Jun-2020	01:10	25	0.00010	INTERRUPTION DUE TO FAULTS
311	19-Jun-2020	PARTS OF BHALASWA AND PEPSI GODOWN	610	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	02:28	19-Jun-2020	02:51	23	0.00005	INTERRUPTION DUE TO FAULTS
312	19-Jun-2020	PARTS OF BANGALI COLONY SANT NAGAR SHALIMAR BAGH	23	OTHER OUTAGE	UNPLANNED OUTAGE	19-Jun-2020	02:26	19-Jun-2020	02:44	18	0.00001	INTERRUPTION DUE TO FAULTS
313	19-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	1027	OTHER OUTAGE	PLANNED OUTAGE	19-Jun-2020	10:38	19-Jun-2020	11:53	75	0.00021	PLANNED OUTAGE
314	20-Jun-2020	PART OF J BLOCK JAHANGIR PURI SHALIMAR BAGH	14	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	00:14	20-Jun-2020	00:40	25	0.00001	INTERRUPTION DUE TO FAULTS
315	20-Jun-2020	PARTS OF INDIAN OIL NO-1 SHALIMAR BAGH	475	OTHER OUTAGE	PLANNED OUTAGE	20-Jun-2020	11:22	20-Jun-2020	17:55	393	0.00044	PLANNED OUTAGE
316	20-Jun-2020	PART OF A-BlK JINDAL WALA SHALIMAR BAGH	13	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	18:02	20-Jun-2020	18:24	22	0.00001	INTERRUPTION DUE TO FAULTS
317	21-Jun-2020	PART OF HAIDER PUR VILLAGE SHALIMAR BAGH	5	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	14:21	21-Jun-2020	15:06	45	0.00001	INTERRUPTION DUE TO FAULTS
318	20-Jun-2020	PARTS OF GALI NO-12 SWAROOP NAGAR SHALIMAR BAGH	1843	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:23	20-Jun-2020	05:06	43	0.00043	INTERRUPTION DUE TO FAULTS
319	20-Jun-2020	PARTS OF I.P. COLONY BURARI SHALIMAR BAGH	4487	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:21	20-Jun-2020	09:35	74	0.00093	INTERRUPTION DUE TO FAULTS
320	20-Jun-2020	PARTS OF GALI NO-12 SWAROOP NAGAR SHALIMAR BAGH	1843	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:19	20-Jun-2020	08:44	25	0.00010	INTERRUPTION DUE TO FAULTS
321	20-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	1590	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	11:01	20-Jun-2020	16:30	329	0.00238	FORCE MAJEURE DUE TO SABOTAGE
322	20-Jun-2020	PARTS OF JJ CLUSTER HAIDER PUR , HAIDERPUR DISPENSARY, BB EAST, LEPROSY COLONY JJ CLUSTER, SAHIPUR VILLAGE	324	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	10:05	20-Jun-2020	10:30	25	0.00004	INTERRUPTION DUE TO FAULTS
323	20-Jun-2020	PARTS OF AD BLK WAZIRPUR, A-31 TO 49 SIDE, A-23, AD-8 SIDE	1873	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:25	20-Jun-2020	05:15	49	0.00022	INTERRUPTION DUE TO FAULTS
324	20-Jun-2020	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK	2932	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	04:25	20-Jun-2020	05:05	40	0.00040	INTERRUPTION DUE TO FAULTS
325	20-Jun-2020	PARTS OF ARORA FARAM SNAT NAGAR SHALIMAR BAGH	2714	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	08:14	20-Jun-2020	08:54	40	0.00028	INTERRUPTION DUE TO FAULTS
326	20-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	87	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	09:40	20-Jun-2020	10:50	70	0.00004	INTERRUPTION DUE TO FAULTS
327	20-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	1219	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	10:13	20-Jun-2020	10:50	37	0.00019	INTERRUPTION DUE TO FAULTS
328	20-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	1657	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	10:01	20-Jun-2020	10:35	35	0.00022	INTERRUPTION DUE TO FAULTS
329	20-Jun-2020	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS)	2480	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	09:54	20-Jun-2020	11:43	109	0.00088	INTERRUPTION DUE TO FAULTS
330	20-Jun-2020	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI	1452	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	18:18	20-Jun-2020	18:52	34	0.00027	INTERRUPTION DUE TO FAULTS
331	20-Jun-2020	PARTS OF BHAGAT COLONY SHALIMAR BAGH	1008	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	18:40	20-Jun-2020	19:21	42	0.00022	INTERRUPTION DUE TO FAULTS
332	20-Jun-2020	PARTS OF INTERCONNECTOR 1 & 2 JAHANGIRPURI SHALIMAR BAGH	43	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	09:00	20-Jun-2020	13:30	270	0.00008	FORCE MAJEURE DUE TO RAIN/STORM
333	21-Jun-2020	PART OF BHALASWA VILLAGE SHALIMAR BAGH	18	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	07:55	21-Jun-2020	08:30	36	0.00004	INTERRUPTION DUE TO FAULTS
334	21-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	1027	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	07:13	21-Jun-2020	08:00	47	0.00020	INTERRUPTION DUE TO FAULTS
335	21-Jun-2020	PARTS OF C&D BLK SHALIMAR BAGH	26	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	11:07	21-Jun-2020	11:23	16	0.000004	SYSTEM SCHEDULE OUTAGE
336	21-Jun-2020	PART OF A-BlK JINDAL WALA SHALIMAR BAGH	13	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	19:39	21-Jun-2020	19:55	16	0.000004	INTERRUPTION DUE TO FAULTS
337	21-Jun-2020	PARTS OF AMBEDKAR NAGAR & J. J. CLUSTER (HAIDER PUR), GALAXY TOYOTA, AGGRAWAL AUTO MALL AND PWD STREET LIGHT	1144	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	02:10	21-Jun-2020	03:24	74	0.00021	INTERRUPTION DUE TO FAULTS
338	21-Jun-2020	PARTS OF HAIDER PUR VILLAGE & GOVIND MOHALLA	937	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	06:39	21-Jun-2020	07:38	59	0.00049	INTERRUPTION DUE TO FAULTS
339	21-Jun-2020	PARTS OF HAIDER PUR VILLAGE & GOVIND MOHALLA	493	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	06:39	21-Jun-2020	07:40	61	0.00017	INTERRUPTION DUE TO FAULTS
340	21-Jun-2020	PARTS OF HAIDER PUR VILLAGE & GOVIND MOHALLA	599	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	06:39	21-Jun-2020	07:45	66	0.00022	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
341	21-Jun-2020	PARTS OF BHALSWA DAIRY SHALIMAR BAGH	6207	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	09:39	21-Jun-2020	10:06	27	0.00094	INTERRUPTION DUE TO FAULTS
342	21-Jun-2020	PARTS OF HARDEV NAGAR, SURENDER COLONY PART 3, PART OF SANAGAM VIHAR, SURRENDER COLONY PART2, SHIV KUNJ, DEEPANSHU COLONY,	3168	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	19:17	21-Jun-2020	19:35	18	0.00033	INTERRUPTION DUE TO FAULTS
343	21-Jun-2020	PARTS OF ISHU VIHAR BHALSWA SHALIMAR BAGH	3718	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	20:12	21-Jun-2020	20:50	39	0.00027	INTERRUPTION DUE TO FAULTS
344	21-Jun-2020	PARTS OF B BLOCK & A-1 MARKET JAHANGIR PURI	4082	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	20:56	21-Jun-2020	21:15	19	0.00042	INTERRUPTION DUE TO FAULTS
345	21-Jun-2020	PARTS OF BHALASWA VILLAGE, I BLK MCD SCHOOL	233	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	22:24	21-Jun-2020	23:00	36	0.00010	INTERRUPTION DUE TO FAULTS
346	21-Jun-2020	PARTS OF BK & BL BLOCKS SHALIMAR BAGH, SHALIMAR CLUB, AP BLOCK, BI BLOCK, AMBIENS MALL	1166	OTHER OUTAGE	UNPLANNED OUTAGE	21-Jun-2020	23:34	21-Jun-2020	23:50	16	0.00031	INTERRUPTION DUE TO FAULTS
347	22-Jun-2020	PARTS OF NEAR B-3 MARKET, A-BIK JINDAL WALA	33	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	08:56	22-Jun-2020	09:08	12	0.00002	SYSTEM SCHEDULE OUTAGE
348	22-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	87	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	09:15	22-Jun-2020	11:58	163	0.00014	FORCE MAJEURE DUE TO SABOTAGE
349	22-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	1219	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	10:02	22-Jun-2020	11:58	116	0.00048	INTERRUPTION DUE TO FAULTS
350	22-Jun-2020	PART OF INTERCONNECTOR 1 JAHANGIRPURI	15	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	10:25	22-Jun-2020	12:20	115	0.00010	INTERRUPTION DUE TO FAULTS
351	22-Jun-2020	PART OF C-BLK OLD ZONAL OFFICE	14	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	11:00	22-Jun-2020	11:15	15	0.000004	SYSTEM SCHEDULE OUTAGE
352	22-Jun-2020	PARTS OF BHALSWA DAIRY, JJ CLUSTER AND KALANDER COLONY	217	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	11:23	22-Jun-2020	12:00	37	0.00005	INTERRUPTION DUE TO FAULTS
353	22-Jun-2020	PART OF CD PARK JAL BOARD SHALIMAR BAGH	8	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	09:34	22-Jun-2020	11:35	121	0.00007	FORCE MAJEURE DUE TO SABOTAGE
354	22-Jun-2020	PARTS OF SANT NAGAR SHALIMAR BAGH	810	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	12:31	22-Jun-2020	12:45	14	0.00003	SYSTEM SCHEDULE OUTAGE
355	22-Jun-2020	PARTS OF A-BLK SWAROOP NAGAR SHALIMAR BAGH	450	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	12:55	22-Jun-2020	13:45	50	0.00007	INTERRUPTION DUE TO FAULTS
356	22-Jun-2020	PARTS OF C&D BLK SHALIMAR BAGH	26	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	14:21	22-Jun-2020	18:00	219	0.00012	FORCE MAJEURE DUE TO SABOTAGE
357	22-Jun-2020	PARTS OF GALI NO-12 SWAROOP NAGAR SHALIMAR BAGH	1843	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	02:05	22-Jun-2020	02:35	30	0.00013	INTERRUPTION DUE TO FAULTS
358	22-Jun-2020	PARTS OF D BLOCK GALI NO 3 AND 4, GALI NO 5 - 11, SWAROOP NAGAR EXTENSION, SWAROOP NAGAR SINDHI COLONY, BHATTA ROAD	4083	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	02:51	22-Jun-2020	03:30	39	0.00055	INTERRUPTION DUE TO FAULTS
359	22-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	888	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:23	22-Jun-2020	06:10	47	0.00013	INTERRUPTION DUE TO FAULTS
360	22-Jun-2020	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	1220	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	05:23	22-Jun-2020	06:17	54	0.00023	INTERRUPTION DUE TO FAULTS
361	22-Jun-2020	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS)	654	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	06:35	22-Jun-2020	07:20	45	0.00013	INTERRUPTION DUE TO FAULTS
362	22-Jun-2020	PARTS OF C BLK , CD PARK JJ CLUSTER , CD PARK JAL BOARD & C BLK DSIDC	2058	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	06:31	22-Jun-2020	07:35	64	0.00053	INTERRUPTION DUE TO FAULTS
363	22-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	1306	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	07:38	22-Jun-2020	08:35	58	0.00024	INTERRUPTION DUE TO FAULTS
364	22-Jun-2020	PARTS OF RAJASTHANI UDHYOG NAGAR SHALIMAR BAGH	80	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	09:30	22-Jun-2020	10:08	38	0.00104	INTERRUPTION DUE TO FAULTS
365	22-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	2104	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	17:24	22-Jun-2020	18:05	40	0.00017	INTERRUPTION DUE TO FAULTS
366	22-Jun-2020	PARTS OF BURARI GARHI,UTTARNCHAL ENCLAVE, KAMAL VIHAR A,B C & D& A1 BLK, PART OF BHAGAT COLONY & CHANDAN VIHAR	1430	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	22:46	22-Jun-2020	23:20	34	0.00008	INTERRUPTION DUE TO FAULTS
367	22-Jun-2020	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR	3307	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	23:41	22-Jun-2020	23:57	16	0.00009	INTERRUPTION DUE TO FAULTS
368	23-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	1027	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	15:35	23-Jun-2020	17:00	85	0.00024	INTERRUPTION DUE TO FAULTS
369	23-Jun-2020	PART OF A-BIK JINDAL WALA SHALIMAR BAGH	13	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	10:56	23-Jun-2020	12:26	90	0.00005	INTERRUPTION DUE TO FAULTS
370	23-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	156	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	14:16	23-Jun-2020	15:15	59	0.00008	INTERRUPTION DUE TO FAULTS
371	23-Jun-2020	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI	184	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	14:29	23-Jun-2020	15:30	61	0.00009	INTERRUPTION DUE TO FAULTS
372	23-Jun-2020	PART OF CD PARK JAL BOARD SHALIMAR BAGH	19	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	16:05	23-Jun-2020	17:10	65	0.00005	SYSTEM SCHEDULE OUTAGE
373	23-Jun-2020	PARTS OF C BLK , CD PARK JJ CLUSTER , CD PARK JAL BOARD & C BLK DSIDC	22	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	20:02	23-Jun-2020	20:35	33	0.00002	INTERRUPTION DUE TO FAULTS
374	23-Jun-2020	PART OF JJ CLUSTER EE BLOCK JAHANGIR PURI	10	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	05:26	23-Jun-2020	06:40	74	0.00002	INTERRUPTION DUE TO FAULTS
375	23-Jun-2020	PARTS OF HARDEV NAGAR, SURENDER COLONY PART 3, PART OF SANAGAM VIHAR, SURRENDER COLONY PART2, SHIV KUNJ, DEEPANSHU COLONY,	3168	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	06:26	23-Jun-2020	06:53	27	0.00057	INTERRUPTION DUE TO FAULTS
376	23-Jun-2020	PARTS OF APEX SCHOOL SANT NAGAR SHALIMAR BAGH	1615	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	07:02	23-Jun-2020	08:20	78	0.00026	INTERRUPTION DUE TO FAULTS
377	23-Jun-2020	PARTS OF IP COLONY A,B & C BLK, DAYANAND ENCLAVE, PART OF KAUSHIK ENCLAVE A & B BLK, AMRIT VIHAR A,B, C & A1 BLK & SWAROOP NAGAR ROAD	3950	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	07:53	23-Jun-2020	09:15	83	0.00092	INTERRUPTION DUE TO FAULTS
378	23-Jun-2020	PARTS OF BABA COLONY A BLK, VASISTH ENCLAVE, PART OF BURARI VILLAGE, PRADHAN ENCLAVE A,B, C D,E BLK,HVDS NUMBERDAR COLONY & TEACHER COLONY	3053	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	08:16	23-Jun-2020	09:00	44	0.00031	INTERRUPTION DUE TO FAULTS
379	23-Jun-2020	PARTS OF J & K BLOCK (JAHANGIR PURI), PART OF VILLAGE BHALASVA,, J J CLUSTER BEHIND ITI (JAHANGIR PURI), J J CLUSTER OPPOSITE VIDYA GAS AGENCY (JAHANGIR PURI) & PART OF SANJAY ENCLAVE (LIG FLATS)	2480	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	08:05	23-Jun-2020	08:40	35	0.00041	INTERRUPTION DUE TO FAULTS
380	23-Jun-2020	PARTS OF LAXMI VIHAR, VIRENDER NAGAR, ZONAL OFFICE, PART OF BURARI VILLAGE, SUNIL COLONY,F 2 BLK PRADHAN ENCLAVE & T/W SECTION.	1794	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	15:54	23-Jun-2020	16:07	13	0.00009	INTERRUPTION DUE TO FAULTS
381	23-Jun-2020	PARTS OF LAXMI VIHAR, VIRENDER NAGAR, ZONAL OFFICE, PART OF BURARI VILLAGE, SUNIL COLONY,F 2 BLK PRADHAN ENCLAVE & T/W SECTION.	1837	OTHER OUTAGE	UNPLANNED OUTAGE	23-Jun-2020	15:54	23-Jun-2020	16:17	23	0.00019	INTERRUPTION DUE TO FAULTS
382	23-Jun-2020	PARTS OF BL BLOCK SCHOOL, AD MARKET SHALIMAR BAGH	310	OTHER OUTAGE	PLANNED OUTAGE	23-Jun-2020	08:59	23-Jun-2020	14:48	349	0.00029	PLANNED OUTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
383	23-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	1591	OTHER OUTAGE	PLANNED OUTAGE	23-Jun-2020	11:21	23-Jun-2020	17:45	384	0.00171	PLANNED OUTAGE
384	24-Jun-2020	PART OF MKTJAHANGIR PURI SHALIMAR BAGH	7	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	11:12	24-Jun-2020	12:30	78	0.00004	SYSTEM SCHEDULE OUTAGE
385	30-Jun-20	PART OF MKTJAHANGIR PURI SHALIMAR BAGH	17	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	10:50	30-Jun-20	11:30	40	0.00002	INTERRUPTION DUE TO FAULTS
386	24-Jun-2020	PART OF JJ CLUSTER EE BLOCK JAHANGIR PURI	16	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	15:42	24-Jun-2020	16:12	30	0.00003	SYSTEM SCHEDULE OUTAGE
387	24-Jun-2020	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE HVDS VIJAY COLONY & JOGI MOHALLA	3784	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	16:49	24-Jun-2020	17:20	30	0.00029	INTERRUPTION DUE TO FAULTS
388	24-Jun-2020	PARTS OF KAUSHIK ENCLAVE A BLK,SURYA APPT.,MAIN SWAROOP NAGAR ROAD, SHAKTI ENCLAVE, BURARI GARHI FLATS, PART OF BURARI VILLAGE HVDS VIJAY COLONY & JOGI MOHALLA	2216	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	16:49	24-Jun-2020	17:40	50	0.00034	INTERRUPTION DUE TO FAULTS
389	20-Jun-2020	PARTS OF TRANSPORT AUTHORITY, DRIVING TRAINING SCHOOL, PRATIBHA INDUSTRIES	21	OTHER OUTAGE	UNPLANNED OUTAGE	20-Jun-2020	17:38	20-Jun-2020	18:00	22	0.00001	INTERRUPTION DUE TO FAULTS
390	24-Jun-2020	PARTS OF AB, AC, AD, AE BLOCK, BK BLOCK SHALIMAR BAGH, AA	626	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	00:05	24-Jun-2020	00:30	26	0.00004	INTERRUPTION DUE TO FAULTS
391	24-Jun-2020	PARTS OF AB, AC, AD, AE BLOCK, BK BLOCK SHALIMAR BAGH, AA	415	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	00:05	24-Jun-2020	01:23	78	0.00009	INTERRUPTION DUE TO FAULTS
392	24-Jun-2020	PARTS OF ARORA FARAM SNAT NAGAR SHALIMAR BAGH	1684	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	14:14	24-Jun-2020	15:04	50	0.00034	INTERRUPTION DUE TO FAULTS
393	24-Jun-2020	PARTS OF BHAGAT COLONY SHALIMAR BAGH	3243	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	19:56	24-Jun-2020	21:18	82	0.00068	INTERRUPTION DUE TO FAULTS
394	24-Jun-2020	PARTS OF BHAGAT COLONY SHALIMAR BAGH	8459	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	19:56	24-Jun-2020	21:28	92	0.00382	INTERRUPTION DUE TO FAULTS
395	24-Jun-2020	PARTS OF DJB,PART OF HIMGIRI ENCLAVE, A,B & A2 BLK, PART OF CHANDAN VIHAR & A2 BLK SANT NAGAR, HARIT VIHAR A B C & D BLK	1960	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	20:28	24-Jun-2020	20:48	20	0.00036	INTERRUPTION DUE TO FAULTS
396	24-Jun-2020	PART OF A BLOCK DDA SLUM FLATS	6	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	20:28	24-Jun-2020	22:05	96	0.00003	INTERRUPTION DUE TO FAULTS
397	24-Jun-2020	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK	442	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	21:32	24-Jun-2020	22:05	33	0.00014	INTERRUPTION DUE TO FAULTS
398	24-Jun-2020	PARTS OF INDIAN OIL, HP,& BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, ,RELIANCE TOWER, PART OF PARVATIANCHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN,	1004	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	10:55	24-Jun-2020	14:36	221	0.00061	PLANNED OUTAGE
399	24-Jun-2020	PARTS OF SSI INDUSTRIAL AREA BHALSWA	36	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	08:04	24-Jun-2020	13:00	296	0.00008	PLANNED OUTAGE
400	24-Jun-2020	PARTS OF BC, BD, BFH, WEST SHALIMAR BAGH, BH, BJ, BG BF EAST SHALIMAR BAGH, SAHI PUR VILLAGE, SHALAMR VILLAGE	625	630 kVA	PLANNED OUTAGE	24-Jun-2020	08:49	24-Jun-2020	11:45	175	0.00034	PLANNED OUTAGE
401	24-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	687	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	18:42	24-Jun-2020	19:20	38	0.00006	FORCE MAJEURE DUE TO SABOTAGE
402	24-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	2562	OTHER OUTAGE	PLANNED OUTAGE	24-Jun-2020	11:59	24-Jun-2020	19:20	440	0.00306	FORCE MAJEURE DUE TO SABOTAGE
403	25-Jun-2020	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK	33	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	07:34	25-Jun-2020	12:30	296	0.00008	FORCE MAJEURE DUE TO SABOTAGE
404	25-Jun-2020	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK	166	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	10:14	25-Jun-2020	12:30	136	0.00004	FORCE MAJEURE DUE TO SABOTAGE
405	25-Jun-2020	PARTS OF SSI INDUSTRIAL AREA BHALSWA	91	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	19:26	25-Jun-2020	20:15	49	0.00001	INTERRUPTION DUE TO FAULTS
406	25-Jun-2020	PARTS OF INDIAN OIL, HP,& BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, ,RELIANCE TOWER, PART OF PARVATIANCHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN,	1004	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	07:01	25-Jun-2020	08:00	59	0.00049	INTERRUPTION DUE TO FAULTS
407	25-Jun-2020	PARTS OF HINDUSTAN PETROLEUM SANT NAGAR SHALIMAR BAGH	677	630 kVA	PLANNED OUTAGE	25-Jun-2020	11:09	25-Jun-2020	15:31	262	0.00044	PLANNED OUTAGE
408	25-Jun-2020	PARTS OF GALI NO-12 SWAROOP NAGAR SHALIMAR BAGH	1843	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:18	25-Jun-2020	14:47	29	0.00122	INTERRUPTION DUE TO FAULTS
409	25-Jun-2020	PARTS OF BURARI TOMAR COLONY SHALIMAR BAGH	3102	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:37	25-Jun-2020	15:32	55	0.00161	INTERRUPTION DUE TO FAULTS
410	25-Jun-2020	PARTS OF LAXMI VIHAR, VIRENDER NAGAR, ZONAL OFFICE, PART OF BURARI VILLAGE, SUNIL COLONY,F 2 BLK PRADHAN ENCLAVE & T/W SECTION.	890	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	14:38	25-Jun-2020	15:40	62	0.00088	INTERRUPTION DUE TO FAULTS
411	25-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	1949	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	15:14	25-Jun-2020	15:38	24	0.00013	INTERRUPTION DUE TO FAULTS
412	25-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	4326	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	15:28	25-Jun-2020	16:27	58	0.00066	INTERRUPTION DUE TO FAULTS
413	25-Jun-2020	PARTS OF SSI INDUSTRIAL AREA BHALSWA	91	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	16:10	25-Jun-2020	17:00	50	0.00001	INTERRUPTION DUE TO FAULTS
414	25-Jun-2020	PARTS OF SSI INDUSTRIAL AREA BHALSWA	91	OTHER OUTAGE	PLANNED OUTAGE	25-Jun-2020	08:03	25-Jun-2020	12:45	282	0.00008	PLANNED OUTAGE
415	25-Jun-2020	PARTS OF HAIDER PUR VILLAGE & GOVIND MOHALLA	60	OTHER OUTAGE	PLANNED OUTAGE	25-Jun-2020	10:50	25-Jun-2020	14:15	205	0.00006	PLANNED OUTAGE
416	26-Jun-2020	PARTS OF I.P. COLONY BURARI SHALIMAR BAGH	626	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	13:13	26-Jun-2020	13:33	20	0.00014	INTERRUPTION DUE TO FAULTS
417	26-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	183	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	15:19	26-Jun-2020	15:43	24	0.00013	INTERRUPTION DUE TO FAULTS
418	26-Jun-2020	PARTS OF HAIDER PUR VILLAGE & GOVIND MOHALLA	730	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	05:42	26-Jun-2020	12:42	420	0.00350	FORCE MAJEURE DUE TO SABOTAGE
419	26-Jun-2020	PARTS OF HAIDER PUR VILLAGE & GOVIND MOHALLA	493	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	05:46	26-Jun-2020	06:30	44	0.00011	SYSTEM SCHEDULE OUTAGE
420	26-Jun-2020	PARTS OF RAJEEV NAGAR SHALIMAR BAGH	2248	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	12:19	26-Jun-2020	13:44	85	0.00123	INTERRUPTION DUE TO FAULTS
421	26-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	4326	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	13:45	26-Jun-2020	14:00	15	0.00031	INTERRUPTION DUE TO FAULTS
422	26-Jun-2020	PARTS OF NEEL KANTH APPRTMENT SHALIMAR BAGH	3555	OTHER OUTAGE	UNPLANNED OUTAGE	26-Jun-2020	16:00	26-Jun-2020	17:13	72	0.00111	INTERRUPTION DUE TO FAULTS
423	26-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	3249	OTHER OUTAGE	PLANNED OUTAGE	26-Jun-2020	10:00	26-Jun-2020	10:12	12	0.00011	PLANNED OUTAGE
424	26-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	516	OTHER OUTAGE	PLANNED OUTAGE	26-Jun-2020	17:36	26-Jun-2020	19:18	102	0.00014	FORCE MAJEURE DUE TO SABOTAGE
425	26-Jun-2020	PARTS OF KAUSHIK ENCLAVE B BLK, LAXMI VIHAR, VINDYASHREE APPT. & PART OF BURARI GARHI & VIRENDER NAGAR	3249	OTHER OUTAGE	PLANNED OUTAGE	26-Jun-2020	10:22	26-Jun-2020	19:18	536	0.00447	FORCE MAJEURE DUE TO SABOTAGE
426	26-Jun-2020	PARTS OF RAJASTHANI UDHYOG NAGAR SHALIMAR BAGH	75	OTHER OUTAGE	PLANNED OUTAGE	26-Jun-2020	10:25	26-Jun-2020	10:48	23	0.00001	PLANNED OUTAGE
427	26-Jun-2020	PARTS OF MAHINDRA PARK & SANJAY NAGAR	769	OTHER OUTAGE	PLANNED OUTAGE	26-Jun-2020	10:32	26-Jun-2020	12:52	140	0.00023	PLANNED OUTAGE
428	26-Jun-2020	PARTS OF NEAR B-3 MARKET, A-BlK JINDAL WALA	84	OTHER OUTAGE	PLANNED OUTAGE	26-Jun-2020	11:33	26-Jun-2020	13:44	131	0.00007	PLANNED OUTAGE
429	27-Jun-2020	PARTS OF BHALASWA VILLAGE, I BLK MCD SCHOOL	356	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	10:52	27-Jun-2020	14:02	190	0.00185	FORCE MAJEURE DUE TO SABOTAGE

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
430	27-Jun-2020	PART OF JJ CLUSTER EE BLOCK JAHANGIR PURI	9	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	11:28	27-Jun-2020	12:30	62	0.00003	INTERRUPTION DUE TO FAULTS
431	27-Jun-2020	PARTS OF INDIAN OIL, HP,& BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, ,RELIANCE TOWER, PART OF PARVATIANCHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN,	39	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	14:58	27-Jun-2020	15:49	51	0.00007	INTERRUPTION DUE TO FAULTS
432	27-Jun-2020	PARTS OF INDIAN OIL, HP,& BHARAT PETROL PUMP SANT NAGAR,BEGALI COLONY, POLICE COLONY, SANT NAGAR MAIN ROAD, LABOUR CHOWK, ,RELIANCE TOWER, PART OF PARVATIANCHAL,SHAGUN BENKET HALL SANT NAGAR, CABLE GODOWN,	1284	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	15:07	27-Jun-2020	15:52	45	0.00044	INTERRUPTION DUE TO FAULTS
433	27-Jun-2020	PARTS OF H2 AND E BLOCK MKT JAHANGIR PURI	2787	OTHER OUTAGE	UNPLANNED OUTAGE	27-Jun-2020	17:54	27-Jun-2020	18:17	24	0.00016	INTERRUPTION DUE TO FAULTS
434	27-Jun-2020	PARTS OF JAGAT PURVILLAGE, PART OF JAGAT PUR EXT., HVDS JAGAT PUR VILLAGE, GALI NO, 9, 5, ZERO JAGAT PUR VILLAGE, POCKET -8 SANT NAGAR, GALI NO 110 SANT NAGAR, APEX SXHOLL SANT NAGAR.	1308	OTHER OUTAGE	PLANNED OUTAGE	27-Jun-2020	12:31	27-Jun-2020	13:24	53	0.00019	PLANNED OUTAGE
435	28-Jun-2020	PARTS OF BHALASWA, SANT NAGAR , HVDS CAKT SANT NAGAR, MURGI FARM , KALI MANADIR, BEGALI COLONY,UPAKAR COLONY, CONSUMER CARE SANT NAGAR,MAIN MKT SANT NAGAR, BRAHAM KUMARA ASHARAM, CHAKU FACTORY	164	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	23:26	29-Jun-2020	00:30	64	0.00004	INTERRUPTION DUE TO FAULTS
436	28-Jun-2020	PARTS OF ARORA FARAM SNAT NAGAR SHALIMAR BAGH	347	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	01:19	28-Jun-2020	03:46	146	0.00028	FORCE MAJEURE DUE TO SABOTAGE
437	28-Jun-2020	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	178	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	07:49	28-Jun-2020	08:25	36	0.00005	INTERRUPTION DUE TO FAULTS
438	28-Jun-2020	PARTS OF JJ CLUSTER HAIDER PUR , HAIDERPUR DISPENSARY, BB EAST, LEPROSY COLONY JJ CLUSTER, SAHIPUR VILLAGE	248	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	11:48	28-Jun-2020	12:15	27	0.00004	INTERRUPTION DUE TO FAULTS
439	28-Jun-2020	PART OF JJ CLUSTER EE BLOCK JAHANGIR PURI	12	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	18:06	28-Jun-2020	18:36	30	0.00001	SYSTEM SCHEDULE OUTAGE
440	28-Jun-2020	PARTS OF RAJEEV NAGAR SHALIMAR BAGH	1974	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	03:18	28-Jun-2020	03:45	27	0.00022	INTERRUPTION DUE TO FAULTS
441	28-Jun-2020	PARTS OF LAXMI VIHAR, VIRENDER NAGAR, ZONAL OFFICE, PART OF BURARI VILLAGE, SUNIL COLONY,F 2 BLK PRADHAN ENCLAVE & T/W SECTION.	298	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	10:10	28-Jun-2020	11:30	80	0.00009	INTERRUPTION DUE TO FAULTS
442	28-Jun-2020	PART OF A BLOCK DDA SLUM FLATS	8	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	12:24	28-Jun-2020	12:54	30	0.00001	INTERRUPTION DUE TO FAULTS
443	28-Jun-2020	PARTS OF BHAGAT COLONY SHALIMAR BAGH	1008	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	16:06	28-Jun-2020	16:40	35	0.00012	INTERRUPTION DUE TO FAULTS
444	28-Jun-2020	PARTS OF HARDEV NAGAR, SURENDER COLONY PART 3, PART OF SANAGAM VIHAR, SURRENDER COLONY PART2, SHIV KUNJ, DEEPANSHU COLONY,	4133	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	16:24	28-Jun-2020	16:47	23	0.00077	INTERRUPTION DUE TO FAULTS
445	28-Jun-2020	PARTS OF JAGAT PUR EXT. NO.2, JAGAT PUR, MILLAN VIHAR, POCKET 5&6 SANAT NAGAR, MATA MANDIR SANT NAGAR, SHIV KUNJ, GALI NO. 65,69 SANT NAGAR, GALI NO.96, 95, 94,	4330	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	17:33	28-Jun-2020	18:10	37	0.00149	INTERRUPTION DUE TO FAULTS
446	28-Jun-2020	PARTS OF BURARI PRADHAN ENCLAVE BURARI SHALIMAR BAGH	1029	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	23:03	29-Jun-2020	01:36	153	0.00170	FORCE MAJEURE DUE TO SABOTAGE
447	28-Jun-2020	PARTS OF BURARI PRADHAN ENCLAVE BURARI SHALIMAR BAGH	4480	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	23:03	29-Jun-2020	01:37	154	0.00684	FORCE MAJEURE DUE TO SABOTAGE
448	28-Jun-2020	PARTS OF BHALSWA DAIRY SHALIMAR BAGH	680	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	23:54	29-Jun-2020	00:10	16	0.00004	INTERRUPTION DUE TO FAULTS
449	28-Jun-2020	PARTS OF GOPI WALA , JHARODA SCHOOL , BHAGWAN PARK, SURNDER COLONY PART 1 &2,,KAYAKALP HOSPITAL,	748	OTHER OUTAGE	UNPLANNED OUTAGE	28-Jun-2020	22:45	28-Jun-2020	23:25	40	0.00009	INTERRUPTION DUE TO FAULTS
450	29-Jun-20	PART OF A BLOCK DDA SLUM FLATS	3	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:57	29-Jun-20	19:15	78	0.00002	INTERRUPTION DUE TO FAULTS
451	29-Jun-20	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	19	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	12:45	29-Jun-20	13:45	60	0.00005	INTERRUPTION DUE TO FAULTS
452	1-Jun-2020	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	3	OTHER OUTAGE	UNPLANNED OUTAGE	1-Jun-2020	14:58	1-Jun-2020	19:00	241	0.00007	FORCE MAJEURE DUE TO SABOTAGE
453	2-Jun-2020	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	4	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	13:02	2-Jun-2020	19:34	392	0.00022	FORCE MAJEURE DUE TO FIRE
454	2-Jun-2020	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	2	OTHER OUTAGE	UNPLANNED OUTAGE	2-Jun-2020	11:00	2-Jun-2020	11:54	54	0.00002	INTERRUPTION DUE TO FAULTS
455	22-Jun-2020	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	18	OTHER OUTAGE	UNPLANNED OUTAGE	22-Jun-2020	14:36	22-Jun-2020	15:50	74	0.00008	SYSTEM SCHEDULE OUTAGE
456	23-Jun-2020	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	18	OTHER OUTAGE	PLANNED OUTAGE	23-Jun-2020	07:55	23-Jun-2020	12:45	290	0.00008	PLANNED OUTAGE
457	29-Jun-20	PARTS OF IP COLONY A,B & C BLK, DAYANAND ENCLAVE, PART OF KAUSHIK ENCLAVE A & B BLK, AMRIT VIHAR A,B, C & A1 BLK & SWAROOP NAGAR ROAD	1264	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	11:47	29-Jun-20	16:37	290	0.00105	PLANNED OUTAGE
458	29-Jun-20	PARTS OF A BLOCK DDA SLUM FLATS, PUNJABI CAMP , PART OF I & J BLK , PART OF A BLK	2129	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	10:30	29-Jun-20	14:48	258	0.00143	PLANNED OUTAGE
459	29-Jun-20	PARTS OF BHALASWA VILLAGE, I BLK MCD SCHOOL	233	OTHER OUTAGE	PLANNED OUTAGE	29-Jun-20	11:32	29-Jun-20	13:50	138	0.00012	PLANNED OUTAGE
460	29-Jun-20	PARTS OF INDIAN OIL NO-1 SHALIMAR BAGH	816	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	11:31	29-Jun-20	12:10	39	0.00013	INTERRUPTION DUE TO FAULTS
461	24-Jun-2020	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	3	OTHER OUTAGE	UNPLANNED OUTAGE	24-Jun-2020	16:07	24-Jun-2020	16:45	38	0.00001	SYSTEM SCHEDULE OUTAGE
462	29-Jun-20	PART OF BHALSWA JHEEL NO-2 MANDIRWALA SHALIMAR BAGH	19	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	15:10	29-Jun-20	15:40	30	0.00004	INTERRUPTION DUE TO FAULTS
463	29-Jun-20	PARTS OF KALANDER COLONY, PARTIAL AREA OF RAJEEV NAGAR	3288	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	15:29	29-Jun-20	15:40	11	0.00010	INTERRUPTION DUE TO FAULTS
464	29-Jun-20	PARTS OF AD BLK WAZIRPUR, A-31 TO 49 SIDE, A-23, AD-8 SIDE SHALIMAR BAGH	518	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	17:53	29-Jun-20	18:42	49	0.00007	INTERRUPTION DUE TO FAULTS
465	29-Jun-20	PARTS OF G BLOCK & G BLOCK J J CLUSTER (JAHANGIR PURI), H1 BLOCK (JAHANGIR PURI), MCD QUARTER (JAHANGIR PURI) SHALIMAR BAGH	38	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	23:58	30-Jun-20	00:25	27	0.00002	INTERRUPTION DUE TO FAULTS
466	25-Jun-2020	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	18	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	19:20	25-Jun-2020	20:15	55	0.00002	INTERRUPTION DUE TO FAULTS
467	29-Jun-20	PARTS OF JAHANGIRABAD, RADHA VIHAR, C&D BLOCK MUKUNDPUR, SAMTA VIHAR, ISHU VIHAR	3907	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	16:42	29-Jun-20	17:04	23	0.00028	INTERRUPTION DUE TO FAULTS
468	29-Jun-20	PARTS OF BADLI AND LABOUR CHOWK AREA SHALIMAR BAGH	579	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	15:45	29-Jun-20	16:35	50	0.00017	INTERRUPTION DUE TO FAULTS
469	29-Jun-20	PARTS OF SMA INDUSTRIAL AREA AND PART OF RAJASTHANI UDHYOG NAGAR	252	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	11:11	29-Jun-20	12:05	54	0.00012	INTERRUPTION DUE TO FAULTS
470	29-Jun-20	PARTS OF SMA INDUSTRIAL AREA AND PART OF RAJASTHANI UDHYOG NAGAR	46	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	14:04	29-Jun-20	14:30	26	0.00006	INTERRUPTION DUE TO FAULTS
471	29-Jun-20	PARTS OF JAHANGIRABAD, RADHA VIHAR, C&D BLOCK MUKUNDPUR, SAMTA VIHAR, ISHU VIHAR	1135	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:00	29-Jun-20	18:40	40	0.00020	INTERRUPTION DUE TO FAULTS
472	29-Jun-20	PARTS OF IP COLONY A,B & C BLK, DAYANAND ENCLAVE, PART OF KAUSHIK ENCLAVE A & B BLK, AMRIT VIHAR A,B, C & A1 BLK & SWAROOP NAGAR ROAD	1264	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	18:37	29-Jun-20	19:02	26	0.00020	INTERRUPTION DUE TO FAULTS
473	29-Jun-20	PARTS OF D BLOCK, E BLOCK, EE BLOCK, J J CLUSTER EE BLOCK JAHANGIR PURI, MUKUND PUR STREET LIGHT	1949	OTHER OUTAGE	UNPLANNED OUTAGE	29-Jun-20	20:54	29-Jun-20	21:20	26	0.00032	INTERRUPTION DUE TO FAULTS
474	25-Jun-2020	PART OF SSI INDUSTRIAL AREA SHALIMAR BAGH	18	OTHER OUTAGE	UNPLANNED OUTAGE	25-Jun-2020	16:07	25-Jun-2020	17:25	78	0.00002	INTERRUPTION DUE TO FAULTS
475	30-Jun-20	PARTS OF HINDUSTAN PETROLEUM AND SHIV KUNJ APPARTMENT SHALIMAR BAGH	4859	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	10:14	30-Jun-20	11:40	86	0.00167	INTERRUPTION DUE TO FAULTS

Sl.No.	Date	Area Affected	Number Of Consumers affected	Capacity Of Distribution Transformer (in 11KV)	Whether PLANNED OUTAGE or Unplanned	Outage Details				Duration (In Min)	Unserved (MU) due to Outage	Remarks
						From		To				
						Date	Time	Date	Time			
476	30-Jun-20	PARTS OF I & J BLOCK JAHANGIR PURI, PART OF VILLAGE BHALASVA, VILLAGE RAM GARH, PART OF SANJAY ENCLAVE (LIG FLATS)	312	OTHER OUTAGE	PLANNED OUTAGE	30-Jun-20	10:26	30-Jun-20	15:08	282	0.00024	PLANNED OUTAGE
477	30-Jun-20	PARTS OF BURARI TOMAR COLONY SHALIMAR BAGH	3103	OTHER OUTAGE	PLANNED OUTAGE	30-Jun-20	11:30	30-Jun-20	13:16	106	0.00074	PLANNED OUTAGE
478	30-Jun-20	PARTS OF AK BLOCK, AO BLOCK JJ CLUSTER NO-2	1076	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	03:13	30-Jun-20	04:12	58	0.00024	INTERRUPTION DUE TO FAULTS
479	30-Jun-20	PARTS OF AK BLOCK, AO BLOCK JJ CLUSTER NO-2	353	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	03:13	30-Jun-20	04:12	58	0.00008	INTERRUPTION DUE TO FAULTS
480	30-Jun-20	PARTS OF BK & BL BLOCKS SHALIMAR BAGH, SHALIMAR CLUB, AP BLOCK, BI BLOCK, AMBIENS MALL	307	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	03:55	30-Jun-20	04:06	11	0.00002	INTERRUPTION DUE TO FAULTS
481	30-Jun-20	PARTS OF BK & BL BLOCKS SHALIMAR BAGH, SHALIMAR CLUB, AP BLOCK, BI BLOCK, AMBIENS MALL	859	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	03:55	30-Jun-20	04:06	11	0.00005	INTERRUPTION DUE TO FAULTS
482	30-Jun-20	PARTS OF BHALSWA DAIRY, JJ CLUSTER AND KALANDER COLONY	217	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	11:06	30-Jun-20	12:20	74	0.00006	INTERRUPTION DUE TO FAULTS
483	30-Jun-20	PARTS OF HATHIWALA SANT NAGAR SHALIMAR BAGH	354	OTHER OUTAGE	UNPLANNED OUTAGE	30-Jun-20	18:29	30-Jun-20	19:22	53	0.00004	INTERRUPTION DUE TO FAULTS