## **Summary of Overall Standards of Performance**

Name of Company TATA Power-DDL

Period of Report Q4 FY 2022-23

SI.No.	Service Area	Overall Standards of Performance	Total Cases	Complaints Attended		Performance
			Received/ Reported (A)	Within Specified Time	Beyond specified time	achieved (%) (C)
1 Power Supply Failure Continuous power failure						
(i)	affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement.		51511	51442	69	99.87
(ii)	Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.	received should be rectified within	12564	12382	182	98.55
(iii)	Continuous power supply failure requiring replacement of distribution transformer.		90	89	1	98.89
(iv)	Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS) and not covered under (i) & (ii) above		33530	33444	86	99.74
(v)	Continuous scheduled power outages		1812	1796	16	99.12
(vi)	Replacement of burnt meter or stolen meter		712	709	3	99.58
		Period of sche	eduled outage			
2	Maximum duration in a single stretch	At least 95% of cases resolved within time	3005	3005	0	100.00
	Restoration of supply by 6:00 PM	limit	3005	2992	13	99.57
3	Faults in street light maintained by the Licensee	At least 90% cases should be complied within prescribed time limits	36587	36557	30	99.92
			Indices			
	SAIFI	To be laid down by the Commission	0.364			
4	SAIDI	based on the targets	0.217			
	CAIDI	proposed by the Licensees	0.596			
5	Frequency variation	To maintain supply frequency within range as per IEGC	0	0	0	-
6	Voltage imbalance	Maximum of 3% at point of commencement of supply	0	0	0	_
7	Percentage billing mistakes	Shall not exceeding 0.2%	1899	1919	1	0.03

<sup>#</sup> There are opening cases being attended during the year. Similarly cases exist being received /reported during the year but carried forward to next year.